



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 06, 2024

**Inspection Result:** NOT READY

**Permit Number:** PRCA20231634

**Property Address:** 304 2ND ST NE, PUYALLUP, WA 98372; 304 2ND AVE NE, PUYALLUP, WA 98372; 304 2ND ST NE, PUYALLUP, WA 98372;

**Contractor:** ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111  
Auburn, WA 98092

**To construct:** Remodel of existing McDonald's including: exterior facade upgrade w/kitchen area addition, demo and construction of non-structural partitions, remodel of dropped ceiling in Dining and Customer Service areas, new order counters, new menu boards, new kitchen equipment, new seating/decor in dining and revision of existing sidewalk to accommodate door relocation. `McDONALD'S REMODEL/ADDITION

On this day we have inspected your construction for **Footings/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

1. complete footings per city approved plans
2. not ready

Sincerely,

Kevin Spruell  
Building Inspector  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)