



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 09, 2024 **Inspection Result:** **NOT READY**

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND 58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 8/29/2024
4th floor framing of rooms
 1. provide collars at plumbing in shafts
 2. provide nail plates at wires at metal studs
 3. provide engineers fix for damaged floor truss
 4. ok to insulate rooms only as discussed with contractor
- 2 date of inspection 9/3/2024
 1. inspection of third floor of rooms only exterior wall and corridor wall head of wall top out approved
 2. ok to insulate as discussed with contractor
- 3 date of inspection 9/9/2024
 1. cancelled on site by contractor

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590