



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 09, 2024 **Inspection Result:** **NOT READY**

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; complete draftstop at floor joist as discussed with contractor.
2 ; provide U.L. listing for electrical penetration at 2 hour ceiling.
not ready

Corrections:

- 1 date of inspection 6/15/2024
 - 1.stairwell insulation approved
 - 2. all framing corrections in stairwell approved including engineering for attic access LEVEL 2
 - 1.R/C channel in corridor and all units approved
 - 2. insulation at bathroom ceilings and walls approved
- 2 date of inspection 8/6/2024
 - 1. rock wool at 4th floor ceiling in rated mech shaft approved
- 3 1. fire stop at plumbing in parking garage area approved

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive, flowing style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684