#### City of Puyallup

### **Engineering Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

Date of Inspection: Sep 12, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRCCP20231400

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: LINCOLN CONSTRUCTION INC 11803 101st Ave Ct E, Suite 201

Puyallup, WA 98373 (253) 847-6414

**To construct:** PARKING LOT A; PARKING IMPROVEMENTS: ASPHALT

PAVING; CONCRETE PAVING & STORMWATER ~ PIERCE COLLEGE

PARKING EXPANSION

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 9/11 - JL - Freeman Bell supposedly cleaned and repaired the silt fence. They also were supposed to keep the heavy silt out of the road. I will reinspect tomorrow.

9/12 - JL - Silt fence was repaired and should be finished correctly. Thank you very much for not working in the rain and creating a mess.

Note: See corrections below.

#### Corrections:

- 1 Keep the silt cleaned up off the road and near any CB. This directly discharges to an existing pond and into a steady running creek.
  - Silt fence should have a 1' overlap and the bottom flap burried.
  - Keep construction debris off roadway!
  - Maintain dust control!


Sincerely,



## City of Puyallup

# **Engineering Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org



Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 435-3636