



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 12, 2024                      **Inspection Result:**     **FAILED**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW \* REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT \* REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS \* REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 date of inspection 9/12/2024
  1. provide test on gas pipe as discussed with contractor (60 PSI)

Sincerely,

Kevin Spruell  
Building Inspector  
KSpruell@PuyallupWA.gov  
(253) 841-5590