



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 13, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCNC20221036

Property Address: 1601 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: ABSHER CONSTRUCTION CO. PO BOX 280 PUYALLUP, WA 98371-0152

To construct: New ~54,000 SF building containing labs, classrooms, faculty and student spaces. REVISION (1) -003/21/2023 - ADDED DETAILS & DESIGN REFINEMENT FROM PERMIT SET TO IFC SET OF DOCUMENTS (NO CHANGE IN SQ FTG OR COST)

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 9/9/2024
boiler room
 - 1.provide insulation at copper pipe west side of room
 2. complete insulation tape at pipe insulation
 - 3.remove smoke detector cover
- room 103F
 1. adjust hot water temp below 120 degrees
- room 128
 1. provide tag at hose bib (non-potable)
- room 135
 - 1.provide drain boot at fab lab sink next paint booth
- room 235
 - 1.repair eye wash station that is leaking
- room 233
 - 1.complete install of autoclave
 - 2.complete install of dishwasher
- room 318



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

1. install ice maker and hammer arrestor
room 312
1. complete faucet mottlab

Sincerely,

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590