



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 16, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCTI20221788

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Conversion of existing OR#1 Suite and Auxiliary spaces into a Hybrid OR Suite, reconfiguration of existing control room, storage, and sub-sterile room to accommodate new Hybrid OR Suite. REVISION (1) - 03/22/2024
REVISE STRUCTURAL DRAWINGS AND CALCS AND MINOR REVISIONS
AT CONTROL ROOM 2D02, OR 2D03, ELECTRONICS ROOM 2D09A.

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 room 2D02
 - 1 ; provide positive attachment of diffuser to main and cross-tee of grid.
 - 2 ; complete rated wall signage.
 - 3 ; complete berc clip.
 - 4 ; seal penetrations at 1 hour fire barrier.
- 2D05
 - 1 ; provide positive attachment of diffuser to main and cross-tee of grid.
 - 2 ; seal penetrations at 1 hour firewall.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684