



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 23, 2024                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW \* REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT \* REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS \* REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Firewall/Firestop Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1    1 ; complete firestop at condensate line at parking garage rated ceiling as discussed with contractor.
- 2 ; (ok to cover except area noted)

Sincerely,

Shannon King  
Building Inspector 2



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684