



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 23, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCA20231634

Property Address: 304 2ND ST NE, PUYALLUP, WA 98372; 304 2ND AVE NE, PUYALLUP, WA 98372; 304 2ND ST NE, PUYALLUP, WA 98372;

Contractor: ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111
Auburn, WA 98092

To construct: Remodel of existing McDonald's including: exterior facade upgrade w/kitchen area addition, demo and construction of non-structural partitions, remodel of dropped ceiling in Dining and Customer Service areas, new order counters, new menu boards, new kitchen equipment, new seating/decor in dining and revision of existing sidewalk to accommodate door relocation. `McDONALD'S REMODEL/ADDITION

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 9/23/2024
1.complete all plumbing R/I and put on test at time of next inspection as discussed with contractor

Sincerely,

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org