



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 24, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: E-21-0313

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790
DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790

To construct: PARKING LOT EXPANSION W. 675 STALLS,CFG~SHB-TC PARKING EXPANSION/BENAROYA

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 9/23 - JL - Site walk with Paul. Ready for punchlist.

9/24 - JL - Added conditions for punchlist. Punchlist is ready for review, then issuance.

Corrections:

- 1 - PL11 Establish wetland boundary, install wetland boundary signage, schedule a planning inspection through Rachael Brown @ RNBrown@PuyallupWA.gov
- PL14 Clean and hang all ladders in the type 2 structures.
- PL17 Install spalls around existing sewer c/o located in south bio-swale.
- PL15 Install island at entrance/exit off 39th, PER PRIOR CONDITION #8.
- PL20 Install structure bolts in grates where CB socks are not located.
- PL21 Install "sewer" c/o lids on all existing sewer c/o's. The addition of storm c/o's will confuse maintenance.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends from the right side of the signature.

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 435-3636