



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 24, 2024 **Inspection Result:** **PASSED**

Permit Number: PRCTI20231772

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: SELLEN 227 WESTLAKE AVE N SEATTLE, WA 98109 (206) 682-7770

To construct: Remodel of portion of emergency department to create spaces for treating lower acuity patients in open bays by removing some walls and installing wall mounted hand-wash sinks. Additionally will convert open room to become two separate rooms for holding patients requiring seclusion with enclosed workroom for staff to observe seclusion rooms. HVAC will be modified to serve the new spaces. Some electrical updates will also occur. - GOOD SAM HOSPITAL - ED

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org