



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 25, 2024                      **Inspection Result:**      **FAILED**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW \* REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT \* REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS \* REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete install of lights and electrical cover approval prior to ceiling grid inspection at floor 2-4 as discussed with contractor.  
not ready
- 2 1 ; complete tie wires at lights as discussed with contractor.  
2 ; complete sprinklers as discussed with contractor prior to next inspection.  
3 ; complete fire rated signage at fire walls above suspended ceiling.  
4 ; complete perimeter wires as discussed with contractor.  
5 ; complete fire caulk at penetrations still not completed at time of inspection.  
6 ; complete gas pipe test approval prior to ceiling cover approval.  
7 ; inspection of corridors ceilings at 3rd & 4th floors only. (except last 4' next to expansion joint & stack 39)

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large, prominent 'S' and 'K'.

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684