



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 26, 2024

Inspection Result: **FAILED**

Permit Number: PRRRSF20231418

Property Address: 907 18TH ST NW, PUYALLUP, WA 98371;

Contractor: GDK SERVICES LLC 7911 BRIGHT COURT SW OLYMPIA, WA 98512

To construct: Remove roof trusses off entire garage. Remove walls and slab from back of original garage that was added but not built to code. Repour new engineered slab and built walls on new section. Add engineered storage trusses over entire garage. * REV (1) 7/30/2024 - FIREWALL DETAILS & ENGINEER FOOTING

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 9/25/2024
 1. provide max rise of 7 3/4" at stairs as discussed with contractor
 2. provide rafter clips by stairs
 3. provide shear clarification on interior shear wall not noted on city approved plans
 4. complete all anchor bolts as discussed with contractor
 5. complete tie in at interior shear wall at ceiling
 6. complete RBC clips from top plate to bird blocks from details 1 and 3 of page S2 of city approved plans
 7. provide clarification at stairs where beam was added to support floor and stairs
 8. complete hangers at joist at stair landings and at floor at top of stairs
 9. complete truss bracing
 10. framing inspection will not be passed until building is weathered in

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590