



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 02, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: B-20-0180

Property Address: 3601 9TH ST SW, PUYALLUP, WA 98373;

Contractor: THARALDSON HOSPITALITY DEV LLC 4520 36TH AVE S FARGO, ND
58104 Roger Olson 4520 36th ave s fargo, ND 58104 (701) 850-9953

To construct: HOMEWOOD SUITES SOUTH HILL MALL MOTEL *FEE DEFERRAL-SWR*
REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD
PERIMETER DRAINTILE * REVISION (2) - 9/13/2024 - ADDITIONAL ROOM
& MOVE BREAK ROOM

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 date of inspection 6/24/2024
 1. gas pipe risers from 1st floor to roof approved at 10 psi as noted on page P-310 of city approved plans
 2. roof drains approved as marked up on page 309 of city approved plansFLOOR 5
 1. DWV and supply test (supply at 90 psi) approved at rooms 529,527,525,523,524,526,528,530 as marked up on city approved plans page P-21013FLOOR 4
 1. DWV and supply test (supply at 90 psi) approved at rooms 429,427,425,423,424,426,428,430 as marked up on city approved plans page P-208B
- 2 date of inspection 6/27/2024
 1. hot water circ line approved as marked up on page P-307 of city approved plans
 2. floors 4 and 5 DWV and supply approved as marked up on city approved plans page P-208
 3. rain drains approved as marked up on city approved plans page 309
- 3 date of inspection 7/2/2024
 1. 5th floor dwv and supply approved as marked up on P-210B of city approved plans



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

2. 4th floor dwv and supply approved as marked up on P-208B of city approved plans
3. rain drains approved as marked up on P-309 of city approved plans
4. date of inspection 7/31/2024
 1. DWV approved from elevator north floors 1,2,3
 2. supply same area failed retest
 3. rain liters same area to include front entryway approved
5. date of inspection 8/7/2024
 1. ADA VALVES 219, 319, 419,521 approved at 90 PSI east to west corridor
 1. DWV floors 1 thru 3 approved as marked up on city approved plans page P-202A, P-202B, P206A
 2. rain drains approved as marked up on page p-309 of city approved plans
 3. supply 2nd and 3rd floor approved at 90 PSI as marked up on city approved plans page P-307
6. date of inspection 8/13/2024
 1. 410 and 414 stack supply approved at 90 PSI as marked up on city approved plans pg P-307
7. date of inspection 8/28/2024
first floor
 1. gas line approved as marked up on PG P-310 of city approved plans
 2. water circ line approved as marked up on city approved plans PG P-307
8. date of inspection 10/2/2024
 1. plumbing approved as marked up on city approved plans PG P307

Sincerely,

Kevin Spruell
Building Inspector
KSpruell@PuyallupWA.gov
(253) 841-5590