



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 09, 2024 **Inspection Result:** **FAILED**

Permit Number: PRGR20240491

Property Address: 3112 E PIONEER, PUYALLUP, WA 98372; 911 SHAW RD, PUYALLUP, WA 98372; 901 SHAW RD, PUYALLUP, WA 98372; 813 SHAW RD, PUYALLUP, WA 98372;

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Grading for relocation and restoration of an existing stream at the East Town Crossing site. STREAM RELOCATION - EAST TOWN CROSSING

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The CESCL was on site today.

They had a sweeper running all day on Pioneer due to import of material.

See corrections. Please feel free to forward this to whomever.

Thank you

Corrections:

- 1 - All CB's on site need to be protected. CB socks where asphalt is placed. Silt fence around CB's in bare dirt areas.
 - All sewer CB's need the same protection. Install silt fence around them. The GI lids that are low and not grouted need to be treated the same way.
 - The existing pond is an active stormwater pond for the neighboring property. This needs to be protected and stabilized. Install silt fence around entire pond where exposed dirt is.
Note: If archeologists want to take responsibility for silt run off, the city, contractor, owner, and the CESCL will need a letter from them. This letter must state that they will take responsibility for silt runoff and maintain bare areas during the winter. If not, then a silt fence needs to be installed and/or hydroseed, straw and or jute matting.
 - Somehow flow control must be maintained during the wet season for the above pond.
 - The open trench heading towards the stream will need to be filled in.
Note: If this area is within the archeologist area then the same will apply for the note above. Letter, taking responsibility or allow work to be done somehow.



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Sincerely,

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 435-3636