



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 11, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRFS20241435

Property Address: 3500 S MERIDIAN, Unit: 410, PUYALLUP, WA 98373;

Contractor: KNIGHT FIRE PROTECTION 9702 LATHROP INDUSTRI DR SW OLYMPIA, WA 98512

To construct: Knight Fire Protection to modify the existing fire sprinkler system to accommodate new walls and ceilings in the tenant improvement area. - SHOE PALACE

On this day we have inspected your construction for **Fire Sprinkler Cover Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Sprinkler cover OK, check head in storeroom for clearance to surface mounted trough light which will be changed out for lower profile. Reviewed fire alarm locations at base of bar joist, advise to have fire alarm contractor review the installation prior to inspection two far from ceiling deck.

Corrections:

Sincerely,

Ray Cockerham
Building Code Official
RayC@PuyallupWA.gov
(253) 841-5585