

WATER

B-20-0180

Plumbing Fixture Plan Review

System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)

All water systems shall have water hammer arrestors and shall be accessible - Sec: 609.10 UPC

Appliances, Appurtenances or Fixtures	No Change to Existing Fixture	Existing Fixture Relocated or Replaced	Existing Fixture Removed Not Replaced	New Fixture Added Not a Replacement	FUW Count For Each Item	Total FUWs City to complete
Bathtub or combination bath/shower				1	4	
Bidet - Private					1	
Clothes washer					4	
Dental unit, cuspidor					1	
Dishwasher, domestic				1	1.5	
Drinking fountain or water cooler - Private/Public					0.5	
Drinking fountain or water cooler - Assembly					0.75	
Hose bib					2.5	
Hose bib, each additional					1	
Lavatory (bathroom sink)				1	1	
Pedicure basin					1	
Shower, per head					2	
SINKS						
Bar sink - Private					1	
Bar sink - Public					2	
Clinic Faucet - Public					3	
Clinic flushometer valve with/without faucet - Public					8	
Kitchen, domestic				1	1.5	
Laundry					1.5	
Service or mop basin - Private					1.5	
Service or mop basin - Public					3	
Wash-up, each set of faucets - Public					2	
Wash fountain, circular spray - Public					4	
URINALS					2	
Urinal, 1.0 GPF Flushometer valve - Public					4	
Urinal, 1.0 GPF Flushometer valve - Assembly					5	
Urinal, greater than 1.0 GPF Flushometer valve - Public					5	
Urinal, greater than 1.0 GPF Flushometer valve - Assembly					6	
Urinal, flush tank – Private or Public					2	
Urinal, flush tank - Assembly					3	
WATER CLOSETS						
Water closet, 1.6 GPF Gravity tank/Flushometer tank – Private/Public				1	2.5	
Water closet, 1.6 GPF Gravity tank/Flushometer tank – Assembly					3.5	
Water closet, 1.6 GPF Flushometer valve – Private/Public					2.5	
Water closet, 1.6 GPF Flushometer valve – Assembly					3.5	
Water closet, greater than 1.6 GPF Gravity tank – Private					3	
Water closet, greater than 1.6 GPF Gravity tank – Public					5.5	
Water closet, greater than 1.6 GPF Gravity tank – Assembly					7	
Water closet, greater than 1.6 GPF - Flushometer valve - Private					7	
Water closet, greater than 1.6 GPF - Flushometer valve - Public					8	
Water closet, greater than 1.6 GPF - Flushometer valve - Assembly					10	
TOTALS						

Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Steve Stackpole

DATE: 9-5-2024

TEL: 253-381-3543

EMAIL: sstackpole@tharaldsonco.com

SANITARY SEWER

B-20-0180

Plumbing Fixture Plan Review

System Development Charge Calculation Sheet Based on Fixture Unit Weight (FUW)

Appliances, Appurtenances or Fixtures	No Change to Existing Fixture	Existing Fixture Relocated or Replaced	Existing Fixture Removed Not Replaced	New Fixture Added Not a Replacement	FUW Count For Each Item	Total FUWs
Bathtub or combination bath/shower				1	2	
Bidet – 1 ¼”					1	
Bidet – 1 ½”					2	
Clothes washer, domestic, 2” standpipe					3	
Dental unit, cuspidor					1	
Dishwasher, domestic with independent drain					2	
Drinking fountain or water cooler – Private/Public					0.5	
Drinking fountain or water cooler – Assembly					1	
Floor drain					2	
Food waste grinder – commercial					3	
Lavatory, (bathroom sink)				1	1	
Lavatory, (bathroom sink) sets of 2 or 3					2	
Pedicure basin					1	
Shower, single head					2	
Shower, multi-head each additional					1	
Wash fountain, 1 ½”					2	
Wash fountain, 2”					3	
SINKS						
Bar sink - Private					1	
Bar sink – Public/Assembly					2	
Clinic, 3” Public/Assembly					6	
Commercial, 1 ½” with food waste					3	
Kitchen, domestic 1 ½” (with/without food waste grinder/dishwasher – Private/Public				1	2	
Laundry, 1 ½”					2	
Service sink /Mop basin, 2”/3”					3	
Service sink, flushing rim 3”					6	
Wash, each set of faucets – Public/Assembly					2	
URINALS						
Urinal, 2” integral trap 1.0 GPF – Private/Public					2	
Urinal, 2” integral trap 1.0 GPF – Assembly					5	
Urinal, 2” integral trap greater than 1.0 GPF – Private/Public					2	
Urinal, 2” integral trap greater than 1.0 GPF – Assembly					6	
Urinal, 1 ½” exposed trap – Private/Public					2	
Urinal, 1 ½” exposed trap – Assembly					5	
WATER CLOSETS						
Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Private				1	3	
Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Public					4	
Water closet, 1.6 GPF Gravity tank / flushometer tank / flushometer valve – Assembly					6	
Water closet, greater than 1.6 GPF Gravity tank / flushometer valve – Private					4	
Water closet, greater than 1.6 GPF Gravity tank / flushometer valve – Public					6	
Water closet, greater than 1.6 GPF Gravity tank / flushometer valve – Assembly					8	
TOTALS						

Contact Engineering Services for current System Development fee information

FORM PREPARED BY: Steve Stackpole

9-5-2024

DATE:

TEL: 253-381-3543

EMAIL: sstackpole@tharaldsonco.com

Rev 7/16

Referring to the previously approved plumbing fixture worksheet for B-20-0180 which was initialed by the City Reviewer (L.L.), provide an updated plumbing fixture worksheet for the total plumbing fixtures as now depicted on the revised plans. Do not count plumbing fixtures in any bedrooms. The only plumbing fixtures counted should include those in the commercial areas like the lobby, breakroom, pool area, kitchen etc. Only the sanitary sewer sheet is required to be filled out since water is provided by a different water purveyor. [PLUMBING FIXTURE WORKSHEET, sheet 2 of 2]