

STRUCTURAL FIXTURE ANCHORAGE CALCULATIONS



FOR

Puyallup, WA

310 31st Ave SE
Store #02403

PREPARED FOR

CITY OF PUYALLUP, WA



04/25/24

JBA PROJECT #2401802403

Calculation Index

[illegible]

PROJECT NO: 2401802403	Sheet No: 1	Of: 66
PROJECT NAME: #02403 - Puyallup, WA		
MADE BY: KSH	DATE: 04/19/24	
CHECKED BY:	DATE:	

Lateral Seismic Analysis

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

	Braced	Down Aisle		Store Latitude/Longitude Coordinates (per Google):
Response Modification Factor, $R =$	4.0	6.0	ASCE-7, Table 15.4-1	N 47° 09' 40" 47.1611
Overstrength Factor, $\Omega_o =$	2.0		ASCE-7, Table 15.4-1	W 122° 17' 20" 122.2889
Deflection Amplification Factor, $C_d =$	3.5		ASCE-7, Table 15.4-1	
Detail Reference Section =	15.5.3		ASCE-7, Table 15.4-1	
Occupancy Category =	II		IBC, Table 1604.5	
Importance Factor, $I_p =$	1.0		ASCE-7 Sect. 15.5.3	
0.2 Second Period Accel., $S_s =$	1.261 g		IBC Figs. 1613.2.1(1-10), ASCE-7 Figs. 22-1 thru 22-8	
1.0 Second Period Accel., $S_1 =$	0.435 g		IBC Figs. 1613.2.1(1-10), ASCE-7 Figs. 22-1 thru 22-8	
(Soil) Site Class =	D (Default)		IBC 1613.2.2 -> ASCE-7, Table 20.3-1	
$F_a =$	1.200		IBC Table 1613.2.3(1), ASCE-7 Table 11.4-1	
$F_v =$	1.865		IBC Table 1613.2.3(2), ASCE-7 Table 11.4-2 + Sect. 11.4.8	
$S_{MS} =$	1.513 g		IBC eq. 16-20, ASCE-7 eq. 11.4-1	
$S_{M1} =$	0.811 g		IBC eq. 16-21, ASCE-7 eq. 11.4-2	
$S_{DS} =$	0.841 g		IBC eq. 16-22, ASCE-7 eq. 11.4-3	
$S_{D1} =$	0.541 g		IBC eq. 16-23, ASCE-7 eq. 11.4-4	
Seismic Design Category				
--based on $S_{DS} =$	D		IBC Table 1613.2.5(1), ASCE-7 Table 11.6-1	
-- based on $S_{D1} =$	D		IBC Table 1613.2.5(2), ASCE-7 Table 11.6-2	

Shelving Fixture

$C_s =$	0.210	RMI sect. 2.6.3 w/ ASCE-7, Sect. 11.4.8
$C_{s1}, \text{min} =$	0.037	RMI sect. 2.6.3 and ASCE-7 sect. 15.5.3
Base Shear, $V = C_s I_p W =$	0.210 W	RMI sect. 2.6.2

Rack Fixture

	Braced	Down Aisle	
Period, $T (H_{\text{rack}} \leq 96") =$	0.265	1.249 sec. - RMI sect. 2.6.3	$T_s, (S_{D1}/S_{DS}) = 0.643 \text{ sec.}$
Period, $T (96" < H_{\text{rack}} \leq 120") =$	0.483	1.182 sec. - RMI sect. 2.6.3	$T_L = 6 \text{ sec.}$
Period, $T (H_{\text{rack}} > 120") =$	0.352	1.348 sec. - RMI sect. 2.6.3	
Period, $T (H_{\text{rack}} = 168" \text{ w/Base Isolator}) =$	NA	NA sec. - RMI sect. 2.6.3 <--- Not Applicable for this project	
$C_s (H_{\text{rack}} \leq 96") =$	0.210	0.072 --> $\min[S_{DS}/R, S_{D1}/((T)(R))]$	
$C_s (96" < H_{\text{rack}} \leq 120") =$	0.210	0.076 --> $\min[S_{DS}/R, S_{D1}/((T)(R))]$	
$C_s (H_{\text{rack}} > 120") =$	0.210	0.067 --> $\min[S_{DS}/R, S_{D1}/((T)(R))]$	
$C_s (H_{\text{rack}} = 168" \text{ w/Base Isolator}) =$	NA	NA --> $\min[S_{DS}/R, S_{D1}/((T)(R))]$	
$C_{s1}, \text{min} =$	0.037	0.037 --> RMI sect. 2.6.3 and ASCE-7 sect. 15.5.3	

Base Shear:

	Braced	Down Aisle
$V (H_{\text{rack}} \leq 96") = C_s I_p W_s =$	0.210	0.072 W_s --> RMI sect. 2.6.2
$V (96" < H_{\text{rack}} \leq 120") = C_s I_p W_s =$	0.210	0.076 W_s --> RMI sect. 2.6.2
$V (H_{\text{rack}} > 120") = C_s I_p W_s =$	0.210	0.067 W_s --> RMI sect. 2.6.2
$V (H_{\text{rack}} = 168" \text{ w/Base Iso}) = C_s I_p W_s =$	NA	NA W_s --> RMI sect. 2.6.2

Load Combinations for LRFD Member Design (RMI, Section 2.2):

for RISA Frame analysis

LC #1: 1.4DL + 1.2PL	DL = Dead Load
LC #2: 1.2DL + 1.4PL	PL = Maximum load from pallets/product stored on racks
LC #7a: $(0.9-0.2S_{DS})DL + (0.9-0.2S_{DS})PL_{\text{app}} + \rho(1.0)EL$ <--- $PL_{\text{app}} = (0.67)PL$ at each shelf level; $\rho = 1.3$ at "Braced" frames	EL = Seismic Load - RMI section 2.6.6 - Vert. Distribution
0.7318 DL 0.7318 PL_{app} 1.0000 EL	
LC #7b: $(0.9-0.2S_{DS})DL + (0.9-0.2S_{DS})PL_{\text{app}} + \rho(1.0)EL$ <--- $PL_{\text{app}} = (1.0)PL$ at top shelf only; $\rho = 1.3$ at "Braced" frames	
0.7318 DL 0.7318 PL_{app} 1.0000 EL	
LC #5: $(1.2+0.2S_{DS})DL + (0.85+0.2S_{DS})\beta PL + \rho(1.0)EL$ <--- $\rho = 1.3$ at "Braced" frames, $\beta = 0.7$, RMI, sect. 2.1	
1.3682 DL 0.7127 PL 1.0000 EL	

PROJECT NO: 2401802403	Sheet No: 2	Of: 66
PROJECT NAME: #02403 - Puyallup, WA		
MADE BY: KSH	DATE: 04/19/24	
CHECKED BY:	DATE:	

Lateral Seismic Analysis

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

	Braced	Down Aisle		Store Latitude/Longitude Coordinates (per Google):
Response Modification Factor, $R =$	4.0	6.0	ASCE-7, Table 15.4-1	N 47° 09' 40" 47.1611
Overstrength Factor, $\Omega_o =$	2.0		ASCE-7, Table 15.4-1	W 122° 17' 20" 122.2889
Deflection Amplification Factor, $C_d =$	3.5		ASCE-7, Table 15.4-1	
Detail Reference Section =	15.5.3		ASCE-7, Table 15.4-1	
Occupancy Category =	II		IBC, Table 1604.5	
Importance Factor, $I_p =$	1.5		ASCE-7 Sect. 15.5.3	
0.2 Second Period Accel., $S_s =$	1.261 g		IBC Figs. 1613.2.1(1-10), ASCE-7 Figs. 22-1 thru 22-8	
1.0 Second Period Accel., $S_1 =$	0.435 g		IBC Figs. 1613.2.1(1-10), ASCE-7 Figs. 22-1 thru 22-8	
(Soil) Site Class =	D (Default)		IBC 1613.2.2 -> ASCE-7, Table 20.3-1	
$F_a =$	1.20		IBC Table 1613.2.3(1), ASCE-7 Table 11.4-1	
$F_v =$	1.87		IBC Table 1613.2.3(2), ASCE-7 Table 11.4-2 + Sect. 11.4.8	
$S_{MS} =$	1.513 g		IBC eq. 16-20, ASCE-7 eq. 11.4-1	
$S_{M1} =$	0.811 g		IBC eq. 16-21, ASCE-7 eq. 11.4-2	
$S_{DS} =$	0.841 g		IBC eq. 16-22, ASCE-7 eq. 11.4-3	
$S_{D1} =$	0.541 g		IBC eq. 16-23, ASCE-7 eq. 11.4-4	
Seismic Design Category				
--based on $S_{DS} =$	D		IBC Table 1613.2.5(1), ASCE-7 Table 11.6-1	
-- based on $S_{D1} =$	D		IBC Table 1613.2.5(2), ASCE-7 Table 11.6-2	

Shelving Fixture

$C_s =$	0.210	RMI sect. 2.6.3 w/ ASCE-7, Sect. 11.4.8
$C_{s1}, \text{min} =$	0.037	RMI sect. 2.6.3 and ASCE-7 sect. 15.5.3
Base Shear, $V = C_s I_p W =$	0.315 W	RMI sect. 2.6.2

Rack Fixture


	Braced	Down Aisle	
Period, $T (H_{\text{rack}} \leq 96") =$	0.265	1.249 sec.	- RMI sect. 2.6.3
Period, $T (96" < H_{\text{rack}} \leq 120") =$	0.483	1.182 sec.	- RMI sect. 2.6.3
Period, $T (H_{\text{rack}} > 120") =$	0.352	1.348 sec.	- RMI sect. 2.6.3
Period, $T (H_{\text{rack}} = 168" \text{ w/Base Isolator}) =$	NA	NA sec.	- RMI sect. 2.6.3 <--- Not Applicable for this project
$C_s (H_{\text{rack}} \leq 96") =$	0.210	0.072	--> $\min[S_{DS}/R, S_{D1}/((T)(R))]$
$C_s (96" < H_{\text{rack}} \leq 120") =$	0.210	0.076	--> $\min[S_{DS}/R, S_{D1}/((T)(R))]$
$C_s (H_{\text{rack}} > 120") =$	0.210	0.067	--> $\min[S_{DS}/R, S_{D1}/((T)(R))]$
$C_s (H_{\text{rack}} = 168" \text{ w/Base Isolator}) =$	NA	NA	--> $\min[S_{DS}/R, S_{D1}/((T)(R))]$
$C_{s1}, \text{min} =$	0.037	0.037	--> RMI sect. 2.6.3 and ASCE-7 sect. 15.5.3

Base Shear:

	Braced	Down Aisle	
$V (H_{\text{rack}} \leq 96") = C_s I_p W_s =$	0.315	0.108 W_s	--> RMI sect. 2.6.2
$V (96" < H_{\text{rack}} \leq 120") = C_s I_p W_s =$	0.315	0.114 W_s	--> RMI sect. 2.6.2
$V (H_{\text{rack}} > 120") = C_s I_p W_s =$	0.315	0.100 W_s	--> RMI sect. 2.6.2
$V (H_{\text{rack}} = 168" \text{ w/Base Iso}) = C_s I_p W_s =$	NA	NA W_s	--> RMI sect. 2.6.2

Gondola (Shelving) Anchorage Design - Load Diagrams

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)



Base Shear, RMI, sect. 2.6.2:

$$V = (C_s)(I_p)(W_s)$$

C_s, I_p, C_s based on frame height and $I_p = 1.0$ or 1.5 with Public Access

$$W_s = (0.67)(PL_{RF})(PL) + DL$$

$PL_{RF} = 1.0$, for Cross-Aisle frames

$PL = (0.67)PL$, for RMI, sect. 2.6.9(1) & ASCE 7, 15.5.3.6(a)

$(1.0)PL$, for RMI, sect. 2.6.9(2) & ASCE 7, 15.5.3.6(b)

Overturning Stability:

Center of Mass (CM) of Product Load (PL) is typically 6" above the shelf or $(1/2)(\text{Shelf height}, H_i)$ when shelf height is $< 12"$.

$F_x = 1.0n$, is set at a Service Load level using $V = (0.7)[C_s I_p W_s]$

Load Case #1: (2/3)PL at each shelf level

RMI, sect.2.6.9(1) & ASCE 7, 15.5.3.3.2(a)

$\omega_x = (0.67)PL$	$h_x = y_i$	$(0.7V)(\omega_x)(h_x)$		Overt'n'g Mom, M_{OT}	Resist'g Mom, M_{RST}
		$(\omega_x)(h_x)$	$\Sigma \omega_x h_x$		
ω_5	y_5	$(\omega_5)(y_5)$	F_5	$(F_5)(y_5)$	$\omega_5(D/2)$
ω_4	y_4	$(\omega_4)(y_4)$	F_4	$(F_4)(y_4)$	$\omega_4(D/2)$
ω_3	y_3	$(\omega_3)(y_3)$	F_3	$(F_3)(y_3)$	$\omega_3(D/2)$
ω_2	y_2	$(\omega_2)(y_2)$	F_2	$(F_2)(y_2)$	$\omega_2(D/2)$
ω_1	y_1	$(\omega_1)(y_1)$	F_1	$(F_1)(y_1)$	$\omega_1(D/2)$
$\omega_u = DL_{frame}$	$y_u = Ht/2$	$(\omega_u)(y_u)$	F_u	$(F_u)(y_u)$	$\omega_u(D/2)$
		$\Sigma (\omega_x)(h_x)$	$\Sigma (F_u + F_i) = 0.7V$	$M_{OT} = \Sigma (F)(y)$	$M_{RST} = \Sigma (\omega)(D/2)$

Load Case #2: (1.0)PL at top shelf level only

RMI, sect.2.6.9(2) & ASCE 7, 15.5.3.3.2(b)

$\omega_x = (1.0)PL$	$h_x = y_i$	$(0.7V)(\omega_x)(h_x)$		Overt'n'g Mom, M_{OT}	Resist'g Mom, M_{RST}
		$(\omega_x)(h_x)$	$\Sigma \omega_x h_x$		
ω_5	y_5	$(\omega_5)(y_5)$	F_5	$(F_5)(y_5)$	$\omega_5(D/2)$
$\omega_u = DL_{frame}$	$y_u = Ht/2$	$(\omega_u)(y_u)$	F_u	$(F_u)(y_u)$	$\omega_u(D/2)$
		$\Sigma (\omega_x)(h_x)$	$\Sigma (F_u + F_5) = 0.7V$	$M_{OT} = \Sigma (F)(y)$	$M_{RST} = \Sigma (\omega)(D/2)$

Design Shelf Loads:

- 9" Shelf = 15 lbs/shelf (Pharmacy)
- 12" Shelf = 50 lbs/shelf
- 15"-16" Shelf = 50 lbs/shelf (incl Apparel)
- 18"-20" Shelf = 125 lbs/shelf
- 24"+ Shelf = 150 lbs/shelf
- = 100 lbs/shelf (End Cap)
- = 225 lbs/shelf (Grocery)
- 30" (HD TV) Shelf = 75 lbs/shelf

No. of Shelf Levels / Fixture Height (Ht):

- (4) Levels at $Ht \leq 48"$
- (5) Levels at $48" < Ht \leq 90"$
- (7) Levels at $Ht > 90"$
- (4) Levels at "24V" & "24X" (Full) = 69" & 81" (Top Shelf)
- (4) Levels at HD TV = 96" (Top Shelf) (120" tall fixture)
- (9) Levels at Pharmacy = 84" ("3RX" fixture)

Factor Of Safety against Overturning at Load Case #1 & #2, $FOS_{OT} = M_{RST}/M_{OT}$:

$FOS_{OT} < 1.0$; Anchor Bolts required for both Shear & Tension

$FOS_{OT} \geq 1.0$; Anchor Bolts required for Shear only, no net uplift tension at base connection

$FOS_{OT} \geq 1.5$; No Anchor Bolts required (Except for Half Gondola Frames per owner's requirements)

Anchorage Connection Design Load Combinations: RMI, section 2.2 - Strength Design

RMI LC #7: $(0.9-0.2S_{DS})DL + (0.9-0.2S_{DS})(0.67)PL - \Omega_0(EL)$, for Load Case #1


Shear, $R_{uh} = (\Omega_0)V/2$

$(0.9-0.2S_{DS})DL + (0.9-0.2S_{DS})PL - \Omega_0(EL)$, for Load Case #2

Tension, $R_{uv} = [(\Omega_0 M_{OT}/0.7) - (0.9-0.2S_{DS})M_{RST}]/(\text{FrameDepth})$

Racking Anchorage Design - Frame Load Diagram

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)



Base Shear, RMI, sect. 2.6.2:

$$V = (C_s)(I_p)(W_s) \quad C_s I_p, C_s \text{ based on frame height and } I_p = 1.0 \text{ or } 1.5 \text{ with Public Access}$$

$$W_s = (0.67)(PL_{RF})(PL) + DL$$

$$PL_{RF} = 1.0 \text{ for Cross-Aisle and Down-Aisle frames}$$

$$PL = (0.67)PL \text{ for RMI, sect. 2.6.9(1) \& ASCE 7, 15.5.3.3.2(a)}$$

$$(1.0)PL \text{ for RMI, sect. 2.6.9(2) \& ASCE 7, 15.5.3.3.2(b)}$$

Overtuning Stability:

Center of Mass (CM) of Product Load (PL) is typically 20" above the shelf or (1/2)(Shelf height, H_i) when shelf height is < 40" (which is the assumed pallet height).

$$F_{x=1..n}, \text{ is set at a Service Load level using } V = (0.7)[C_s I_p W_s]$$

Load Case #1: (2/3)PL at each shelf level, RMI, sect.2.6.9(1) & ASCE 7, 15.5.3.3.2(a)

$\omega_x =$ (0.67)PL	$h_x = y_i$	(0.7V)(ω_x)(h_x)		Overtun'g Mom, M_{OT}	Resist'g Mom, M_{RST}
		(ω_x)(h_x)	$\Sigma \omega_x h_x$		
ω_4	y_4	(ω_4)(y_4)	F_{x4}	(F_{x4})(y_4)	$\omega_4(D/2)$
ω_3	y_3	(ω_3)(y_3)	F_{x3}	(F_{x3})(y_3)	$\omega_3(D/2)$
ω_2	y_2	(ω_2)(y_2)	F_{x2}	(F_{x2})(y_2)	$\omega_2(D/2)$
ω_1	y_1	(ω_1)(y_1)	F_{x1}	(F_{x1})(y_1)	$\omega_1(D/2)$
$\omega_u = DL_{frame}$	$y_u = Ht/2$	(ω_u)(y_u)	F_{xu}	(F_{xu})(y_u)	$\omega_u(D/2)$
		$\Sigma (\omega_x)(h_x)$	$\Sigma (F_{xu} + F_{xu}) = 0.7V$	$M_{OT} = \Sigma (F)(y)$	$M_{RST} = \Sigma (\omega)(D/2)$

Load Case #2: (1.0)PL at top shelf level only, RMI, sect.2.6.9(2) & ASCE 7, 15.5.3.3.2(b)

$\omega_x =$ (1.0)PL	$h_x = y_i$	(0.7V)(ω_x)(h_x)		Overtun'g Mom, M_{OT}	Resist'g Mom, M_{RST}
		(ω_x)(h_x)	$\Sigma \omega_x h_x$		
ω_4	y_4	(ω_4)(y_4)	F_{x4}	(F_{x4})(y_4)	$\omega_4(D/2)$
$\omega_u = DL_{frame}$	$y_u = Ht/2$	(ω_u)(y_u)	F_{xu}	(F_{xu})(y_u)	$\omega_u(D/2)$
		$\Sigma (\omega_x)(h_x)$	$\Sigma (F_{xu} + F_{xu}) = 0.7V$	$M_{OT} = \Sigma (F)(y)$	$M_{RST} = \Sigma (\omega)(D/2)$

Factor Of Safety against Overturning at Load Case #1 & #2, $FOS_{OT} = M_{RST}/M_{OT}$:

$FOS_{OT} < 1.0$; Anchor Bolts required for both Shear & Tension

$FOS_{OT} \geq 1.0$; Anchor Bolts required for Shear only, no net uplift tension at base connection

$FOS_{OT} \geq 1.5$; Anchor Bolts required for Shear only for frames 96" tall and taller at sales floor area and for all frames taller than 48" in storage areas (non sales floor).

Anchorage Connection Design Load Combinations: RMI, section 2.2 - Strength Design

RMI LC #6: (0.9-0.2 S_{DS})DL + (0.9-0.2 S_{DS})(0.67)PL - Ω_o (EL), for Load Case #1

Shear, $R_{uh} = (\Omega_o)V/2$

(0.9-0.2 S_{DS})DL + (0.9-0.2 S_{DS})PL - Ω_o (EL), for Load Case #2

Tension, $R_{uw} = [(\Omega_o M_{OT}/0.7) - (0.9-0.2S_{DS})M_{RST}]/(\text{FrameDepth})$

Rack Frame Member Design Load Combinations: RMI, section 2.2 - Strength Design

RMI LC #1: 1.4DL + 1.2PL

Redundancy factor, $\rho = 1.0$

<- SDC "A"/"B"/"C", RMI, sect. 2.6.2.1

RMI LC #2: 1.2DL + 1.4PL

1.3

<- SDC "D"/"E"/"F", RMI, sect. 2.6.2.1

RMI LC #5: (1.2+0.2 S_{DS})DL + (0.85+0.2 S_{DS})(0.67) β PL + ρ EL, for Load Case #1

$\beta = 0.7$, RMI, sect. 2.1

(1.2+0.2 S_{DS})DL + (0.85+0.2 S_{DS}) β PL + ρ EL, for Load Case #2

RMI LC #7: (0.9-0.2 S_{DS})DL + (0.9-0.2 S_{DS})(0.67)PL - ρ EL, for Load Case #1

(0.9-0.2 S_{DS})DL + (0.9-0.2 S_{DS})PL - ρ EL, for Load Case #2


Rack Framing Member Design: RMI, section 6.3

Per ANSI/MH16.1, Section 6.3, effective lengths may be determined by rational methods consistent with AISI or AISC. AISC Design by Second-Order Analysis, Section C2.2a is used. Notional loads are applied to gravity load cases and $K=1.0$ is used since the ratio of second-order drift to first-order drift $(P-\delta) / (P-\Delta) < 1.1$.

Shelving / Single Sided 48" Tall "R" 4 Level 18R

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	125 lbs
# of Levels =	Wall 4 Level
Uniform Weight per level =	20.83 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	18 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	0 in
h ₄ =	14 in
h ₃ =	14 in
h ₂ =	14 in
h ₁ =	6 in
Total Shelf Height, H _t =	48 in
Unit Height, H _u =	48 in
Unit Base Depth, D =	11 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 324.5 lbs

Base Shear, V = C_sI_pW_s = 102.3 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 0.0 lbs @ 0 in (CM)

F₄ = 24.1 lbs @ 54 in (CM)

F₃ = 17.8 lbs @ 40 in (CM)

F₂ = 11.6 lbs @ 26 in (CM)

F₁ = 5.4 lbs @ 12 in (CM)

F_u = 12.8 lbs @ 24 in (CM)

ΣF_i = 102.3 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2686 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 2383 in-lbs

Factor of Safety

FOS = 0.887

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 183.8 lbs

Base Shear, V = C_sI_pW_s = 58.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 0.0 lbs

F₄ = 29.9 lbs @ 54 in (CM)

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.6 lbs @ 24 in (CM)

ΣF_i = 58.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 1871 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1238 in-lbs


Factor of Safety

FOS = 0.661

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	36 lbs	20 lbs
R _v =	27 lbs (Uplift)	58 lbs (Uplift)
Overturning FOS =	0.887 < 1.5--ABs Req'd	0.661 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	102lbs / 2.837 >= 1.5 OK	65lbs / 3.229 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	102 lbs	58 lbs
Net Uplift (R _{uv}) =	539 lbs	404 lbs
Overturning + Gravity (P _u) =	844 lbs	495 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	539 lbs	404 lbs
max tension stress ratio (TSR) =	0.222 OK	0.166 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	102 lbs	58 lbs
Max shear stress ratio (VSR) =	0.067 OK	0.038 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.289 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 48" Tall "R" 4 Level


18R

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	844 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.093 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	447 lbs
Area reqd. for bearing (A_{reqd}) =	0.30 ft ²
"b" distance =	6.55 in
Slab thickness (t) =	4.00 in
$S = (1^*)t^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	20 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2^*))^2)/3$ =	33.94 in-lb/in - Defl. End M1 = 17 in-lb/in
$M_u / \phi M_{nt}$ =	0.048 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	11 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	7.8 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1559 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	72938 in*lbs

Load Combination #1:	M_{OT} =	2686 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	75321 in*lbs
	Total Overturning FOS =	28.046 OK


Load Combination #2:	M_{OT} =	1871 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	74175 in*lbs
	Total Overturning FOS =	39.638 OK



Shelving / Single Sided 54" Tall "S" 5 Level 18S

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	125 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	20.83 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	18 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	12 in
h ₄ =	12 in
h ₃ =	12 in
h ₂ =	12 in
h ₁ =	6 in
Total Shelf Height, H _t =	54 in
Unit Height, H _u =	54 in
Unit Base Depth, D =	11 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 380.6 lbs

Base Shear, V = C_sI_pW_s = 120.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 23.8 lbs @ 60 in (CM)

F₄ = 19.0 lbs @ 48 in (CM)

F₃ = 14.3 lbs @ 36 in (CM)

F₂ = 9.5 lbs @ 24 in (CM)

F₁ = 4.8 lbs @ 12 in (CM)

F_u = 12.8 lbs @ 27 in (CM)

ΣF_i = 120.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 3480 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 2842 in-lbs

Factor of Safety

FOS = 0.817

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 183.8 lbs

Base Shear, V = C_sI_pW_s = 58.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 29.8 lbs @ 60 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.7 lbs @ 27 in (CM)

ΣF_i = 58.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2080 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1238 in-lbs


Factor of Safety

FOS = 0.595

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	42 lbs	20 lbs
R _v =	58 lbs (Uplift)	77 lbs (Uplift)
Overturning FOS =	0.817 < 1.5--ABs Req'd	0.595 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	127 lbs / 3.015 >= 1.5 OK	70 lbs / 3.463 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	120 lbs	58 lbs
Net Uplift (R _{uv}) =	715 lbs	458 lbs
Overturning + Gravity (P _u) =	1061 lbs	535 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	715 lbs	458 lbs
max tension stress ratio (TSR) =	0.295 OK	0.189 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	120 lbs	58 lbs
Max shear stress ratio (VSR) =	0.078 OK	0.038 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.373 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 54" Tall "S" 5 Level


18S

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1061 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.117 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	554 lbs
Area reqd. for bearing (A_{reqd}) =	0.37 ft ²
"b" distance =	7.29 in
Slab thickness (t) =	4.00 in
$S = (1^*)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	20 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	46.57 in-lb/in - Defl. End M1 = 24 in-lb/in
$M_u / \phi M_{nt}$ =	0.066 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} w l$
$R = V$	$= w l$
V_x	$= w x$
M max. (at fixed end)	$= \frac{w l^2}{3}$
M_x (at deflected end)	$= \frac{w l^2}{6}$
M_x	$= \frac{w l^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{w l^4}{24 E I}$
Δx	$= \frac{w l^4}{24 E I} (1^2 - 3x^2)$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	11 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	7.8 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1559 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	72938 in*lbs

Load Combination #1:	$M_{OT} =$	3480 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	75779 in*lbs
	Total Overturning FOS =	21.778 OK


Load Combination #2:	$M_{OT} =$	2080 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	74175 in*lbs
	Total Overturning FOS =	35.669 OK



Shelving / Single Sided 60" Tall "T" 5 Level 18T

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	125 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	20.83 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	18 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	13.5 in
h ₄ =	13.5 in
h ₃ =	13.5 in
h ₂ =	13.5 in
h ₁ =	6 in
Total Shelf Height, H _t =	60 in
Unit Height, H _u =	60 in
Unit Base Depth, D =	11 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 380.6 lbs

Base Shear, V = C_sI_pW_s = 120.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 24.0 lbs @ 66 in (CM)

F₄ = 19.1 lbs @ 52.5 in (CM)

F₃ = 14.2 lbs @ 39 in (CM)

F₂ = 9.3 lbs @ 25.5 in (CM)

F₁ = 4.4 lbs @ 12 in (CM)

F_u = 13.0 lbs @ 30 in (CM)

ΣF_i = 120.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 3823 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 2842 in-lbs

Factor of Safety

FOS = 0.743

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 183.8 lbs

Base Shear, V = C_sI_pW_s = 58.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 29.7 lbs @ 66 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.8 lbs @ 30 in (CM)

ΣF_i = 58.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2288 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1238 in-lbs


Factor of Safety

FOS = 0.541

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	42 lbs	20 lbs
R _v =	89 lbs (Uplift)	95 lbs (Uplift)
Overturning FOS =	0.743 < 1.5--ABs Req'd	0.541 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	134 lbs / 3.201 >= 1.5 OK	75 lbs / 3.696 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	120 lbs	58 lbs
Net Uplift (R _{uv}) =	804 lbs	512 lbs
Overturning + Gravity (P _u) =	1128 lbs	576 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	804 lbs	512 lbs
max tension stress ratio (TSR) =	0.331 OK	0.211 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	120 lbs	58 lbs
Max shear stress ratio (VSR) =	0.078 OK	0.038 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.410 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 60" Tall "T" 5 Level


18T

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1128 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.124 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	577 lbs
Area reqd. for bearing (A_{reqd}) =	0.38 ft ²
"b" distance =	7.44 in
Slab thickness (t) =	4.00 in
$S = (1^*)t^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}]S$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	20 lb/in/in
$M_u = w_u L^2/3 = (w_u)(b-(2^*))^2/3$ =	50.27 in-lb/in - Defl. End M1 = 26 in-lb/in
$M_u / \phi M_{nt}$ =	0.071 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} wL$
$R = V$	$= wL$
V_x	$= wx$
M max. (at fixed end)	$= \frac{wL^2}{3}$
M_x (at deflected end)	$= \frac{wL^2}{6}$
M_x	$= \frac{wL^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{wL^4}{24EI}$
Δx	$= \frac{wL^4}{24EI} (1^2 - x^2)^2$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	11 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	7.8 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1559 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	72938 in*lbs

Load Combination #1:	$M_{OT} =$	3823 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	75779 in*lbs
	Total Overturning FOS =	19.824 OK


Load Combination #2:	$M_{OT} =$	2288 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	74175 in*lbs
	Total Overturning FOS =	32.421 OK



Shelving / Single Sided 78" Tall "V" 5 Level 18V

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	125 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	20.83 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	18 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	18 in
h ₄ =	18 in
h ₃ =	18 in
h ₂ =	18 in
h ₁ =	6 in
Total Shelf Height, H _t =	78 in
Unit Height, H _u =	78 in
Unit Base Depth, D =	11 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 380.6 lbs

Base Shear, V = C_sI_pW_s = 120.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 24.6 lbs @ 84 in (CM)

F₄ = 19.3 lbs @ 66 in (CM)

F₃ = 14.1 lbs @ 48 in (CM)

F₂ = 8.8 lbs @ 30 in (CM)

F₁ = 3.5 lbs @ 12 in (CM)

F_u = 13.7 lbs @ 39 in (CM)

ΣF_i = 120.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 4860 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 2842 in-lbs

Factor of Safety

FOS = 0.585

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 183.8 lbs

Base Shear, V = C_sI_pW_s = 58.0 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 29.6 lbs @ 84 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 11.0 lbs @ 39 in (CM)

ΣF_i = 58.0 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2913 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1238 in-lbs


Factor of Safety

FOS = 0.425

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	42 lbs	20 lbs
R _v =	183 lbs (Uplift)	152 lbs (Uplift)
Overturning FOS =	0.585 < 1.5--ABs Req'd	0.425 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	158lbs / 3.762 >= 1.5 OK	89lbs / 4.397 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	120 lbs	58 lbs
Net Uplift (R _{uv}) =	1073 lbs	674 lbs
Overturning + Gravity (P _u) =	1329 lbs	697 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	1073 lbs	674 lbs
max tension stress ratio (TSR) =	0.442 OK	0.278 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	120 lbs	58 lbs
Max shear stress ratio (VSR) =	0.078 OK	0.038 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.521 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 78" Tall "V" 5 Level


18V

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1329 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.147 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	648 lbs
Area reqd. for bearing (A_{reqd}) =	0.43 ft ²
"b" distance =	7.89 in
Slab thickness (t) =	4.00 in
$S = (1^*)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	21 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	61.70 in-lb/in - Defl. End M1 = 31 in-lb/in
$M_u / \phi M_{nt}$ =	0.087 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




$$\begin{aligned} \text{Total Equiv. Uniform Load} &= \frac{8}{3} wL \\ R = V &= wL \\ V_x &= wx \\ M \text{ max. (at fixed end)} &= \frac{wL^2}{3} \\ M_x \text{ (at deflected end)} &= \frac{wL^2}{6} \\ M_x &= \frac{wL^2}{6} (1^2 - 3x^2) \\ \Delta \text{ max. (at deflected end)} &= \frac{wL^4}{24EI} \\ \Delta x &= \frac{wL^4}{24EI} (1^2 - x^2)^2 \end{aligned}$$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	11 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	7.8 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1559 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	72938 in*lbs

Load Combination #1:	M_{OT} =	4860 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	75779 in*lbs
	Total Overturning FOS =	15.594 OK


Load Combination #2:	M_{OT} =	2913 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	74175 in*lbs
	Total Overturning FOS =	25.463 OK



Shelving / Single Sided 60" Tall "T" 5 Level 24T

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	18.75 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	13.5 in
h ₄ =	13.5 in
h ₃ =	13.5 in
h ₂ =	13.5 in
h ₁ =	6 in
Total Shelf Height, H _t =	60 in
Unit Height, H _u =	60 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 436.7 lbs

Base Shear, V = C_sI_pW_s = 137.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7)	F ₉ =	0.0 lbs	@ 0 in (CM)
	F ₈ =	0.0 lbs	@ 0 in (CM)
	F ₇ =	0.0 lbs	@ 0 in (CM)
	F ₆ =	0.0 lbs	@ 0 in (CM)
	F ₅ =	28.3 lbs	@ 66 in (CM)
	F ₄ =	22.5 lbs	@ 52.5 in (CM)
	F ₃ =	16.7 lbs	@ 39 in (CM)
	F ₂ =	10.9 lbs	@ 25.5 in (CM)
	F ₁ =	5.1 lbs	@ 12 in (CM)
	F _u =	12.8 lbs	@ 30 in (CM)
	ΣF _i =	137.7 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 4426 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 4500 in-lbs

Factor of Safety

FOS = 1.017

NO UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 200.5 lbs

Base Shear, V = C_sI_pW_s = 63.2 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads)	F ₉ =	0.0 lbs	
	F ₈ =	0.0 lbs	
	F ₇ =	0.0 lbs	
	F ₆ =	0.0 lbs	
	F ₅ =	34.0 lbs	@ 66 in (CM)
	F ₄ =	0.0 lbs	
	F ₃ =	0.0 lbs	
	F ₂ =	0.0 lbs	
	F ₁ =	0.0 lbs	
	F _u =	10.3 lbs	@ 30 in (CM)
	ΣF _i =	63.2 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2551 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1875 in-lbs


Factor of Safety

FOS = 0.735

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	48 lbs	22 lbs
R _u =	0 lbs (No Uplift)	45 lbs (Uplift)
Overturning FOS =	1.017 < 1.5--ABs Req'd	0.735 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	128 lbs / 2.663 >= 1.5 OK	68 lbs / 3.053 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	138 lbs	63 lbs
Net Uplift (R _{uw}) =	0 lbs	394 lbs
Overturning + Gravity (P _u) =	1079 lbs	507 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	0 lbs	394 lbs
max tension stress ratio (TSR) =	0.000 OK	0.163 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	138 lbs	63 lbs
Max shear stress ratio (VSR) =	0.090 OK	0.041 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.204 < 1.2 OK - LC#2 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 60" Tall "T" 5 Level


24T

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	1079 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.119 < 1.0 O.K.




(Punching Perimeter)

Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	590 lbs
Area reqd. for bearing (A_{reqd}) =	0.39 ft ²
"b" distance =	7.53 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	19 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2/3$ =	48.48 in-lb/in - Defl. End M1 = 25 in-lb/in
$M_u / \phi M_{nt}$ =	0.068 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} wL$
$R = V$	$= wL$
V_x	$= wx$
M max. (at fixed end)	$= \frac{wL^2}{3}$
M_x (at deflected end)	$= \frac{wL^2}{6}$
M_x	$= \frac{wL^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{wL^4}{24EI}$
Δx	$= \frac{wL^4}{24EI} (1^2 - 3x^2)$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	$M_{OT} =$	4426 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	83808 in*lbs
	Total Overturning FOS =	18.936 OK


Load Combination #2:	$M_{OT} =$	2551 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	81183 in*lbs
	Total Overturning FOS =	31.827 OK



Shelving / Single Sided 66" Tall "U" 5 Level 24U

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	18.75 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	15 in
h ₄ =	15 in
h ₃ =	15 in
h ₂ =	15 in
h ₁ =	6 in
Total Shelf Height, H _t =	66 in
Unit Height, H _u =	66 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 436.7 lbs

Base Shear, V = C_sI_pW_s = 137.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 28.6 lbs @ 72 in (CM)

F₄ = 22.6 lbs @ 57 in (CM)

F₃ = 16.7 lbs @ 42 in (CM)

F₂ = 10.7 lbs @ 27 in (CM)

F₁ = 4.8 lbs @ 12 in (CM)

F_u = 13.0 lbs @ 33 in (CM)

ΣF_i = 137.7 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 4825 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 4500 in-lbs

Factor of Safety

FOS = 0.933

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 200.5 lbs

Base Shear, V = C_sI_pW_s = 63.2 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 33.9 lbs @ 72 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.4 lbs @ 33 in (CM)

ΣF_i = 63.2 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2783 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1875 in-lbs

Factor of Safety

FOS = 0.674

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	48 lbs	22 lbs
R _v =	22 lbs (Uplift)	61 lbs (Uplift)
Overturning FOS =	0.933 < 1.5--ABs Req'd	0.674 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	135 lbs / 2.801 >= 1.5 OK	71 lbs / 3.228 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	138 lbs	63 lbs
Net Uplift (R _{uv}) =	699 lbs	439 lbs
Overturning + Gravity (P _u) =	1136 lbs	540 lbs

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in


c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²



Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	699 lbs	439 lbs
max tension stress ratio (TSR) =	0.288 OK	0.181 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	138 lbs	63 lbs
Max shear stress ratio (VSR) =	0.090 OK	0.041 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.378 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 66" Tall "U" 5 Level


24U

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1136 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.125 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	610 lbs
Area reqd. for bearing (A_{reqd}) =	0.41 ft ²
"b" distance =	7.65 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	19 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	51.65 in-lb/in - Defl. End M1 = 26 in-lb/in
$M_u / \phi M_{nt}$ =	0.073 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} w l$
$R = V$	$= w l$
V_x	$= w x$
M max. (at fixed end)	$= \frac{w l^2}{3}$
M_x (at deflected end)	$= \frac{w l^2}{6}$
M_x	$= \frac{w l^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{w l^4}{24 EI}$
Δx	$= \frac{w l^4}{24 EI} (1^2 - x^2)^2$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	$M_{OT} =$	4825 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	83808 in*lbs
	Total Overturning FOS =	17.370 OK


Load Combination #2:	$M_{OT} =$	2783 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	81183 in*lbs
	Total Overturning FOS =	29.172 OK



Shelving / Single Sided 78" Tall "V" 5 Level 24V

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	18.75 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	18 in
h ₄ =	18 in
h ₃ =	18 in
h ₂ =	18 in
h ₁ =	6 in
Total Shelf Height, H _t =	78 in
Unit Height, H _u =	78 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 436.7 lbs

Base Shear, V = C_sI_pW_s = 137.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 29.0 lbs @ 84 in (CM)

F₄ = 22.8 lbs @ 66 in (CM)

F₃ = 16.6 lbs @ 48 in (CM)

F₂ = 10.4 lbs @ 30 in (CM)

F₁ = 4.1 lbs @ 12 in (CM)

F_u = 13.4 lbs @ 39 in (CM)

ΣF_i = 137.7 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 5627 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 4500 in-lbs

Factor of Safety

FOS = 0.800

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 200.5 lbs

Base Shear, V = C_sI_pW_s = 63.2 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 33.8 lbs @ 84 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.5 lbs @ 39 in (CM)

ΣF_i = 63.2 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 3247 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1875 in-lbs


Factor of Safety

FOS = 0.577

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	48 lbs	22 lbs
R _v =	75 lbs (Uplift)	91 lbs (Uplift)
Overturning FOS =	0.800 < 1.5--ABS Req'd	0.577 < 1.5--ABS Req'd
Sliding Restraint force, R _{RST} / FOS =	148 lbs / 3.078 >= 1.5 OK	79 lbs / 3.578 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	138 lbs	63 lbs
Net Uplift (R _{uv}) =	852 lbs	527 lbs
Overturning + Gravity (P _u) =	1250 lbs	606 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1		LC #2	
Factored Tension Load (N _u) =	852 lbs		527 lbs	
max tension stress ratio (TSR) =	0.351	OK	0.217	OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1		LC #2	
Factored Shear Load (V _u) =	138 lbs		63 lbs	
Max shear stress ratio (VSR) =	0.090	OK	0.041	OK
Combined shear and tension stress ratio (TSR + VSR) =	0.441	< 1.2 OK - LC#1 (controls)		

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 78" Tall "V" 5 Level


24V

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1250 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.138 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	650 lbs
Area reqd. for bearing (A_{reqd}) =	0.43 ft ²
"b" distance =	7.90 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	20 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	58.10 in-lb/in - Defl. End M1 = 30 in-lb/in
$M_u / \phi M_{nt}$ =	0.082 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	M_{OT} =	5627 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	83808 in*lbs
	Total Overturning FOS =	14.894 OK


Load Combination #2:	M_{OT} =	3247 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	81183 in*lbs
	Total Overturning FOS =	25.000 OK



Shelving / Single Sided 84" Tall "W" 5 Level 24W

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	18.75 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	20 in
h ₄ =	19 in
h ₃ =	20 in
h ₂ =	19 in
h ₁ =	6 in
Total Shelf Height, H _t =	84 in
Unit Height, H _u =	84 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 436.7 lbs

Base Shear, V = C_sI_pW_s = 137.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 29.3 lbs @ 90 in (CM)

F₄ = 22.8 lbs @ 70 in (CM)

F₃ = 16.6 lbs @ 51 in (CM)

F₂ = 10.1 lbs @ 31 in (CM)

F₁ = 3.9 lbs @ 12 in (CM)

F_u = 13.6 lbs @ 42 in (CM)

ΣF_i = 137.7 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 6017 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 4500 in-lbs

Factor of Safety

FOS = 0.748

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 200.5 lbs

Base Shear, V = C_sI_pW_s = 63.2 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 33.8 lbs @ 90 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.5 lbs @ 42 in (CM)

ΣF_i = 63.2 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 3480 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1875 in-lbs


Factor of Safety

FOS = 0.539

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	48 lbs	22 lbs
R _v =	101 lbs (Uplift)	107 lbs (Uplift)
Overturning FOS =	0.748 < 1.5--ABs Req'd	0.539 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	155 lbs / 3.213 >= 1.5 OK	83 lbs / 3.753 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	138 lbs	63 lbs
Net Uplift (R _{uv}) =	927 lbs	571 lbs
Overturning + Gravity (P _u) =	1305 lbs	639 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	927 lbs	571 lbs
max tension stress ratio (TSR) =	0.382 OK	0.235 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	138 lbs	63 lbs
Max shear stress ratio (VSR) =	0.090 OK	0.041 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.472 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266


Shelving / Single Sided 84" Tall "W" 5 Level 24W

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	1305 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.144 < 1.0 O.K.




(Punching Perimeter)

Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	670 lbs
Area reqd. for bearing (A_{reqd}) =	0.45 ft ²
"b" distance =	8.02 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	20 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	61.27 in-lb/in - Defl. End M1 = 31 in-lb/in
$M_u / \phi M_{nt}$ =	0.086 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} w l$
$R = V$	$= w l$
V_x	$= w x$
M max. (at fixed end)	$= \frac{w l^2}{3}$
M_x (at deflected end)	$= \frac{w l^2}{6}$
M_x	$= \frac{w}{6} (l^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{w l^4}{24 E I}$
Δx	$= \frac{w}{24 E I} (l^2 - x^2)^2$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	$M_{OT} =$	6017 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	83808 in*lbs
	Total Overturning FOS =	13.929 OK


Load Combination #2:	$M_{OT} =$	3480 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	81183 in*lbs
	Total Overturning FOS =	23.332 OK



Shelving / Single Sided 90" Tall "X" 5 Level 24X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	18.75 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	21 in
h ₄ =	21 in
h ₃ =	21 in
h ₂ =	21 in
h ₁ =	6 in
Total Shelf Height, H _t =	90 in
Unit Height, H _u =	90 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 436.7 lbs

Base Shear, V = C_sI_pW_s = 137.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7)	F ₉ =	0.0 lbs	@ 0 in (CM)
	F ₈ =	0.0 lbs	@ 0 in (CM)
	F ₇ =	0.0 lbs	@ 0 in (CM)
	F ₆ =	0.0 lbs	@ 0 in (CM)
	F ₅ =	29.4 lbs	@ 96 in (CM)
	F ₄ =	23.0 lbs	@ 75 in (CM)
	F ₃ =	16.5 lbs	@ 54 in (CM)
	F ₂ =	10.1 lbs	@ 33 in (CM)
	F ₁ =	3.7 lbs	@ 12 in (CM)
	F _u =	13.7 lbs	@ 45 in (CM)
	ΣF _i =	137.7 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 6433 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 4500 in-lbs

Factor of Safety

FOS = 0.700

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 200.5 lbs

Base Shear, V = C_sI_pW_s = 63.2 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads)	F ₉ =	0.0 lbs	
	F ₈ =	0.0 lbs	
	F ₇ =	0.0 lbs	
	F ₆ =	0.0 lbs	
	F ₅ =	33.7 lbs	@ 96 in (CM)
	F ₄ =	0.0 lbs	
	F ₃ =	0.0 lbs	
	F ₂ =	0.0 lbs	
	F ₁ =	0.0 lbs	
	F _u =	10.5 lbs	@ 45 in (CM)
	ΣF _i =	63.2 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 3712 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1875 in-lbs


Factor of Safety

FOS = 0.505

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	48 lbs	22 lbs
R _v =	129 lbs (Uplift)	122 lbs (Uplift)
Overturning FOS =	0.700 < 1.5--ABs Req'd	0.505 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	162 lbs / 3.357 >= 1.5 OK	87 lbs / 3.928 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	138 lbs	63 lbs
Net Uplift (R _{uv}) =	1006 lbs	616 lbs
Overturning + Gravity (P _u) =	1365 lbs	672 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN _{sa} =	8437 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, (0.75)φN _{cb} =	2427 lbs	<--ACI 318-14 Eq 17.4.2.1b
Pullout Strength, (0.75)φN _{pn} =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	1006 lbs	616 lbs
max tension stress ratio (TSR) =	0.414 OK	0.254 OK

Shear Allowables

Steel Strength, φV _{sa} =	4062 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, φV _{cb} =	1533 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, φV _{cp} =	3485 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	138 lbs	63 lbs
Max shear stress ratio (VSR) =	0.090 OK	0.041 OK

Combined shear and tension stress ratio (TSR + VSR) = 0.504 < 1.2 OK - LC#1 (controls)

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 90" Tall "X" 5 Level


24X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	1365 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.151 < 1.0 O.K.




(Punching Perimeter)

Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	691 lbs
Area reqd. for bearing (A_{reqd}) =	0.46 ft ²
"b" distance =	8.14 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	21 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	64.74 in-lb/in - Defl. End M1 = 33 in-lb/in
$M_u / \phi M_{nt}$ =	0.091 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	$M_{OT} =$	6433 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	83808 in*lbs
	Total Overturning FOS =	13.028 OK


Load Combination #2:	$M_{OT} =$	3712 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	81183 in*lbs
	Total Overturning FOS =	21.872 OK



Shelving / Single Sided 90" Tall "X" 5 Level 24XSD

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	225 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	28.13 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	21 in
h ₄ =	21 in
h ₃ =	21 in
h ₂ =	21 in
h ₁ =	6 in
Total Shelf Height, H _t =	90 in
Unit Height, H _u =	90 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL _{RF} = 1.0]	
Seismic (C _s)(I _p) =	0.315 W _s (Cross-Aisle)
W _s = (0.67)(PL _{RF})(0.67)PL+DL =	605.0 lbs
Base Shear, V = C _s I _p W _s =	190.8 lbs
Horizontal forces per level, F _x = C _w V (RMI sect 2.6.6)	
(Service Loads, E = 0.7)	
F ₉ =	0.0 lbs @ 0 in (CM)
F ₈ =	0.0 lbs @ 0 in (CM)
F ₇ =	0.0 lbs @ 0 in (CM)
F ₆ =	0.0 lbs @ 0 in (CM)
F ₅ =	42.8 lbs @ 96 in (CM)
F ₄ =	33.4 lbs @ 75 in (CM)
F ₃ =	24.1 lbs @ 54 in (CM)
F ₂ =	14.7 lbs @ 33 in (CM)
F ₁ =	5.3 lbs @ 12 in (CM)
F _u =	13.3 lbs @ 45 in (CM)
ΣF _i =	190.8 lbs (@ Factored Loads)
Calculate Overturning Moment (Service), M _{OT} = ΣF _i h _i	
M _{OT} =	9057 in-lbs
Calculate Resisting Moment (Service), M _{RST}	
M _{RST} =	6375 in-lbs
Factor of Safety	
FOS =	0.704

UPLIFT - ANCHORS REQUIRED


Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL _{RF} = 1.0]	
Seismic (C _s)(I _p) =	0.315 W _s (Cross-Aisle)
W _s = (0.67)(PL _{RF})(1)PL+DL =	250.8 lbs
Base Shear, V = C _s I _p W _s =	79.1 lbs
Horizontal forces per level, F _x = C _w V (RMI sect 2.6.6)	
(Service Loads)	
F ₉ =	0.0 lbs
F ₈ =	0.0 lbs
F ₇ =	0.0 lbs
F ₆ =	0.0 lbs
F ₅ =	45.8 lbs @ 96 in (CM)
F ₄ =	0.0 lbs
F ₃ =	0.0 lbs
F ₂ =	0.0 lbs
F ₁ =	0.0 lbs
F _u =	9.5 lbs @ 45 in (CM)
ΣF _i =	79.1 lbs (@ Factored Loads)
Calculate Overturning Moment (Service), M _{OT} = ΣF _i h _i	
M _{OT} =	4827 in-lbs
Calculate Resisting Moment (Service), M _{RST}	
M _{RST} =	2438 in-lbs
Factor of Safety	
FOS =	0.505

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	67 lbs	28 lbs
R _u =	179 lbs (Uplift)	159 lbs (Uplift)
Overturning FOS =	0.704 < 1.5--ABs Req'd	0.505 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	227lbs / 3.393 >= 1.5 OK	112lbs / 4.039 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	191 lbs	79 lbs
Net Uplift (R _{uw}) =	1414 lbs	801 lbs
Overturning + Gravity (P _u) =	1929 lbs	869 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment =	2.5 in
f' _c =	3500 psi
e _n ' =	0 in <--- Eccen. Of Anchor
h _{ef} =	2 in 1.5(h _{ef}) = 3.000 in
c _a =	3.5 in 1.5(c _a) = 5.250 in
Conc. thickness, t =	4 in
# of Anchors, n =	2 - anchors per connection
S _x =	2.5 in
A _{se} =	0.051 in ²

Tension Allowables

Steel Strength, φN _{sa} =	8437 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, (0.75)φN _{cbg} =	2427 lbs	<--ACI 318-14 Eq 17.4.2.1b
Pullout Strength, (0.75)φN _{pn} =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1		LC #2	
Factored Tension Load (N_u) =	1414 lbs		801 lbs	
max tension stress ratio (TSR) =	0.583	OK	0.330	OK

Shear Allowables

Steel Strength, φV _{sa} =	4062 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, φV _{cbg} =	1533 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, φV _{cpb} =	3485 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2	
Factored Shear Load (V_u) =	191 lbs	79 lbs	
Max shear stress ratio (VSR) =	0.125	0.052	OK
ension stress ratio (TSR + VSR) =	0.707	< 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266


Shelving / Single Sided 90" Tall "X" 5 Level 24XSD

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1929 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.213 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	979 lbs
Area reqd. for bearing (A_{reqd}) =	0.65 ft ²
"b" distance =	9.69 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	21 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	101.27 in-lb/in - Defl. End M1 = 51 in-lb/in
$M_u / \phi M_{nt}$ =	0.143 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} wL$
$R = V$	$= wL$
V_x	$= wx$
M max. (at fixed end)	$= \frac{wL^2}{3}$
M_x (at deflected end)	$= \frac{wL^2}{6}$
M_x	$= \frac{wL^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{wL^4}{24EI}$
Δx	$= \frac{wL^4}{24EI} (1^2 - x^2)$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	$M_{OT} =$	9057 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	85683 in*lbs
	Total Overturning FOS =	9.460 OK


Load Combination #2:	$M_{OT} =$	4827 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	81746 in*lbs
	Total Overturning FOS =	16.934 OK



Shelving / Single Sided 120" Tall "YZ" 4 Level 30YZ

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	75 lbs
# of Levels =	Wall 4 Level - HD TV
Uniform Weight per level =	7.50 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	30 in
Shelf Load / Level	
$h_9 =$	0 in
$h_8 =$	0 in
$h_7 =$	0 in
$h_6 =$	0 in
$h_5 =$	0 in
$h_4 =$	30 in
$h_3 =$	30 in
$h_2 =$	30 in
$h_1 =$	6 in
Total Shelf Height, $H_t =$	96 in
Unit Height, $H_u =$	120 in
Unit Base Depth, $D =$	21 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic $(C_s)(I_p) = 0.315 W_s$ (Cross-Aisle)

$W_s = (0.67)(PL_{RF})(0.67)PL + DL = 234.7$ lbs

Base Shear, $V = C_s I_p W_s = 74.0$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$) $F_9 = 0.0$ lbs @ 0 in (CM)

$F_8 = 0.0$ lbs @ 0 in (CM)

$F_7 = 0.0$ lbs @ 0 in (CM)

$F_6 = 0.0$ lbs @ 0 in (CM)

$F_5 = 0.0$ lbs @ 0 in (CM)

$F_4 = 15.2$ lbs @ 102 in (CM)

$F_3 = 10.7$ lbs @ 72 in (CM)

$F_2 = 6.3$ lbs @ 42 in (CM)

$F_1 = 1.8$ lbs @ 12 in (CM)

$F_u = 17.8$ lbs @ 60 in (CM)

$\Sigma F_i = 74.0$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_i h_i$

$M_{OT} = 3677$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 3150$ in-lbs

Factor of Safety

FOS = 0.857

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - $PL=1.0(PL)$]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic $(C_s)(I_p) = 0.315 W_s$ (Cross-Aisle)

$W_s = (0.67)(PL_{RF})(1.0)PL + DL = 150.3$ lbs

Base Shear, $V = C_s I_p W_s = 47.4$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads) $F_9 = 0.0$ lbs

$F_8 = 0.0$ lbs

$F_7 = 0.0$ lbs

$F_6 = 0.0$ lbs

$F_5 = 0.0$ lbs

$F_4 = 18.6$ lbs @ 102 in (CM)

$F_3 = 0.0$ lbs

$F_2 = 0.0$ lbs

$F_1 = 0.0$ lbs

$F_u = 14.6$ lbs @ 60 in (CM)

$\Sigma F_i = 47.4$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_i h_i$

$M_{OT} = 2771$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 1838$ in-lbs


Factor of Safety

FOS = 0.663

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
$R_i =$	26 lbs	17 lbs
$R_v =$	25 lbs (Uplift)	44 lbs (Uplift)
Overturning FOS =	0.857 < 1.5--ABS Req'd	0.663 < 1.5--ABS Req'd
Sliding Restraint force, $R_{RST} / FOS =$	73lbs / 2.823 >= 1.5 OK	52lbs / 3.121 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	74 lbs	47 lbs
Net Uplift (R_{uv}) =	391 lbs	313 lbs
Overturning + Gravity (P_u) =	595 lbs	388 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

$f'_c = 3500$ psi

$e_n' = 0$ in <--- Eccen. Of Anchor

$h_{ef} = 2$ in 1.5(h_{ef}) = 3.000 in

$c_a = 3.5$ in 1.5(c_a) = 5.250 in

Conc. thickness, $t = 4$ in

of Anchors, $n = 2$ - anchors per connection

$S_x = 2.5$ in

$A_{se} = 0.051$ in²

Tension Allowables

Steel Strength, $\phi N_{sa} = 8437$ lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, $(0.75)\phi N_{cb} = 2427$ lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, $(0.75)\phi N_{pn} = NA$ <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N_u) =	391 lbs	313 lbs
max tension stress ratio (TSR) =	0.161 OK	0.129 OK

Shear Allowables

Steel Strength, $\phi V_{sa} = 4062$ lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, $\phi V_{cb} = 1533$ lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, $\phi V_{cp} = 3485$ lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V_u) =	74 lbs	47 lbs
Max shear stress ratio (VSR) =	0.048 OK	0.031 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.209 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266


Shelving / Single Sided 120" Tall "YZ" 4 Level 30YZ

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	595 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.066 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	312 lbs
Area reqd. for bearing (A_{reqd}) =	0.21 ft ²
"b" distance =	5.47 in
Slab thickness (t) =	4.00 in
$S = (1") (t)^2 / 6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t (7.5) [(f'_c)^{1/2}] (S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	20 lb/in/in
$M_u = w_u L^2 / 3 = (w_u) [(b - (2")) / 2]^2 / 3$ =	19.97 in-lb/in - Defl. End $M_1 = 10$ in-lb/in
$M_u / \phi M_{nt}$ =	0.028 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} w l$
$R = V$	$= w l$
V_x	$= w x$
M max. (at fixed end)	$= \frac{w l^2}{3}$
M_x (at deflected end)	$= \frac{w l^2}{6}$
M_x	$= \frac{w l^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{w l^4}{24 E I}$
Δx	$= \frac{w l^4}{24 E I} (1^2 - x^2)^2$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	21 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2 / 6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r / 1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.6 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1726 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c / 2$ =	89364 in*lbs

Load Combination #1:	$M_{OT} =$	3677 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	92514 in*lbs
	Total Overturning FOS =	25.157 OK


Load Combination #2:	$M_{OT} =$	2771 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	91201 in*lbs
	Total Overturning FOS =	32.913 OK



Shelving / Single Sided 78" Tall "V" 5 Level 36V

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	12.50 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	36 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	18 in
h ₄ =	18 in
h ₃ =	18 in
h ₂ =	18 in
h ₁ =	6 in
Total Shelf Height, H _t =	78 in
Unit Height, H _u =	78 in
Unit Base Depth, D =	27 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 436.7 lbs

Base Shear, V = C_sI_pW_s = 137.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 29.0 lbs @ 84 in (CM)

F₄ = 22.8 lbs @ 66 in (CM)

F₃ = 16.6 lbs @ 48 in (CM)

F₂ = 10.4 lbs @ 30 in (CM)

F₁ = 4.1 lbs @ 12 in (CM)

F_u = 13.4 lbs @ 39 in (CM)

ΣF_i = 137.7 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 5627 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 8100 in-lbs

Factor of Safety

FOS = 1.440

NO UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 200.5 lbs

Base Shear, V = C_sI_pW_s = 63.2 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 33.8 lbs @ 84 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.5 lbs @ 39 in (CM)

ΣF_i = 63.2 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 3247 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 3375 in-lbs


Factor of Safety

FOS = 1.039

NO UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _i =	48 lbs	22 lbs
R _u =	0 lbs (No Uplift)	0 lbs (No Uplift)
Overturning FOS =	1.440 < 1.5--ABs Req'd	1.039 < 1.5--ABs Req'd
Sliding Restraint force, R _{RST} / FOS =	107lbs / 2.213 >= 1.5 OK	55lbs / 2.491 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	138 lbs	63 lbs
Net Uplift (R _{uw}) =	0 lbs	0 lbs
Overturning + Gravity (P _u) =	895 lbs	401 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 2 - anchors per connection

S_x = 2.5 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 8437 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 2427 lbs <--ACI 318-14 Eq 17.4.2.1b

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	0 lbs	0 lbs
max tension stress ratio (TSR) =	0.000 OK	0.000 OK

Shear Allowables

Steel Strength, φV_{sa} = 4062 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1533 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 3485 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	138 lbs	63 lbs
Max shear stress ratio (VSR) =	0.090 OK	0.041 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.090 < 1.2 OK - LC#1 (controls)	

USE: (2) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266


Shelving / Single Sided 78" Tall "V" 5 Level 36V

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	895 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.099 < 1.0 O.K.



Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	525 lbs
Area reqd. for bearing (A_{reqd}) =	0.35 ft ²
"b" distance =	7.10 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	18 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2/3$ =	38.48 in-lb/in - Defl. End M1 = 20 in-lb/in
$M_u / \phi M_{nt}$ =	0.054 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD



Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:


Width of Single Rack =	27 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	9.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1826 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	100019 in*lbs
Load Combination #1:	
M_{OT} =	5627 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	108119 in*lbs
Total Overturning FOS =	19.215 OK
Load Combination #2:	
M_{OT} =	3247 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	103394 in*lbs
Total Overturning FOS =	31.840 OK



Shelving / Single Sided 90" Tall "EC" 5 Level 2490 EC

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	100 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	12.50 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	24 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	21 in
h ₄ =	21 in
h ₃ =	21 in
h ₂ =	21 in
h ₁ =	6 in
Total Shelf Height, H _t =	90 in
Unit Height, H _u =	90 in
Unit Base Depth, D =	15 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 324.5 lbs

Base Shear, V = C_sI_pW_s = 102.3 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 20.4 lbs @ 96 in (CM)

F₄ = 15.9 lbs @ 75 in (CM)

F₃ = 11.5 lbs @ 54 in (CM)

F₂ = 7.0 lbs @ 33 in (CM)

F₁ = 2.5 lbs @ 12 in (CM)

F_u = 14.3 lbs @ 45 in (CM)

ΣF_i = 102.3 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 4676 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 3250 in-lbs

Factor of Safety

FOS = 0.695

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 167.0 lbs

Base Shear, V = C_sI_pW_s = 52.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 25.1 lbs @ 96 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 11.8 lbs @ 45 in (CM)

ΣF_i = 52.7 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2939 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1500 in-lbs


Factor of Safety

FOS = 0.510

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _h =	36 lbs	18 lbs
R _v =	95 lbs (Uplift)	96 lbs (Uplift)
Overturning FOS =	0.695 < 1.5--ABS Req'd	0.510 < 1.5--ABS Req'd
Sliding Restraint force, R _{RST} / FOS =	118lbs / 3.309 >= 1.5 OK	70lbs / 3.79 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	102 lbs	53 lbs
Net Uplift (R _{uv}) =	732 lbs	487 lbs
Overturning + Gravity (P _u) =	988 lbs	537 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 1 - anchors per connection

S_x = 0 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 4219 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 1713 lbs <--ACI 318-14 Eq 17.4.2.1a

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	732 lbs	487 lbs
max tension stress ratio (TSR) =	0.427 OK	0.284 OK

Shear Allowables

Steel Strength, φV_{sa} = 2031 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1238 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 2460 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	102 lbs	53 lbs
Max shear stress ratio (VSR) =	0.083 OK	0.043 OK

Combined shear and tension stress ratio (TSR + VSR) = 0.510 < 1.2 OK - LC#1 (controls)

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 90" Tall "EC" 5 Level


2490 EC

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	988 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.109 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	498 lbs
Area reqd. for bearing (A_{reqd}) =	0.33 ft ²
"b" distance =	6.91 in
Slab thickness (t) =	4.00 in
$S = (1^*)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	21 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	41.59 in-lb/in - Defl. End M1 = 21 in-lb/in
$M_u / \phi M_{nt}$ =	0.059 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




$$\begin{aligned} \text{Total Equiv. Uniform Load} &= \frac{8}{3} wL \\ R = V &= wL \\ V_x &= wx \\ M \text{ max. (at fixed end)} &= \frac{wL^2}{3} \\ M_x \text{ (at deflected end)} &= \frac{wx^2}{6} \\ M_x &= \frac{w}{6} (L^2 - 3x^2) \\ \Delta \text{ max. (at deflected end)} &= \frac{wL^4}{24EI} \\ \Delta x &= \frac{wx}{24EI} (L^2 - x^2)^2 \end{aligned}$$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	15 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1626 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	79308 in*lbs

Load Combination #1:	M_{OT} =	4676 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	82558 in*lbs
	Total Overturning FOS =	17.655 OK


Load Combination #2:	M_{OT} =	2939 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	80808 in*lbs
	Total Overturning FOS =	27.493 OK



Shelving / Single Sided 78" Tall "EC" 5 Level 3678 EC

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	100 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	8.33 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	36 in
Shelf Load / Level	
h_9 =	0 in
h_8 =	0 in
h_7 =	0 in
h_6 =	0 in
h_5 =	18 in
h_4 =	18 in
h_3 =	18 in
h_2 =	18 in
h_1 =	6 in
Total Shelf Height, H_t =	78 in
Unit Height, H_u =	78 in
Unit Base Depth, D =	27 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic $(C_s)(I_p) = 0.315 W_s$ (Cross-Aisle)

$W_s = (0.67)(PL_{RF})(0.67)PL + DL = 324.5$ lbs

Base Shear, $V = C_s I_p W_s = 102.3$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$) $F_9 = 0.0$ lbs @ 0 in (CM)

$F_8 = 0.0$ lbs @ 0 in (CM)

$F_7 = 0.0$ lbs @ 0 in (CM)

$F_6 = 0.0$ lbs @ 0 in (CM)

$F_5 = 20.2$ lbs @ 84 in (CM)

$F_4 = 15.9$ lbs @ 66 in (CM)

$F_3 = 11.5$ lbs @ 48 in (CM)

$F_2 = 7.2$ lbs @ 30 in (CM)

$F_1 = 2.9$ lbs @ 12 in (CM)

$F_u = 14.0$ lbs @ 39 in (CM)

$\Sigma F_i = 102.3$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_i h_i$

$M_{OT} = 4090$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 5850$ in-lbs

Factor of Safety

$FOS = 1.430$

NO UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - $PL=1.0(PL)$]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic $(C_s)(I_p) = 0.315 W_s$ (Cross-Aisle)

$W_s = (0.67)(PL_{RF})(1.0)PL + DL = 167.0$ lbs

Base Shear, $V = C_s I_p W_s = 52.7$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads) $F_9 = 0.0$ lbs

$F_8 = 0.0$ lbs

$F_7 = 0.0$ lbs

$F_6 = 0.0$ lbs

$F_5 = 25.2$ lbs @ 84 in (CM)

$F_4 = 0.0$ lbs

$F_3 = 0.0$ lbs

$F_2 = 0.0$ lbs

$F_1 = 0.0$ lbs

$F_u = 11.7$ lbs @ 39 in (CM)

$\Sigma F_i = 52.7$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_i h_i$

$M_{OT} = 2571$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 2700$ in-lbs


Factor of Safety

$FOS = 1.050$

NO UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R_u =	36 lbs	18 lbs
R_v =	0 lbs (No Uplift)	0 lbs (No Uplift)
Overturning FOS =	1.430 < 1.5--ABs Req'd	1.050 < 1.5--ABs Req'd
Sliding Restraint force, R_{RST} / FOS =	78 lbs / 2.19 >= 1.5 OK	45 lbs / 2.424 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	102 lbs	53 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	646 lbs	322 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

$f'_c = 3500$ psi

$e_n' = 0$ in <--- Eccen. Of Anchor

$h_{ef} = 2$ in 1.5(h_{ef}) = 3.000 in

$c_a = 3.5$ in 1.5(c_a) = 5.250 in

Conc. thickness, $t = 4$ in

of Anchors, $n = 1$ - anchors per connection

$S_x = 0$ in

$A_{se} = 0.051$ in²

Tension Allowables

Steel Strength, $\phi N_{sa} = 4219$ lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, $(0.75)\phi N_{cb} = 1713$ lbs <--ACI 318-14 Eq 17.4.2.1a

Pullout Strength, $(0.75)\phi N_{pn} = NA$ <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N_u) =	0 lbs	0 lbs
max tension stress ratio (TSR) =	0.000 OK	0.000 OK

Shear Allowables

Steel Strength, $\phi V_{sa} = 2031$ lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, $\phi V_{cb} = 1238$ lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, $\phi V_{cp} = 2460$ lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V_u) =	102 lbs	53 lbs
Max shear stress ratio (VSR) =	0.083 OK	0.043 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.083 < 1.2 OK - LC#1 (controls)	

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 78" Tall "EC" 5 Level


3678 EC

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	646 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.071 < 1.0 O.K.



Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	378 lbs
Area reqd. for bearing (A_{reqd}) =	0.25 ft ²
"b" distance =	6.02 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	18 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	24.02 in-lb/in - Defl. End M1 = 13 in-lb/in
$M_u / \phi M_{nt}$ =	0.034 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD



Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:


Width of Single Rack =	27 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r / 1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	9.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1826 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	100019 in*lbs
Load Combination #1:	
M_{OT} =	4090 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	105869 in*lbs
Total Overturning FOS =	25.882 OK
Load Combination #2:	
M_{OT} =	2571 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	102719 in*lbs
Total Overturning FOS =	39.956 OK



Shelving / Single Sided 78" Tall "EC" 5 Level 4878 EC

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	100 lbs
# of Levels =	Wall 5 Level
Uniform Weight per level =	6.25 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	48 in
Shelf Load / Level	
h ₉ =	0 in
h ₈ =	0 in
h ₇ =	0 in
h ₆ =	0 in
h ₅ =	18 in
h ₄ =	18 in
h ₃ =	18 in
h ₂ =	18 in
h ₁ =	6 in
Total Shelf Height, H _t =	78 in
Unit Height, H _u =	78 in
Unit Base Depth, D =	39 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 324.5 lbs

Base Shear, V = C_sI_pW_s = 102.3 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7) F₉ = 0.0 lbs @ 0 in (CM)

F₈ = 0.0 lbs @ 0 in (CM)

F₇ = 0.0 lbs @ 0 in (CM)

F₆ = 0.0 lbs @ 0 in (CM)

F₅ = 20.2 lbs @ 84 in (CM)

F₄ = 15.9 lbs @ 66 in (CM)

F₃ = 11.5 lbs @ 48 in (CM)

F₂ = 7.2 lbs @ 30 in (CM)

F₁ = 2.9 lbs @ 12 in (CM)

F_u = 14.0 lbs @ 39 in (CM)

ΣF_i = 102.3 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 4090 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 8450 in-lbs

Factor of Safety

FOS = 2.066

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 167.0 lbs

Base Shear, V = C_sI_pW_s = 52.7 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads) F₉ = 0.0 lbs

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 25.2 lbs @ 84 in (CM)

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 11.7 lbs @ 39 in (CM)

ΣF_i = 52.7 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 2571 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 3900 in-lbs


Factor of Safety

FOS = 1.517

NO UPLIFT - NO ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _h =	36 lbs	18 lbs
R _v =	0 lbs (No Uplift)	0 lbs (No Uplift)
Overturning FOS =	2.066 >= 1.5	1.517 >= 1.5
Sliding Restraint force, R _{RST} / FOS =	67lbs / 1.865 >= 1.5 OK	37lbs / 2.026 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	102 lbs	53 lbs
Net Uplift (R _{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P _u) =	547 lbs	260 lbs



Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-T22 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_n' = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 1 - anchors per connection

S_x = 0 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, φN_{sa} = 4219 lbs <--ACI 318-14 Eq 17.4.1.2

Concrete Breakout, (0.75)φN_{cb} = 1713 lbs <--ACI 318-14 Eq 17.4.2.1a

Pullout Strength, (0.75)φN_{pn} = NA <--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	0 lbs	0 lbs
max tension stress ratio (TSR) =	0.000 OK	0.000 OK

Shear Allowables

Steel Strength, φV_{sa} = 2031 lbs <--ACI 318-14 Eq 17.5.1.2c

Concrete breakout, φV_{cb} = 1238 lbs <--ACI 318-14 Eq 17.5.2.1b

Concrete pryout, φV_{cp} = 2460 lbs <--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	102 lbs	53 lbs
Max shear stress ratio (VSR) =	0.083 OK	0.043 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.083 < 1.2 OK - LC#1 (controls)	

USE: NO UPLIFT - USE (1) 3/8" DIA Hilti Kwik Bolt-T22 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Single Sided 78" Tall "EC" 5 Level


4878 EC

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	547 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.060 < 1.0 O.K.




(Punching Perimeter)

Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	343 lbs
Area reqd. for bearing (A_{reqd}) =	0.23 ft ²
"b" distance =	5.74 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	17 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2/3$ =	19.35 in-lb/in - Defl. End M1 = 10 in-lb/in
$M_u / \phi M_{nt}$ =	0.027 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} w l$
$R = V$	$= w l$
V_x	$= w x$
M max. (at fixed end)	$= \frac{w l^2}{3}$
M_x (at deflected end)	$= \frac{w l^2}{6}$
M_x	$= \frac{w l^2}{6} (1^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{w l^4}{24 E I}$
Δx	$= \frac{w l^4}{24 E I} (1^2 - x^2)^2$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	39 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r/1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	10.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	2026 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	123130 in*lbs

Load Combination #1:	$M_{OT} =$	4090 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	131580 in*lbs
	Total Overturning FOS =	32.168 OK


Load Combination #2:	$M_{OT} =$	2571 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	127030 in*lbs
	Total Overturning FOS =	49.412 OK



Shelving / Single Sided 84" Tall "3RX" 9 Level 9-3RX

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.0
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	15 lbs
# of Levels =	Wall 9 Level
Uniform Weight per level =	5.00 psf/shelf
Weight of Unit =	100 lbs
Anchorage spacing/Trib width =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth =	9 in
Shelf Load / Level	
h ₉ =	9.5 in 15 lbs
h ₈ =	10 in 15 lbs
h ₇ =	9.5 in 15 lbs
h ₆ =	10 in 15 lbs
h ₅ =	9.5 in 15 lbs
h ₄ =	10 in 15 lbs
h ₃ =	9.5 in 15 lbs
h ₂ =	10 in 15 lbs
h ₁ =	6 in 15 lbs
Total Shelf Height, H _t =	84 in
Unit Height, H _u =	84 in
Unit Base Depth, D =	6.5 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.210 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL + DL = 160.6 lbs

Base Shear, V = C_sI_pW_s = 33.8 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads, E = 0.7)	F ₉ =	2.4 lbs	@ 90 in (CM)
	F ₈ =	2.2 lbs	@ 80.5 in (CM)
	F ₇ =	1.9 lbs	@ 70.5 in (CM)
	F ₆ =	1.6 lbs	@ 61 in (CM)
	F ₅ =	1.4 lbs	@ 51 in (CM)
	F ₄ =	1.1 lbs	@ 41.5 in (CM)
	F ₃ =	0.8 lbs	@ 31.5 in (CM)
	F ₂ =	0.6 lbs	@ 22 in (CM)
	F ₁ =	0.3 lbs	@ 12 in (CM)
	F _u =	11.3 lbs	@ 42 in (CM)
	ΣF _i =	33.8 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 1259 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 618 in-lbs

Factor of Safety

FOS = 0.490

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.210 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1)PL + DL = 110.1 lbs

Base Shear, V = C_sI_pW_s = 23.1 lbs

Horizontal forces per level, F_x = C_wV (RMI sect 2.6.6)

(Service Loads)	F ₉ =	3.9 lbs	@ 90in (CM)
	F ₈ =	0.0 lbs	
	F ₇ =	0.0 lbs	
	F ₆ =	0.0 lbs	
	F ₅ =	0.0 lbs	
	F ₄ =	0.0 lbs	
	F ₃ =	0.0 lbs	
	F ₂ =	0.0 lbs	
	F ₁ =	0.0 lbs	
	F _u =	12.3 lbs	@ 42in (CM)
	ΣF _i =	23.1 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_ih_i

M_{OT} = 869 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 374 in-lbs


Factor of Safety

FOS = 0.430

UPLIFT - ANCHORS REQUIRED

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R ₁ =	12 lbs	8 lbs
R _v =	99 lbs (Uplift)	76 lbs (Uplift)
Overturning FOS =	0.490 < 1.5--ABS Req'd	0.430 < 1.5--ABS Req'd
Sliding Restraint force, R _{RST} / FOS =	69lbs / 5.796 >= 1.5 OK	47lbs / 5.828 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	34 lbs	23 lbs
Net Uplift (R _{uv}) =	484 lbs	340 lbs
Overturning + Gravity (P _u) =	550 lbs	361 lbs



Tension Allowables

Steel Strength, φN _{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, (0.75)φN _{cb} =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1a
Pullout Strength, (0.75)φN _{pn} =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1		LC #2
Factored Tension Load (N _u) =	484 lbs		340 lbs
max tension stress ratio (TSR) =	0.283	OK	0.199

Shear Allowables

Steel Strength, φV _{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, φV _{cb} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, φV _{cp} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1		LC #2
Factored Shear Load (V _u) =	34 lbs		23 lbs
Max shear stress ratio (VSR) =	0.027	OK	0.019
Combined shear and tension stress ratio (TSR + VSR) =	0.310	< 1.2 OK - LC#1 (controls)	

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266


Shelving / Single Sided 84" Tall "3RX" 9 Level 9-3RX

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	550 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064.38 lbs
$V_u / \phi V_n$ =	0.061 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	256 lbs
Area reqd. for bearing (A_{reqd}) =	0.17 ft ²
"b" distance =	4.96 in
Slab thickness (t) =	4.00 in
$S = (1") (t)^2 / 6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t (7.5) [(f'_c)^{1/2}] (S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	22 lb/in/in
$M_u = w_u L^2 / 3 = (w_u) [(b - (2")) / 2]^2 / 3$ =	16.31 in-lb/in - Defl. End M1 = 9 in-lb/in
$M_u / \phi M_{nt}$ =	0.023 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	6.5 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2 / 6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r / 1.5$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	7.4 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1484 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c / 2$ =	66090 in*lbs

Load Combination #1:	M_{OT} =	1259 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	66707 in*lbs
	Total Overturning FOS =	52.978 OK


Load Combination #2:	M_{OT} =	869 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	66464 in*lbs
	Total Overturning FOS =	76.451 OK



Shelving / Double Sided 84" Tall "3RX" 9 Level 18-3RX

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.0
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	15 lbs <---assumes (2) shelves per level
# of Levels =	9 Level
Uniform Weight per level =	5.00 psf/shelf
Weight of Unit =	100 lbs
Upright Frame anchorage spacing (Trib width) =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth (ea. side) =	9 in Shelf Load / Level / Frame
h ₉ =	9.5 in 30 lbs
h ₈ =	10 in 30 lbs
h ₇ =	9.5 in 30 lbs
h ₆ =	10 in 30 lbs
h ₅ =	9.5 in 30 lbs
h ₄ =	10 in 30 lbs
h ₃ =	9.5 in 30 lbs
h ₂ =	10 in 30 lbs
h ₁ =	6 in 30 lbs
Total Shelf Height, H _t =	84 in
Unit Base Depth, D =	8.5 in
Unit Height, H _u =	84 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.210 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(0.67)PL+DL = 221.2 lbs

Base Shear, V = C_sI_pW_s = 46.5 lbs

Horizontal forces per level, F_x = C_{vx}V (RMI sect 2.6.6)

(Service Loads, E = 0.7)

F₉ = 4.4 lbs @ 90 in (CM)

F₈ = 3.9 lbs @ 80.5 in (CM)

F₇ = 3.4 lbs @ 70.5 in (CM)

F₆ = 3.0 lbs @ 61 in (CM)

F₅ = 2.5 lbs @ 51 in (CM)

F₄ = 2.0 lbs @ 41.5 in (CM)

F₃ = 1.5 lbs @ 31.5 in (CM)

F₂ = 1.1 lbs @ 22 in (CM)

F₁ = 0.6 lbs @ 12 in (CM)

F_u = 10.2 lbs @ 42 in (CM)

ΣF_x = 46.5 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_xh_i

M_{OT} = 1849 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 1194 in-lbs

Factor of Safety

FOS = 0.646

UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.210 W_s (Cross-Aisle)

W_s = (0.67)(PL_{RF})(1.0)PL+DL = 120.1 lbs

Base Shear, V = C_sI_pW_s = 25.3 lbs

Horizontal forces per level, F_x = C_{vx}V (RMI sect 2.6.6)

(Service Loads)

F₉ = 6.9 lbs @ 90 in (CM)

F₈ = 0.0 lbs

F₇ = 0.0 lbs

F₆ = 0.0 lbs

F₅ = 0.0 lbs

F₄ = 0.0 lbs

F₃ = 0.0 lbs

F₂ = 0.0 lbs

F₁ = 0.0 lbs

F_u = 10.8 lbs @ 42 in (CM)

ΣF_x = 25.3 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), M_{OT} = ΣF_xh_i

M_{OT} = 1074 in-lbs

Calculate Resisting Moment (Service), M_{RST}

M_{RST} = 553 in-lbs

Factor of Safety

FOS = 0.514

UPLIFT - ANCHORS REQUIRED

Check Single Frame / Bay Overturning Stability:

M_{OT} (LC#1) = 1849 in-lbs

M_{RST} (LC#1) = 1194 in-lbs

FOS = M_{RST} / M_{OT} = 0.646

< 1.0 AB Req'd

--> ABs Req'd at Each Frame - FOS < 1.0 at LC#1 or LC#2

M_{OT} (LC#2) = 1074 in-lbs

M_{RST} (LC#2) = 553 in-lbs

FOS = M_{RST} / M_{OT} = 0.514

< 1.5 AB Req'd

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R _h =	16 lbs	9 lbs
R _v =	77 lbs (Uplift)	61 lbs (Uplift)
Overturning FOS =	0.646 < 1.5 - ABs Req'd	0.514 < 1.5 AB Req'd
Sliding Restraint force, R _{RST} / FOS =	82 lbs / 5.039 >= 1.5 OK	47 lbs / 5.274 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R _{uh}) =	47 lbs	25 lbs
Net Uplift (R _{uv}) =	519 lbs	314 lbs
Overturning + Gravity (P _u) =	670 lbs	353 lbs

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_{an} = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in


c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 1 - anchors per connection

S_x = 0 in

A_{se} = 0.051 in²



Tension Allowables

Steel Strength, φN _{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, (0.75)φN _{cbg} =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1a
Pullout Strength, (0.75)φN _{pn} =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N _u) =	519 lbs	314 lbs
max tension stress ratio (TSR) =	0.303 OK	0.183 OK

Shear Allowables

Steel Strength, φV _{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, φV _{cbg} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, φV _{cpo} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V _u) =	47 lbs	25 lbs
Max shear stress ratio (VSR) =	0.038 OK	0.020 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.340	< 1.2 OK - LC#1 (controls)

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Double Sided 84" Tall "3RX" 9 Level


18-3RX

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	670 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064 lbs
$V_u / \phi V_n$ =	0.074 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	331 lbs
Area reqd. for bearing (A_{reqd}) =	0.22 ft^2
"b" distance =	5.64 in
Slab thickness (t) =	4.00 in
$S = (1") (t)^2 / 6$ =	2.67 in^3/in
ϕM_{nt} (tension allowable) = $\phi_t (7.5) [(f'_c)^{1/2}] (S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	21.09 lb/in/in
$M_u = w_u L^2 / 3 = (w_u) [(b - (2")) / 2]^2 / 3$ =	23.24 in-lb/in - Defl. End $M_1 = 12$ in-lb/in
$M_u / \phi M_{nt}$ =	0.033 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	8.5 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2 / 6$ =	32.0 in^3/ft
Allowable Concrete Slab Bending Moment, $M_{all} = S \cdot f_r$ =	1183.2 $ft \cdot lbs/ft$
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	7.6 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1518 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c / 2$ =	69092 in-lbs

Load Combination #1:	$M_{OT} =$	1849 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	70286 in-lbs
	Total Overturning FOS =	38.015 OK


Load Combination #2:	$M_{OT} =$	1074 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	69644 in-lbs
	Total Overturning FOS =	64.823 OK



Shelving / Double Sided 48" Tall "R" 4 Level 36R

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5	
Supported on Elevated Floor (Y/N):	No	
Total Load per shelf =	125 lbs	<---assumes (2) shelves per level
# of Levels =	4 Level	
Uniform Weight per level =	20.83 psf/shelf	
Weight of Unit =	100 lbs	
Upright Frame anchorage spacing (Trib width) =	4 ft	(Frames are assumed to be 4'-0" oc)
Shelf depth (ea. side) =	18 in	Shelf Load / Level / Frame
h_9 =	0 in	
h_8 =	0 in	
h_7 =	0 in	
h_6 =	0 in	
h_5 =	0 in	
h_4 =	14 in	250 lbs
h_3 =	14 in	250 lbs
h_2 =	14 in	250 lbs
h_1 =	6 in	250 lbs
Total Shelf Height, H_t =	48 in	Unit Height, H_u = 48 in
Unit Base Depth, D =	24 in	



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 548.9$ lbs

Base Shear, $V = C_b I_p W_s = 173.1$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)

Note:

(CM) = Product Center of Mass typically 6 inches above the top of shelf at each level.

F_9 =	0.0 lbs	@ 0 in (CM)
F_8 =	0.0 lbs	@ 0 in (CM)
F_7 =	0.0 lbs	@ 0 in (CM)
F_6 =	0.0 lbs	@ 0 in (CM)
F_5 =	0.0 lbs	@ 0 in (CM)
F_4 =	44.7 lbs	@ 54 in (CM)
F_3 =	33.1 lbs	@ 40 in (CM)
F_2 =	21.5 lbs	@ 26 in (CM)
F_1 =	9.9 lbs	@ 12 in (CM)
F_u =	11.9 lbs	@ 24 in (CM)
ΣF_x =	173.1 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 4704$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 9240$ in-lbs

Factor of Safety

FOS = 1.964

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 267.5$ lbs

Base Shear, $V = C_b I_p W_s = 84.4$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads)

F_9 =	0.0 lbs	
F_8 =	0.0 lbs	
F_7 =	0.0 lbs	
F_6 =	0.0 lbs	
F_5 =	0.0 lbs	
F_4 =	50.1 lbs	@ 54in (CM)
F_3 =	0.0 lbs	
F_2 =	0.0 lbs	
F_1 =	0.0 lbs	
F_u =	8.9 lbs	@ 24in (CM)
ΣF_x =	84.4 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 2922$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 4200$ in-lbs

Factor of Safety

FOS = 1.438

NO UPLIFT - ANCHORS REQUIRED

Check Single Frame / Bay Overturning Stability:

M_{OT} (LC#1) = 4704 in-lbs

M_{RST} (LC#1) = 9240 in-lbs


$FOS = M_{RST} / M_{OT} = 1.964 \geq 1.5$ No AB Req'd

--> ABs Req'd - FOS < 1.5 at LC#2

M_{OT} (LC#2) = 2922 in-lbs

M_{RST} (LC#2) = 4200 in-lbs

$FOS = M_{RST} / M_{OT} = 1.438 < 1.5$ AB Req'd



Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R_u =	61 lbs	30 lbs
R_v =	0 lbs (No Uplift)	0 lbs (No Uplift)
Overturning FOS =	1.964 ≥ 1.5	1.438 < 1.5 AB Req'd
Sliding Restraint force, R_{RST} / FOS =	118lbs / 1.941 ≥ 1.5 OK	64lbs / 2.163 ≥ 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	173 lbs	84 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	995 lbs	455 lbs

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_{an} = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in

c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 1 - anchors per connection

S_x = 0 in

A_{se} = 0.051 in²

Tension Allowables

Steel Strength, ϕN_{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1a
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N_u) =	0 lbs	0 lbs
max tension stress ratio (TSR) =	0.000 OK	0.000 OK

Shear Allowables

Steel Strength, ϕV_{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, ϕV_{cbg} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpo} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V_u) =	173 lbs	84 lbs
Max shear stress ratio (VSR) =	0.140 OK	0.068 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.140	< 1.2 OK - LC#1 (controls)

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Double Sided 48" Tall "R" 4 Level


36R

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	995 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064 lbs
$V_u / \phi V_n$ =	0.110 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	621 lbs
Area reqd. for bearing (A_{reqd}) =	0.41 ft ²
"b" distance =	7.72 in
Slab thickness (t) =	4.00 in
$S = (1^*)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	16.69 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	45.52 in-lb/in - Defl. End M1 = 23 in-lb/in
$M_u / \phi M_{nt}$ =	0.064 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Total Equiv. Uniform Load	$= \frac{8}{3} wL$
$R = V$	$= wL$
V_x	$= wx$
M max. (at fixed end)	$= \frac{wL^2}{3}$
M_x (at deflected end)	$= \frac{wx^2}{6}$
M_x	$= \frac{w}{6} (L^2 - 3x^2)$
Δ max. (at deflected end)	$= \frac{wL^4}{24EI}$
Δx	$= \frac{wx}{24EI} (L^2 - x^2)^2$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	24 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all} = S \cdot f_r$ =	1183.2 ft-lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.9 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1776 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	94616 in-lbs

Load Combination #1:	$M_{OT} =$	4704 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	103856 in-lbs
	Total Overturning FOS =	22.080 OK


Load Combination #2:	$M_{OT} =$	2922 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	98816 in-lbs
	Total Overturning FOS =	33.824 OK



Shelving / Double Sided 60" Tall "T" 5 Level 36T

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	125 lbs <---assumes (2) shelves per level
# of Levels =	5 Level
Uniform Weight per level =	20.83 psf/shelf
Weight of Unit =	100 lbs
Upright Frame anchorage spacing (Trib width) =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth (ea. side) =	18 in Shelf Load / Level / Frame
h_9 =	0 in
h_8 =	0 in
h_7 =	0 in
h_6 =	0 in
h_5 =	13.5 in 250 lbs
h_4 =	13.5 in 250 lbs
h_3 =	13.5 in 250 lbs
h_2 =	13.5 in 250 lbs
h_1 =	6 in 250 lbs
Total Shelf Height, H_t =	60 in Unit Height, H_u = 60 in
Unit Base Depth, D =	24 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 661.1$ lbs

Base Shear, $V = C_s I_p W_s = 208.5$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)

Note:
(CM) = Product Center of
Mass typically 6 inches
above the top of shelf at
each level.

$F_9 = 0.0$ lbs @ 0 in (CM)

$F_8 = 0.0$ lbs @ 0 in (CM)

$F_7 = 0.0$ lbs @ 0 in (CM)

$F_6 = 0.0$ lbs @ 0 in (CM)

$F_5 = 45.2$ lbs @ 66 in (CM)

$F_4 = 36.0$ lbs @ 52.5 in (CM)

$F_3 = 26.7$ lbs @ 39 in (CM)

$F_2 = 17.5$ lbs @ 25.5 in (CM)

$F_1 = 8.2$ lbs @ 12 in (CM)

$F_u = 12.3$ lbs @ 30 in (CM)

$\Sigma F_x = 208.5$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 6831$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 11250$ in-lbs

Factor of Safety

FOS = 1.647

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, $PL_{RF} = 1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 267.5$ lbs

Base Shear, $V = C_s I_p W_s = 84.4$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads)

$F_9 = 0.0$ lbs

$F_8 = 0.0$ lbs

$F_7 = 0.0$ lbs

$F_6 = 0.0$ lbs

$F_5 = 50.0$ lbs @ 66 in (CM)

$F_4 = 0.0$ lbs

$F_3 = 0.0$ lbs

$F_2 = 0.0$ lbs

$F_1 = 0.0$ lbs

$F_u = 9.1$ lbs @ 30 in (CM)

$\Sigma F_x = 84.4$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 3570$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 4200$ in-lbs

Factor of Safety

FOS = 1.176

NO UPLIFT - ANCHORS REQUIRED

Check Single Frame / Bay Overturning Stability:

M_{OT} (LC#1) = 6831 in-lbs

M_{RST} (LC#1) = 11250 in-lbs

$FOS = M_{RST} / M_{OT} = 1.647 \geq 1.5$ No AB Req'd

--> ABs Req'd - FOS < 1.5 at LC#2

M_{OT} (LC#2) = 3570 in-lbs

M_{RST} (LC#2) = 4200 in-lbs

$FOS = M_{RST} / M_{OT} = 1.176 < 1.5$ AB Req'd

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R_u =	73 lbs	30 lbs
R_v =	0 lbs (No Uplift)	0 lbs (No Uplift)
Overturning FOS =	1.647 >= 1.5	1.176 < 1.5 AB Req'd
Sliding Restraint force, R_{RST} / FOS =	154 lbs / 2.107 >= 1.5 OK	71 lbs / 2.392 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	209 lbs	84 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	1312 lbs	513 lbs

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_{an} = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in


c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 1 - anchors per connection

S_x = 0 in

A_{se} = 0.051 in²



Tension Allowables

Steel Strength, ϕN_{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1a
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N_u) =	0 lbs	0 lbs
max tension stress ratio (TSR) =	0.000 OK	0.000 OK

Shear Allowables

Steel Strength, ϕV_{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, ϕV_{cbg} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpo} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V_u) =	209 lbs	84 lbs
Max shear stress ratio (VSR) =	0.168 OK	0.068 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.168	< 1.2 OK - LC#1 (controls)

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Double Sided 60" Tall "T" 5 Level


36T

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1312 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064 lbs
$V_u / \phi V_n$ =	0.145 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	792 lbs
Area reqd. for bearing (A_{reqd}) =	0.53 ft ²
"b" distance =	8.72 in
Slab thickness (t) =	4.00 in
$S = (1^*)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	17.26 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	64.93 in-lb/in - Defl. End M1 = 33 in-lb/in
$M_u / \phi M_{nt}$ =	0.091 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




$$\begin{aligned} \text{Total Equiv. Uniform Load} &= \frac{8}{3} w l \\ R = V &= w l \\ V_x &= w x \\ M \text{ max. (at fixed end)} &= \frac{w l^2}{3} \\ M_x \text{ (at deflected end)} &= \frac{w l^2}{6} \\ M_x &= \frac{w l^2}{6} (1^2 - 3x^2) \\ \Delta \text{ max. (at deflected end)} &= \frac{w l^4}{24 EI} \\ \Delta x &= \frac{w l^4}{24 EI} \end{aligned}$$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	24 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all} = S \cdot f_r$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.9 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1776 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	94616 in*lbs

Load Combination #1:	M_{OT} =	6831 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	105866 in*lbs
	Total Overturning FOS =	15.498 OK


Load Combination #2:	M_{OT} =	3570 in*lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	98816 in*lbs
	Total Overturning FOS =	27.676 OK



Shelving / Double Sided 90" Tall "X" 5 Level 36X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	125 lbs <---assumes (2) shelves per level
# of Levels =	5 Level
Uniform Weight per level =	20.83 psf/shelf
Weight of Unit =	100 lbs
Upright Frame anchorage spacing (Trib width) =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth (ea. side) =	18 in Shelf Load / Level / Frame
h_9 =	0 in
h_8 =	0 in
h_7 =	0 in
h_6 =	0 in
h_5 =	21 in 250 lbs
h_4 =	21 in 250 lbs
h_3 =	21 in 250 lbs
h_2 =	21 in 250 lbs
h_1 =	6 in 250 lbs
Total Shelf Height, H_t =	90 in
Unit Base Depth, D =	24 in
Unit Height, H_u =	90 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 661.1$ lbs

Base Shear, $V = C_b I_p W_s = 208.5$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)

Note:

(CM) = Product Center of Mass typically 6 inches above the top of shelf at each level.

F_9 =	0.0 lbs	@ 0 in (CM)
F_8 =	0.0 lbs	@ 0 in (CM)
F_7 =	0.0 lbs	@ 0 in (CM)
F_6 =	0.0 lbs	@ 0 in (CM)
F_5 =	47.2 lbs	@ 96 in (CM)
F_4 =	36.9 lbs	@ 75 in (CM)
F_3 =	26.5 lbs	@ 54 in (CM)
F_2 =	16.2 lbs	@ 33 in (CM)
F_1 =	5.9 lbs	@ 12 in (CM)
F_u =	13.2 lbs	@ 45 in (CM)
ΣF_x =	208.5 lbs	(@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 9931$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 11250$ in-lbs

Factor of Safety

FOS = 1.133

NO UPLIFT - ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 267.5$ lbs

Base Shear, $V = C_b I_p W_s = 84.4$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads)

F_9 =	0.0 lbs
F_8 =	0.0 lbs
F_7 =	0.0 lbs
F_6 =	0.0 lbs
F_5 =	49.7 lbs @ 96in (CM)
F_4 =	0.0 lbs
F_3 =	0.0 lbs
F_2 =	0.0 lbs
F_1 =	0.0 lbs
F_u =	9.3 lbs @ 45in (CM)
ΣF_x =	84.4 lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 5194$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 4200$ in-lbs

Factor of Safety

FOS = 0.809

UPLIFT - ANCHORS REQUIRED

Check Single Frame / Bay Overturning Stability:

M_{OT} (LC#1) = 9931 in-lbs

M_{RST} (LC#1) = 11250 in-lbs

FOS = $M_{RST} / M_{OT} = 1.133$

< 1.0 AB Req'd

--> ABs Req'd at Each Frame - FOS < 1.0 at LC#1 or LC#2

M_{OT} (LC#2) = 5194 in-lbs

M_{RST} (LC#2) = 4200 in-lbs

FOS = $M_{RST} / M_{OT} = 0.809$

< 1.5 AB Req'd

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
R_u =	73 lbs	30 lbs
R_v =	0 lbs (No Uplift)	41 lbs (Uplift)
Overturning FOS =	1.133 < 1.5 - ABs Req'd	0.809 < 1.5 AB Req'd
Sliding Restraint force, R_{RST} / FOS =	186 lbs / 2.55 >= 1.5 OK	88 lbs / 2.965 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	209 lbs	84 lbs
Net Uplift (R_{uv}) =	0 lbs	490 lbs
Overturning + Gravity (P_u) =	1587 lbs	657 lbs

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

f'_c = 3500 psi

e_{an} = 0 in <--- Eccen. Of Anchor

h_{ef} = 2 in 1.5(h_{ef}) = 3.000 in


c_a = 3.5 in 1.5(c_a) = 5.250 in

Conc. thickness, t = 4 in

of Anchors, n = 1 - anchors per connection

S_x = 0 in

A_{se} = 0.051 in²



Tension Allowables

Steel Strength, ϕN_{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1a
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N_u) =	0 lbs	490 lbs
max tension stress ratio (TSR) =	0.000 OK	0.286 OK

Shear Allowables

Steel Strength, ϕV_{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, ϕV_{cbg} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpo} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V_u) =	209 lbs	84 lbs
Max shear stress ratio (VSR) =	0.168 OK	0.068 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.354	< 1.2 OK - LC#2 (controls)

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Double Sided 90" Tall "X" 5 Level


36X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1587 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064 lbs
$V_u / \phi V_n$ =	0.175 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	889 lbs
Area reqd. for bearing (A_{reqd}) =	0.59 ft ²
"b" distance =	9.24 in
Slab thickness (t) =	4.00 in
$S = (1^*)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	18.60 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	81.19 in-lb/in - Defl. End M1 = 41 in-lb/in
$M_u / \phi M_{nt}$ =	0.114 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




$$\begin{aligned} \text{Total Equiv. Uniform Load} &= \frac{8}{3} w l \\ R = V &= w l \\ V_x &= w x \\ M \text{ max. (at fixed end)} &= \frac{w l^2}{3} \\ M_x \text{ (at deflected end)} &= \frac{w l^2}{6} \\ M_x &= \frac{w l^2}{6} (1^2 - 3x^2) \\ \Delta \text{ max. (at deflected end)} &= \frac{w l^4}{24 E I} \\ \Delta x &= \frac{w l^4}{24 E I} (1^2 - x^2)^2 \end{aligned}$$

Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	24 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all} = S \cdot f_r$ =	1183.2 ft-lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	8.9 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1776 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	94616 in-lbs

Load Combination #1:	M_{OT} =	9931 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	105866 in-lbs
	Total Overturning FOS =	10.661 OK


Load Combination #2:	M_{OT} =	5194 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)}$ =	98816 in-lbs
	Total Overturning FOS =	19.026 OK



Shelving / Double Sided 90" Tall "X" 5 Level 48X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs <---assumes (2) shelves per level
# of Levels =	5 Level
Uniform Weight per level =	18.75 psf/shelf
Weight of Unit =	100 lbs
Upright Frame anchorage spacing (Trib width) =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth (ea. side) =	24 in Shelf Load / Level / Frame
$h_9 =$	0 in
$h_8 =$	0 in
$h_7 =$	0 in
$h_6 =$	0 in
$h_5 =$	21 in 300 lbs
$h_4 =$	21 in 300 lbs
$h_3 =$	21 in 300 lbs
$h_2 =$	21 in 300 lbs
$h_1 =$	6 in 300 lbs
Total Shelf Height, $H_t =$	90 in
Unit Base Depth, $D =$	33 in
Unit Height, $H_u =$	90 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 773.4$ lbs

Base Shear, $V = C_b I_p W_s = 243.9$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)

Note:

(CM) = Product Center of
Mass typically 6 inches
above the top of shelf at
each level.

$F_9 = 0.0$ lbs @ 0 in (CM)

$F_8 = 0.0$ lbs @ 0 in (CM)

$F_7 = 0.0$ lbs @ 0 in (CM)

$F_6 = 0.0$ lbs @ 0 in (CM)

$F_5 = 56.1$ lbs @ 96 in (CM)

$F_4 = 43.8$ lbs @ 75 in (CM)

$F_3 = 31.5$ lbs @ 54 in (CM)

$F_2 = 19.3$ lbs @ 33 in (CM)

$F_1 = 7.0$ lbs @ 12 in (CM)

$F_u = 13.1$ lbs @ 45 in (CM)

$\Sigma F_x = 243.9$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 11677$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 18233$ in-lbs

Factor of Safety

FOS = 1.561

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 301.0$ lbs

Base Shear, $V = C_b I_p W_s = 94.9$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads)

$F_9 = 0.0$ lbs

$F_8 = 0.0$ lbs

$F_7 = 0.0$ lbs

$F_6 = 0.0$ lbs

$F_5 = 57.5$ lbs @ 96 in (CM)

$F_4 = 0.0$ lbs

$F_3 = 0.0$ lbs

$F_2 = 0.0$ lbs

$F_1 = 0.0$ lbs

$F_u = 9.0$ lbs @ 45 in (CM)

$\Sigma F_x = 94.9$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 5921$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 6600$ in-lbs

Factor of Safety

FOS = 1.115

NO UPLIFT - ANCHORS REQUIRED

Check Single Frame / Bay Overturning Stability:

M_{OT} (LC#1) = 11677 in-lbs

M_{RST} (LC#1) = 18233 in-lbs

FOS = $M_{RST} / M_{OT} = 1.561 \geq 1.5$ No AB Req'd

--> ABs Req'd - FOS < 1.5 at LC#2

M_{OT} (LC#2) = 5921 in-lbs

M_{RST} (LC#2) = 6600 in-lbs

FOS = $M_{RST} / M_{OT} = 1.115 < 1.5$ AB Req'd

Base Reactions:

Reactions (Service Loads):	LC #1	LC #2
$R_u =$	85 lbs	33 lbs
$R_v =$	0 lbs (No Uplift)	0 lbs (No Uplift)
Overturning FOS =	1.561 ≥ 1.5	1.115 < 1.5 AB Req'd
Sliding Restraint force, $R_{RST} / FOS =$	185 lbs / 2.169 ≥ 1.5 OK	82 lbs / 2.483 ≥ 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	244 lbs	95 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	1587 lbs	604 lbs

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment = 2.5 in

$f'_c = 3500$ psi

$e_{an} = 0$ in <--- Eccen. Of Anchor

$h_{ef} = 2$ in $1.5(h_{ef}) = 3.000$ in


$c_{an} = 3.5$ in $1.5(c_{an}) = 5.250$ in

Conc. thickness, $t = 4$ in

of Anchors, $n = 1$ - anchors per connection

$S_x = 0$ in

$A_{se} = 0.051$ in²



Tension Allowables

Steel Strength, $\phi N_{sa} =$	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg} =$	1713 lbs	<--ACI 318-14 Eq 17.4.2.1a
Pullout Strength, $(0.75)\phi N_{pn} =$	NA	<--ACI 318-14 Eq 17.4.3.1

	LC #1	LC #2
Factored Tension Load (N_u) =	0 lbs	0 lbs
max tension stress ratio (TSR) =	0.000 OK	0.000 OK

Shear Allowables

Steel Strength, $\phi V_{sa} =$	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout, $\phi V_{cbg} =$	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, $\phi V_{cpo} =$	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b

	LC #1	LC #2
Factored Shear Load (V_u) =	244 lbs	95 lbs
Max shear stress ratio (VSR) =	0.197 OK	0.077 OK
Combined shear and tension stress ratio (TSR + VSR) =	0.197	< 1.2 OK - LC#1 (controls)

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Shelving / Double Sided 90" Tall "X" 5 Level


48X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1587 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064 lbs
$V_u / \phi V_n$ =	0.175 < 1.0 O.K.



Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	949 lbs
Area reqd. for bearing (A_{reqd}) =	0.63 ft ²
"b" distance =	9.54 in
Slab thickness (t) =	4.00 in
$S = (1^2)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t(7.5)[(f'_c)^{1/2}](S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	17.42 lb/in/in
$M_u = w_u L^2/3 = (w_u)((b-(2''))/2)^2 / 3$ =	82.63 in-lb/in - Defl. End M1 = 42 in-lb/in
$M_u / \phi M_{nt}$ =	0.116 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD



Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:


Width of Single Rack =	33 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all} = S \cdot f_r$ =	1183.2 ft*lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	9.6 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	1926 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c/2$ =	111275 in*lbs
Load Combination #1:	
M_{OT} =	11677 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	129507 in*lbs
Total Overturning FOS =	11.091 OK
Load Combination #2:	
M_{OT} =	5921 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	117875 in*lbs
Total Overturning FOS =	19.907 OK



Shelving / Double Sided 90" Tall "X" 5 Level 54X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor =	1.5
Supported on Elevated Floor (Y/N):	No
Total Load per shelf =	150 lbs <---assumes (2) shelves per level
# of Levels =	5 Level
Uniform Weight per level =	16.67 psf/shelf
Weight of Unit =	100 lbs
Upright Frame anchorage spacing (Trib width) =	4 ft (Frames are assumed to be 4'-0" oc)
Shelf depth (ea. side) =	27 in Shelf Load / Level / Frame
h_9 =	0 in
h_8 =	0 in
h_7 =	0 in
h_6 =	0 in
h_5 =	21 in 300 lbs
h_4 =	21 in 300 lbs
h_3 =	21 in 300 lbs
h_2 =	21 in 300 lbs
h_1 =	6 in 300 lbs
Total Shelf Height, H_t =	90 in
Unit Base Depth, D =	39 in
Unit Height, H_u =	90 in



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1* [per RMI sect. 2.6.8(1) - PL=0.67(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})(0.67)PL + DL = 773.4$ lbs

Base Shear, $V = C_b I_p W_s = 243.9$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)

Note:

(CM) = Product Center of Mass typically 6 inches above the top of shelf at each level.

$F_9 = 0.0$ lbs @ 0 in (CM)

$F_8 = 0.0$ lbs @ 0 in (CM)

$F_7 = 0.0$ lbs @ 0 in (CM)

$F_6 = 0.0$ lbs @ 0 in (CM)

$F_5 = 56.1$ lbs @ 96 in (CM)

$F_4 = 43.8$ lbs @ 75 in (CM)

$F_3 = 31.5$ lbs @ 54 in (CM)

$F_2 = 19.3$ lbs @ 33 in (CM)

$F_1 = 7.0$ lbs @ 12 in (CM)

$F_u = 13.1$ lbs @ 45 in (CM)

$\Sigma F_x = 243.9$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 11677$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 21548$ in-lbs

Factor of Safety

FOS = 1.845

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2* [per RMI sect. 2.6.8(2) - PL=1.0(PL)]

[per RMI sect. 2.6.2, PL_{RF} = 1.0]

Seismic (C_s)(I_p) = 0.315 W_s (Cross-Aisle)

$W_s = (0.67)(PL_{RF})(1.0)PL + DL = 301.0$ lbs

Base Shear, $V = C_b I_p W_s = 94.9$ lbs

Horizontal forces per level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads)

$F_9 = 0.0$ lbs

$F_8 = 0.0$ lbs

$F_7 = 0.0$ lbs

$F_6 = 0.0$ lbs

$F_5 = 57.5$ lbs @ 96 in (CM)

$F_4 = 0.0$ lbs

$F_3 = 0.0$ lbs

$F_2 = 0.0$ lbs

$F_1 = 0.0$ lbs

$F_u = 9.0$ lbs @ 45 in (CM)

$\Sigma F_x = 94.9$ lbs (@ Factored Loads)

Calculate Overturning Moment (Service), $M_{OT} = \Sigma F_x h_i$

$M_{OT} = 5921$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 7800$ in-lbs

Factor of Safety

FOS = 1.317

NO UPLIFT - ANCHORS REQUIRED

Check Single Frame / Bay Overturning Stability:

M_{OT} (LC#1) = 11677 in-lbs

M_{RST} (LC#1) = 21548 in-lbs

FOS = $M_{RST} / M_{OT} = 1.845 \geq 1.5$ No AB Req'd

--> ABs Req'd - FOS < 1.5 at LC#2

M_{OT} (LC#2) = 5921 in-lbs

M_{RST} (LC#2) = 7800 in-lbs

FOS = $M_{RST} / M_{OT} = 1.317 < 1.5$ AB Req'd

Base Reactions:

Reactions (Service Loads):

LC #1

$R_u = 85$ lbs

$R_v = 0$ lbs (No Uplift)

Overturning FOS = 1.845 >= 1.5

Sliding Restraint force, $R_{RST} / FOS = 172$ lbs / 2.009 >= 1.5 OK

Reactions (Factored Loads):

LC #1

Base Shear (R_{uh}) = 244 lbs

Net Uplift (R_{uv}) = 0 lbs

Overturning + Gravity (P_u) = 1470 lbs

LC #2

33 lbs

0 lbs (No Uplift)

1.317 < 1.5 AB Req'd


76 lbs / 2.275 >= 1.5 OK

LC #2

95 lbs

0 lbs

545 lbs



Tension Allowables

Steel Strength, $\phi N_{sa} =$

5675 lbs

Concrete Breakout, $(0.75)\phi N_{cbg} =$

752 lbs

Pullout Strength, $(0.75)\phi N_{pn} =$

519 lbs

LC #1

0 lbs

max tension stress ratio (TSR) = 0.000 OK

LC #2

0 lbs

0.000 OK

Shear Allowables

Steel Strength, $\phi V_{sa} =$

1449 lbs

Concrete breakout, $\phi V_{cbg} =$

1704 lbs

Concrete pryout, $\phi V_{cpo} =$

1080 lbs

LC #1

244 lbs

Max shear stress ratio (VSR) = 0.226 OK

LC #2

95 lbs

0.088 OK

Combined shear and tension stress ratio (TSR + VSR) = 0.226 < 1.2 OK - LC#1 (controls)

Anchor Design (using "Cracked Concrete" Properties)

Try: 3/8"Ø DeWalt Screw Bolt+ Anchor - 2" embed.

Embedment = 2 in

$f'_c = 3500$ psi

$e_{an} = 0$ in <--- Eccen. Of Anchor

$h_{ef} = 1.33$ in $1.5(h_{ef}) = 1.995$ in

$c_a = 5$ in $1.5(c_a) = 7.500$ in

Conc. thickness, $t = 4$ in

of Anchors, $n = 1$ - anchors per connection

$S_x = 0$ in

$A_{se} = 0.094$ in²

USE: (1) 3/8"Ø DeWalt Screw Bolt+ Anchor - 2" embed. ICC REPORT #ESR-3889

Shelving / Double Sided 90" Tall "X" 5 Level


54X

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)


Max. Factored Vertical Load (P_u) =	1470 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	2 in.
Rack Post Y-Y =	2 in.
b_o =	24.00 in.
β =	1.00
V_n =	22718 lbs Eq. (22-10)
V_n max =	15107 lbs Eq. (22-10)
ϕV_n =	9064 lbs
$V_u / \phi V_n$ =	0.162 < 1.0 O.K.



Slab tension based on Soil bearing area check:

Allowable soil bearing =	1500 psf
Max. Vertical Load (Service) (P) =	908 lbs
Area reqd. for bearing (A_{reqd}) =	0.61 ft ²
"b" distance =	9.34 in
Slab thickness (t) =	4.00 in
$S = (1") (t)^2 / 6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $\phi_t (7.5) [(f'_c)^{1/2}] (S)$ =	710 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	16.86 lb/in/in
$M_u = w_u L^2 / 3 = (w_u) [(b - (2")) / 2]^2 / 3$ =	75.64 in-lb/in - Defl. End M1 = 38 in-lb/in
$M_u / \phi M_{nt}$ =	0.107 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Shelving Fixture FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	39 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2 / 6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all} = S \cdot f_r$ =	1183.2 ft-lbs/ft
Effective Cantilever Span Length (L_c) at M_{all} =	6.9 ft
Total Length of Slab (L_c + Width of Single Rack) =	10.1 ft
Trib. Width of Slab = Trib width of Rack =	4.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	2026 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot L_c / 2$ =	123130 in-lbs

Load Combination #1:	$M_{OT} =$	11677 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	144678 in-lbs
	Total Overturning FOS =	12.390 OK

Load Combination #2:	$M_{OT} =$	5921 in-lbs
	$M_{RST(Rack)} + M_{RST(slab)} =$	130930 in-lbs
	Total Overturning FOS =	22.112 OK



Storage Rack - Seismic Design


Rack AWS

24/44-120 075A

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor (I_p) =	1.0	<--- No Public Access Allowed (Typ. at Back Stockroom / Grocery Storage Areas)
Supported on Elevated Floor (Y/N):	No	
Max. Weight per level (2 Pallets / shelf) =	1035 lbs/shelf	
Weight of Unit =	250 lbs	<--- Shipping weight per Manuf.
Rack Trib width (CL-to-CL of frames) =	96 in	Total Shelf Load
h_9 =	0 in	0 lbs
h_8 =	0 in	0 lbs
h_7 =	0 in	0 lbs
h_6 =	0 in	0 lbs
h_5 =	0 in	0 lbs
h_4 =	0 in	0 lbs
h_3 =	36 in	1035 lbs
h_2 =	48 in	1035 lbs
h_1 =	36 in	500 lbs
Total Shelf Height, H_t =	120 in	
Unit Height, H_u =	120 in	
Unit Base Depth, D =	24 in	

Note: Per ANSI MH16.1, Section 6.3, effective lengths may be determined by rational methods consistent with AISI or AISC. AISC Design by Second-Order Analysis, Section C2.2a is used. Notional loads are applied to gravity load cases and $K=1.0$ is used since the ratio of second-order drift to first-order drift ($P-\delta$) / ($P-\Delta$) < 1.1.



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1 [RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[RMI sect 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.210 W_s (Braced)
0.076 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 1403.7$ lbs
Base Shear, $V = C_{sp}W_s = 295.1$ lbs (Braced)
107.1 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx}V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)
 $F_9 = 0.0$ lbs @ 0 in (CM)
 $F_8 = 0.0$ lbs @ 0 in (CM)
 $F_7 = 0.0$ lbs @ 0 in (CM)
 $F_6 = 0.0$ lbs @ 0 in (CM)
 $F_5 = 0.0$ lbs @ 0 in (CM)
 $F_4 = 0.0$ lbs @ 0 in (CM)
 $F_3 = 98.8$ lbs @ 140 in (CM)
 $F_2 = 72.0$ lbs @ 102 in (CM)
 $F_1 = 20.5$ lbs @ 60 in (CM)
 $F_u = 15.3$ lbs @ 60 in (CM)

Note:
(CM) = Product Center of Mass typically 20 inches above the top of shelf at each level.

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$

$M_{OT} = 23327$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 23663$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.014$

NO UPLIFT - ANCHORS REQUIRED

Load Case 2 [RMI sect. 2.6.8(2), $PL=1.0(PL)$]

[RMI 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.210 W_s (Braced)
0.076 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 943.5$ lbs
Base Shear, $V = C_{sp}W_s = 198.4$ lbs (Braced)
72.0 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx}V$ (RMI sect 2.6.6)

(Service Loads) $F_9 = 0.0$ lbs
 $F_8 = 0.0$ lbs
 $F_7 = 0.0$ lbs
 $F_6 = 0.0$ lbs
 $F_5 = 0.0$ lbs
 $F_4 = 0.0$ lbs
 $F_3 = 125.8$ lbs @ 140 in (CM)
 $F_2 = 0.0$ lbs
 $F_1 = 0.0$ lbs
 $F_u = 13.0$ lbs @ 60 in (CM)

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$


$M_{OT} = 18397$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 15420$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 0.838$

UPLIFT - ANCHORS REQUIRED



Anchor Design (using "Cracked Concrete" Properties)

Upright Post Type = UA

Try: 1/2" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment (h_{nom}) = 2.5 in

$f_c = 3500$ psi

$e_{a1} = 1.875$ in <--- Eccen. of Anchor

$h_{ef} = 2$ in 1.5(h_{ef}) = 3.000 in

Conc. thickness, $t = 5$ in 1.5(C_d) = 15.000 in

of Anchors, $n = 1$

$S_x = 0.00$ in

$S_y = 0.00$ in

$A_{se} = 0.099$ in²

Base Reactions:

	LC #1	LC #2
R_n =	103 lbs	69 lbs
R_v =	0 lbs	124 lbs
Overturning FOS =	1.014	0.838
Sliding Restraint, $R_{RST}/FOS = 418$ lbs / 4.051	>= 1.5 OK	310 lbs / 4.459 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	295 lbs	198 lbs
Net Uplift (R_{uv}) =	0 lbs	1720 lbs
Overturning + Gravity (P_u) =	3552 lbs	2332 lbs

Tension Allowables

Steel Strength, ϕN_{sa} =	7306 lbs	<---ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<---ACI 318-14 Eq 17.4.2.1b
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<---ACI 318-14 Eq 17.4.3.1
Factored Tension Load, (N_u) =	0 lbs	1720 lbs (LC #2)
max tension stress ratio (TSR) =	0.000	OK (LC#1) 1.004 OK (LC#2)

Shear Allowables

Steel Strength, ϕV_{sa} =	3321 lbs	<---ACI 318-14 Eq 17.5.1.2c
Concrete breakout (Y_g), ϕV_{cbg} =	5702 lbs	<---ACI 318-14 Eq 17.5.2.1b
Concrete breakout (X_g), ϕV_{cbg} =	5069 lbs	<---ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpa} =	2460 lbs	<---ACI 318-14 Eq 17.5.3.1b
Factored Shear Load (V_u) :	Braced = 295 lbs	198 lbs
	Down Aisle = 107 lbs	72 lbs
Max shear stress ratio (VSR) :	Braced = 0.120	OK
	Down Aisle = 0.044	OK
	Braced (TSR+VSR <= 1.2) = 1.085	<= 1.2 OK - LC #2 Controls
	Down Aisle (VSR <= 1.0) = 0.044	OK - LC #1 Controls

USE: (1) 1/2" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Storage Rack - Seismic Design

Rack AWS


24/44-120 075A

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	3552 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	5 in.
Rack Post X-X =	5.00 in.
Rack Post Y-Y =	3.75 in.
b_o =	37.50 in.
β =	1.33
V_n =	36975 lbs Eq. (22-10)
V_n max =	29506 lbs Eq. (22-10)
ϕV_n =	17704 lbs
$V_u / \phi V_n$ =	0.201 < 1.0 O.K.



Max Vertical Load (ASD) - RMI, sect 2.1 - LC#4:

$$P = (1+0.11S_d)DL + (3/4)[(1+0.14S_d)PL + (0.7)EL]$$

S_{DS} =	0.841 ($I_p=1$)
DL = (Frame Wt/2) =	125 lbs
PL = Σ (Shelf Load $h_1 - h_2$)/2 =	1285 lbs
EL = $M_{OT, LCH1} / ((0.7)(D))$ =	2073 lbs
P =	1943 lbs <-- At Each Post

Max Vertical Load (LRFD) - RMI, sect 2.2 - LC#5:


$$P = (1.2+0.2S_d)DL + (0.85+0.2S_d)PL + EL$$

P_u =	3552 lbs <-- At Each Post
---------	---------------------------

Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Service Vertical Load (P) =	1943 lbs
Area reqd. for bearing (A_{reqd}) =	1.30 ft ²
"b" distance =	13.66 in
Slab thickness (t) =	5.00 in
$S = (1^3)(t)^2/6 =$	4.17 in ³ /in
ϕM_{nt} (tension allowable) = $f_t^* 7.5 * [(f'_c)^{1/2}] * S =$	1109.26 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd} =$	19.04 lb/in/in
$M_u = wL^2/3 = (w_u)[(b-\min(X-X, Y-Y))/2]^2 / 3 =$	155.77 in-lb/in - Defl. End M1 = 78 in-lb/in
$M_u / \phi M_{nt} =$	0.140 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Rack FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	24 in
Slab thickness (t) =	5.0 in
Modulus of Rupture, $f_r = 7.5 * \text{SQRT}(f'_c) =$	443.7 psi
Concrete Slab Section Modulus, $S = b(t^2)/6 =$	50.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S * f_r / 1.5 =$	1232.5 ft*lbs/ft
Effective Cantilever Span Length (l_c) at $M_{all} =$	6.3 ft
Total Length of Slab (l_c + Width of Single Rack) =	8.3 ft
Trib. Width of Slab = Trib width of Rack =	8.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	4140.1 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} * l_c/2 =$	205684 in*lbs
Load Combination #1: $M_{OT} =$	23327 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	229346 in*lbs
Total Overturning FOS =	9.832 OK
Load Combination #2: $M_{OT} =$	18397 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	221104 in*lbs
Total Overturning FOS =	12.018 OK



Upright Frame Member/Connection Design:



Upright Frame Geometry

Height, H (in)	Width, B (in)	Panel - D ₁ , in	Panel - D ₂ , in	Panel - D ₃ , in	Frame Post Type	Base PL Type	Frame Type
120	24	52	52	0	UA	BP-1	Desk

Upright Column (UC) Section Properties

Mark :		UCA300x225x0075				
b _c (in)	h _c (in)	t _c (in)	w _c (in)	A _g (in ²)	A _g (in ²)	x _{bar} (in)
3.000	2.250	0.075	0.500	0.637	0.511	0.946
I _x (in ⁴)	S _x (in ³)	I _y (in ⁴)	S _y (in ³)	C _w (in ⁶)	J (in ⁴)	r _o (in)
0.937	0.511	0.387	0.297	0.514	0.00119	2.502
r _x (in) =	1.354	r _y (in) =	0.870			

Upright Frame Horizontal (UH) / Diagonal (UD) Brace Section Properties

Mark : C275x1063x0062						
b_w (in)	h_w (in)	t_w (in)	w_w (in)	A_g (in ²)	x_{bar} (in)	x_0 (in)
2.750	1.063	0.062	0.438	0.325	0.352	0.834
I_x (in ⁴)	S_x (in ³)	I_y (in ⁴)	S_y (in ³)	C_w (in ⁶)	J (in ⁴)	r_o (in)
0.360	0.262	0.050	0.070	0.093	0.00042	1.399
r_x (in) =	1.053	r_y (in) =	0.391			

Upright Frame Shelf Beam Section Properties

Mark :		B410x250x0066	
d (in)	b (in)	c _b (in)	c _w (in)
4.100	2.500	1.625	0.875
t (in)	I _x (in ⁴)	S _x (in ³)	r _x (in)
0.066	1.716	0.792	1.441
A _g (in ²)	I _y (in ⁴)	S _y (in ³)	r _y (in)
0.827	0.761	0.557	0.960
x _{bar} (in) =	1.133	y _{bar} (in) =	1.932

Storage Rack - Seismic Design

Rack AWS

24/44-120 075A

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Upright Post Base Plate Design:

Check for Axial Compression, P_{max} :

Base Plate Type = BP-1
Base Plate Depth = 5.00 in
Base Plate Width = 3.75 in
Default Plate Thickness = 0.2500 in
Base Plate Area, A_{BP} = 18.75 in²
Upright Width, b_c = 3.000 in
Upright Depth, h_c = 2.250 in
Upright Post Brg Area, A_{Post} = 6.75 in²
 A_{reqd} / A_{Post} = 0.396 < 1.0 O.K.
 P_{max} (per RISA) = 6554 lbs
 T_{max} (per RISA) = 2021 lbs
Design Bearing Pressure, f_p = 349.55 psi
Required Bearing Area, $A_{reqd} = P_{max} / (0.7f_c)$ = 2.6751 in²

Upright Frame Steel Material:

ASTM A570, Grade 55
 F_y = 55,000 psi
 F_u = 70,000 psi
 E = 29,000 ksi

----- Base Plate Size and Thickness is acceptable for Axial Compression

Check for Axial Tension, T_{max} :

Tension force per bolt, f_t = 2021.00 lbs
Bolt CL dist to face of Post = 0.25 in
Effective Plate Width, b_{eff} = 3.75 in

Min. Thickness required, t_{pl} = 0.11078 in <--- Base Plate Thickness is Adequate

Shelf Beam End Connections (2 Lug Connector)

ASTM A570, GR. 35 (F_y = 55 ksi, F_u = 70 ksi) $\Omega_b = 1.6$

$\Omega_b = 1.67$

Beam End Connector Bending Capacity check:

$\lambda_p = 0.54 \sqrt{E/F_y} = 12.3997$
Connector PL Thickness, t = 0.1875 in
Net Lug width, b_{lug} = 0.6563 in
Min. Beam Depth, H_{bm} = 4.100 in
Net Lug Height, $b_{lug,h}$ = 0.875 in
Uniform beam load, w = 64.7 lb/ft <--- (1/2 Max. Shelf Load) / (Rack Trib width)

$\lambda_{min}, b/t = 4.6667 < \lambda_p$
 $A_{lug} = (t)(b_{lug,h}) = 0.16406$ in²
 $A_{brg,col} = (t_c)(b_{lug,h}) = 0.06563$ in²
 $d_{CL} = 4" + b_{lug,h} - b_{lug,h}/2 = 4.4375$ in

Determine max. T_A for connector lug (shear or bearing on column):

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs <--- Shear at Lug tab
 $P_a = (A_{brg,col})(2.1F_y)/\Omega_b = 4539$ lbs <--- Lug Brg on Column Wall
 $T_A = \min(V_a, P_a) = 3384$ lbs
 $M_A = (T_A)(d_{CL}) + (T_A)(b_{lug,h}/2) + M_{x,pl,all} = 19940$ in-lbs
 M_{lat} (per RISA, Joint J47) = 1800 in-lbs
 $M_{graviv} = (1/2)[wL^2/12] = 2070$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{graviv} = 3870$ in-lbs
 $M / M_A = 0.194 < 1.0$ O.K.

Connector Plate Bending Capacity:

$A_{0,pl} = 0.5215$ in²


$r_o = r_i + t = 0.3125$ in L_x (long leg) = 2.1875 in
 $r_i = 0.1250$ in L_y (short leg) = 0.8750 in
 $x_{bar} = 0.8907$ in $y_{bar} = 0.2121$ in
 $I_x = 0.0199$ in⁴ $S_x = I_x / y_{bar} = 0.0938$ in³
 $M_{x,pl,all} = (\text{bent about Long Leg} - (x\text{-axis})) = (1.5)(F_y)(S_x)/\Omega_b = 4632$ in-lbs (AISC Eq. F10-1)

Shear Capacity check:


$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs / lug
 V (Impact) = 258.75 lbs - 25% Max. Shelf Load at beam end (RMI section 2.3)
 V (per RISA, member SB42) = 587 lbs - total beam end shear
 $V / V_A = 0.125 < 1.0$ O.K.

Beam to Connector Weld check:

Shelf Beam Wall thickness, t_{beam} = 0.075 in
Shelf Beam Depth, $H_{bm} = H_{weld} = 4.100$ in
Top Beam Flange width, $B_{weld} = 1.625$ in
Beam Haunch depth, $Y_{weld} = 1.500$ in
Corner offset distance, d_{corner} = 0.200 in
Vertical Weld length, L_1 = 3.700 in
Top Weld length, L_2 = 1.225 in
Vertical Weld length, L_3 = 1.175 in
Total Length of Weld, L_w = 6.100 in
Distance to Y-axis Centroid, = 0.47618 in
Distance to X-axis Centroid, = 2.70487 in
Moment Inertia of Weld - X-axis, $I_{x,weld} = 0.71829$ in⁴
Moment Inertia of Weld - Y-axis, $I_{y,weld} = 0.23701$ in⁴
Polar Moment of Inertia, $I_p = I_x + I_y = 0.95530$ in⁴
 $F_{w,all} = [(0.6)F_{exx}/\Omega_{weld}](1+0.5\sin^{1.5}(\theta)) = 31500$ psi
 $M_{all} = (F_{w,all})(I_p)/c = 12013$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{graviv} = 3870$ in-lbs
 $M / M_{all} = 0.322 < 1.0$ O.K.
Interior Bend Radius = 0.125 in
Fillet Weld leg width = 0.125 in
Weld throat width, w_w = 0.08839 in
 $\Omega_{weld} = 2.00$
 $F_{exx} = 70$ ksi
2.73 in <--- distance to bottom of L_3



Beam End Section at 2 Lug Connector



Storage Rack - Seismic Design


Rack B

44-120 125S

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor (I_p) =	1.0	<--- No Public Access Allowed (Typ. at Back Stockroom / Grocery Storage Areas)
Supported on Elevated Floor (Y/N):	No	
Max. Weight per level (2 Pallets / shelf)	3300 lbs/shelf	
Weight of Unit =	250 lbs	<--- Shipping weight per Manuf.
Rack Trib width (CL-to-CL of frames) =	96 in	Total Shelf Load
h_9 =	0 in	0 lbs
h_8 =	0 in	0 lbs
h_7 =	0 in	0 lbs
h_6 =	0 in	0 lbs
h_5 =	0 in	0 lbs
h_4 =	36 in	3300 lbs
h_3 =	36 in	3300 lbs
h_2 =	36 in	3300 lbs
h_1 =	12 in	3300 lbs
Total Shelf Height, H_t =	120 in	
Unit Height, H_u =	120 in	
Unit Base Depth, D =	44 in	

Note: Per ANSI MH16.1, Section 6.3, effective lengths may be determined by rational methods consistent with AISI or AISC. AISC Design by Second-Order Analysis, Section C2.2a is used. Notional loads are applied to gravity load cases and $K=1.0$ is used since the ratio of second-order drift to first-order drift $(P-\delta) / (P-\Delta) < 1.1$.



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1 [RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[RMI sect 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.210 W_s (Braced)
0.076 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 6175.5$ lbs
Base Shear, $V = C_s I_p W_s = 1298.4$ lbs (Braced)
471.1 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)
 $F_9 = 0.0$ lbs @ 0 in (CM)
 $F_8 = 0.0$ lbs @ 0 in (CM)
 $F_7 = 0.0$ lbs @ 0 in (CM)
 $F_6 = 0.0$ lbs @ 0 in (CM)
 $F_5 = 0.0$ lbs @ 0 in (CM)
 $F_4 = 375.2$ lbs @ 144 in (CM)
 $F_3 = 265.8$ lbs @ 102 in (CM)
 $F_2 = 172.0$ lbs @ 66 in (CM)
 $F_1 = 78.2$ lbs @ 30 in (CM)
 $F_u = 17.7$ lbs @ 60 in (CM)

Note:
(CM) = Product Center of Mass typically 20 inches above the top of shelf at each level.

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$

$M_{OT} = 95903$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 200068$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 2.086$

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2 [RMI sect. 2.6.8(2), $PL=1.0(PL)$]

[RMI 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.210 W_s (Braced)
0.076 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 2461.0$ lbs
Base Shear, $V = C_s I_p W_s = 517.4$ lbs (Braced)
187.7 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads)
 $F_9 = 0.0$ lbs
 $F_8 = 0.0$ lbs
 $F_7 = 0.0$ lbs
 $F_6 = 0.0$ lbs
 $F_5 = 0.0$ lbs
 $F_4 = 350.8$ lbs @ 140 in (CM)
 $F_3 = 0.0$ lbs
 $F_2 = 0.0$ lbs
 $F_1 = 0.0$ lbs
 $F_u = 11.4$ lbs @ 60 in (CM)

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$


$M_{OT} = 49796$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 78100$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.568$

NO UPLIFT - NO ANCHORS REQUIRED



Anchor Design (using "Cracked Concrete" Properties)

Upright Post Type = UA

Try: 1/2" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment (h_{nom}) = 2.5 in

$f_c = 3500$ psi

$e_{an} = 1.875$ in <-- Eccen. of Anchor

$h_{ef} = 2$ in 1.5(h_{ef}) = 3.000 in

Conc. thickness, $t = 4$ in 1.5(C_d) = 15.000 in

of Anchors, $n = 1$

$S_x = 0.00$ in

$S_y = 0.00$ in

$A_{se} = 0.099$ in²

Base Reactions:

	LC #1	LC #2
R_n =	454 lbs	181 lbs
R_v =	0 lbs	0 lbs
Overturning FOS =	2.086	1.568
Sliding Restraint, R_{RST}/FOS =	1317 lbs / 2.898	591 lbs / 3.261
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	1298 lbs	517 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	11539 lbs	4264 lbs

Tension Allowables

Steel Strength, ϕN_{sa} =	7306 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1b
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<--ACI 318-14 Eq 17.4.3.1
Factored Tension Load, (N_u) =	0 lbs	(LC #1)
max tension stress ratio (TSR) =	0.000	OK (LC#1)
		0.000 OK (LC#2)

Shear Allowables

Steel Strength, ϕV_{sa} =	3321 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout (Y_g), ϕV_{cbg} =	5702 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete breakout (X_g), ϕV_{cbg} =	5069 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpa} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b
Factored Shear Load (V_u) :		
Braced =	1298 lbs	517 lbs
Down Aisle =	471 lbs	188 lbs
Max shear stress ratio (VSR) :		
Braced =	0.528	OK
Down Aisle =	0.192	OK
Braced (TSR+VSR <= 1.2) =	0.528	<= 1.2 OK - LC #1 Controls
Down Aisle (VSR <= 1.0) =	0.192	OK - LC #1 Controls

USE: (1) 1/2" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Storage Rack - Seismic Design

Rack B


44-120 125S

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	11539 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	5.00 in.
Rack Post Y-Y =	3.75 in.
b_o =	33.50 in.
β =	1.33
V_n =	26425 lbs Eq. (22-10)
V_n max =	21087 lbs Eq. (22-10)
ϕV_n =	12652 lbs
$V_u / \phi V_n$ =	0.912 < 1.0 O.K.



Max Vertical Load (ASD) - RMI, sect 2.1 - LC#4:

$$P = (1+0.11Sds)DL + (3/4)[(1+0.14Sds)PL + (0.7)EL]$$

S_{DS} =	0.841 ($I_p=1$)
DL = (Frame Wt/2) =	125 lbs
PL = Σ (Shelf Load $h_1 - h_2$)/2 =	6600 lbs
EL = $M_{OT, LCH1} / ((0.7)(D))$ =	4648 lbs
P =	7304 lbs <--- At Each Post

Max Vertical Load (LRFD) - RMI, sect 2.2 - LC#5:


$$P = (1.2+0.2Sds)DL + (0.85+0.2Sds)PL + EL$$

$$P_u = 11539 \text{ lbs <--- At Each Post}$$

Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Service Vertical Load (P) =	7304 lbs
Area reqd. for bearing (A_{reqd}) =	4.87 ft ²
"b" distance =	26.48 in
Slab thickness (t) =	4.00 in
$S = (1^3)(t)^2/6 =$	2.67 in ³ /in
ϕM_{rt} (tension allowable) = $f_t^* 7.5 * [(f'_c)^{1/2}] * S =$	709.93 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd} =$	16.46 lb/in/in
$M_u = wL^2/3 = (w_u)[(b - \min(X-X, Y-Y))/2]^2 / 3 =$	708.52 in-lb/in - Defl. End M1 = 355 in-lb/in
$M_u / \phi M_{rt} =$	0.998 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Rack FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	44 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 * \text{SQRT}(f'_c) =$	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6 =$	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S * f_r / 1.5 =$	788.8 ft*lbs/ft
Effective Cantilever Span Length (l_c) at $M_{all} =$	5.6 ft
Total Length of Slab (l_c + Width of Single Rack) =	9.3 ft
Trib. Width of Slab = Trib width of Rack =	8.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	3713.5 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} * l_c/2 =$	206854 in*lbs
Load Combination #1: $M_{OT} =$	95903 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	406922 in*lbs
Total Overturning FOS =	4.243 OK
Load Combination #2: $M_{OT} =$	49796 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	284954 in*lbs
Total Overturning FOS =	5.722 OK



Upright Frame Member/Connection Design:



Upright Frame Geometry

Height, H (in)	Width, B (in)	Panel - D ₁ , in	Panel - D ₂ , in	Panel - D ₃ , in	Frame Post Type	Base PL Type	Frame Type
120	44	40	40	24	UA	BP-1	Typical

Upright Column (UC) Section Properties

Mark :		UCA300x225x0075				
b _c (in)	h _c (in)	t _c (in)	w _c (in)	A _g (in ²)	A _g (in ²)	x _{bar} (in)
3.000	2.250	0.075	0.500	0.637	0.511	0.946
I _x (in ⁴)	S _x (in ³)	I _y (in ⁴)	S _y (in ³)	C _w (in ⁶)	J (in ⁴)	r _o (in)
0.937	0.511	0.387	0.297	0.514	0.00119	2.502
r _x (in) =	1.354	r _y (in) =	0.870			

Upright Frame Horizontal (UH) / Diagonal (UD) Brace Section Properties

Upright H-Shape: Horizontal Dimensions (inches) (US) Grade Section Properties						
Mark :		C275x1063x0062				
b_w (in)	h_w (in)	t_w (in)	w_w (in)	A_g (in ²)	x_{50s} (in)	x_0 (in)
2.750	1.063	0.062	0.438	0.325	0.352	0.834
I_x (in ⁴)	S_x (in ³)	I_y (in ⁴)	S_y (in ³)	C_w (in ⁶)	J (in ⁴)	r_o (in)
0.360	0.262	0.050	0.070	0.093	0.00042	1.399
r_x (in) =	1.053	r_y (in) =	0.391			

Upright Frame Shelf Beam Section Properties

Mark : B410x250x0066			
d (in)	b (in)	c_h (in)	c_w (in)
4.100	2.500	1.625	0.875
t (in)	I_x (in ⁴)	S_x (in ³)	r_x (in)
0.066	1.716	0.792	1.441
A_g (in ²)	I_y (in ⁴)	S_y (in ³)	r_y (in)
0.827	0.761	0.557	0.960
x_{bar} (in) =	1.133	y_{bar} (in) =	1.932

Storage Rack - Seismic Design

Rack B

44-120 125S

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Upright Post Base Plate Design:

Check for Axial Compression, P_{max} :

Base Plate Type =	BP-1
Base Plate Depth =	5.00 in
Base Plate Width =	3.75 in
Default Plate Thickness =	0.2500 in
Base Plate Area, A_{BP} =	18.75 in ²
Upright Width, b_c =	3.000 in
Upright Depth, h_c =	2.250 in
Upright Post Brg Area, A_{Post} =	6.75 in ²
A_{reqd} / A_{Post} =	0.658 < 1.0 O.K.
P_{max} (per RISA) =	10888.013 lbs
T_{max} (per RISA) =	1278.251 lbs
Design Bearing Pressure, f_p =	580.69 psi
Required Bearing Area, $A_{reqd} = P_{max} / (0.7f_c)$ =	4.4441 in ²

Upright Frame Steel Material:

ASTM A570, Grade 55	
F_y =	55,000 psi
F_u =	70,000 psi
E =	29,000 ksi

----- Base Plate Size and Thickness is acceptable for Axial Compression

Check for Axial Tension, T_{max} :

Tension force per bolt, f_t =	1278.25 lbs
Bolt CL dist to face of Post =	0.25 in
Effective Plate Width, b_{eff} =	3.75 in

Min. Thickness required, t_{pl} = 0.08810 in <--- Base Plate Thickness is Adequate

Shelf Beam End Connections (2 Lug Connector)

ASTM A570, GR. 35 (F_y = 55 ksi, F_u = 70 ksi) $\Omega_b = 1.6$

$\Omega_b = 1.67$

Beam End Connector Bending Capacity check:

$\lambda_p = 0.54 \sqrt{E/F_y} =$	12.3997	$\lambda_{min}, b/t =$	4.6667 < λ_p
Connector PL Thickness, $t =$	0.1875 in	$A_{lug} = (t)(b_{lug,h}) =$	0.16406 in ²
Net Lug width, $b_{lug} =$	0.6563 in	$A_{brg,col} = (t_c)(b_{lug,h}) =$	0.06563 in ²
Min. Beam Depth, $H_{bm} =$	4.100 in	$d_{CL} = 4" + b_{lug,h} - b_{lug,h}/2 =$	4.4375 in
Net Lug Height, $b_{lug,h} =$	0.875 in		
Uniform beam load, $w =$	206.3 lb/ft <--- (1/2 Max. Shelf Load) / (Rack Trib width)		

Determine max. T_A for connector lug (shear or bearing on column):

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v =$	3384 lbs <--- Shear at Lug tab
$P_a = (A_{brg,col})(2.1F_u)/\Omega_b =$	4539 lbs <--- Lug Brg on Column Wall
$T_A = \min(V_a, P_a) =$	3384 lbs
$M_A = (T_A)(d_{CL}) + (T_A)(b_{lug,h}/2) + M_{x,pl,all} =$	19940 in-lbs
M_{lat} (per RISA, Joint J47) =	4376.016 in-lbs
$M_{graviv} = (1/2)[wL^2/12] =$	6600 in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} =$	10976 in-lbs
$M / M_A =$	0.550 < 1.0 O.K.

Connector Plate Bending Capacity:



$A_{0,pl} =$	0.5215 in ²		
$r_o = r_i + t =$	0.3125 in	L_x (long leg) =	2.1875 in
$r_i =$	0.1250 in	L_y (short leg) =	0.8750 in
$x_{bar} =$	0.8907 in	$y_{bar} =$	0.2121 in
$I_x =$	0.0199 in ⁴	$S_x = I_x / y_{bar} =$	0.0938 in ³
$M_{x,pl,all} =$ (bent about Long Leg - (x-axis)) =	$(1.5)(F_y)(S_x)/\Omega_b =$		4632 in-lbs (AISC Eq. F10-1)

Shear Capacity check:

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v =$	3384 lbs / lug
V (Impact) =	825 lbs - 25% Max. Shelf Load at beam end (RMI section 2.3)
V (per RISA, member SB42) =	1185.684 lbs - total beam end shear
$V / V_A =$	0.297 < 1.0 O.K.

Beam to Connector Weld check:

Shelf Beam Wall thickness, $t_{beam} =$	0.075 in
Shelf Beam Depth, $H_{bm} = H_{weld} =$	4.100 in
Top Beam Flange width, $B_{weld} =$	1.625 in
Beam Haunch depth, $Y_{weld} =$	1.500 in
Corner offset distance, $d_{corner} =$	0.200 in
Vertical Weld length, $L_1 =$	3.700 in
Top Weld length, $L_2 =$	1.225 in
Vertical Weld length, $L_3 =$	1.175 in
Total Length of Weld, $L_w =$	6.100 in
Distance to Y-axis Centroid, =	0.47618 in
Distance to X-axis Centroid, =	2.70487 in
Moment Inertia of Weld - X-axis, $I_{x,weld} =$	0.71829 in ⁴
Moment Inertia of Weld - Y-axis, $I_{y,weld} =$	0.23701 in ⁴
Polar Moment of Inertia, $I_p = I_x + I_y =$	0.95530 in ⁴
$F_{w,all} = [(0.6)F_{exx}/\Omega_{weld}](1+0.5\sin^{1.5}(\theta)) =$	31500 psi
$M_{all} = (F_{w,all})(I_p)/c =$	12013 in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} =$	10976 in-lbs
$M / M_{all} =$	0.914 < 1.0 O.K.
Interior Bend Radius =	0.125 in
Fillet Weld leg width =	0.125 in
Weld throat width, $w_w =$	0.08839 in
$\Omega_{weld} =$	2.00
$F_{exx} =$	70 ksi
	2.73 in <--- distance to bottom of L_3



Storage Rack - Seismic Design

Rack D


24-120 075A

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	5136 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	5.00 in.
Rack Post Y-Y =	3.75 in.
b_o =	33.50 in.
β =	1.33
V_n =	26425 lbs Eq. (22-10)
V_n max =	21087 lbs Eq. (22-10)
ϕV_n =	12652 lbs
$V_u / \phi V_n$ =	0.406 < 1.0 O.K.



Max Vertical Load (ASD) - RMI, sect 2.1 - LC#4:

$$P = (1+0.11S_d)DL + (3/4)[(1+0.14S_d)PL + (0.7)EL]$$

S_{DS} =	0.841 ($I_p=1$)
DL = (Frame Wt/2) =	125 lbs
PL = Σ (Shelf Load $h_1 - h_2$)/2 =	2070 lbs
EL = $M_{OT, LCH1} / ((0.7)(D))$ =	2858 lbs
P =	2877 lbs <-- At Each Post

Max Vertical Load (LRFD) - RMI, sect 2.2 - LC#5:


$$P = (1.2+0.2S_d)DL + (0.85+0.2S_d)PL + EL$$

P_u =	5136 lbs <-- At Each Post
---------	---------------------------

Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Service Vertical Load (P) =	2877 lbs
Area reqd. for bearing (A_{reqd}) =	1.92 ft ²
"b" distance =	16.62 in
Slab thickness (t) =	4.00 in
$S = (1^3)(t)^2/6 =$	2.67 in ³ /in
ϕM_{rt} (tension allowable) = $f_t^* 7.5[(f'_c)^{1/2}]^2 S =$	709.93 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd} =$	18.60 lb/in/in
$M_u = wL^2/3 = (w_u)[(b-\min(X-X, Y-Y))/2]^2 / 3 =$	256.64 in-lb/in - Defl. End M1 = 129 in-lb/in
$M_u / \phi M_{rt} =$	0.362 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Rack FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	24 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 \cdot \text{SQRT}(f'_c) =$	443.7 psi
Concrete Slab Section Modulus, $S = b(t^2)/6 =$	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S \cdot f_r / 1.5 =$	788.8 ft*lbs/ft
Effective Cantilever Span Length (l_c) at $M_{all} =$	5.6 ft
Total Length of Slab (l_c + Width of Single Rack) =	7.6 ft
Trib. Width of Slab = Trib width of Rack =	8.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	3046.9 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} \cdot l_c/2 =$	139251 in*lbs
Load Combination #1: $M_{OT} =$	32167 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	175536 in*lbs
Total Overturning FOS =	5.457 OK
Load Combination #2: $M_{OT} =$	18397 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	154671 in*lbs
Total Overturning FOS =	8.407 OK



Upright Frame Member/Connection Design:



Upright Frame Geometry

Height, H (in)	Width, B (in)	Panel - D ₁ , in	Panel - D ₂ , in	Panel - D ₃ , in	Frame Post Type	Base PL Type	Frame Type
120	24	40	40	24	UA	BP-1	Typical

Upright Column (UC) Section Properties

Mark :		UCA300x225x0075				
b _c (in)	h _c (in)	t _c (in)	w _c (in)	A _g (in ²)	A _g (in ²)	x _{bar} (in)
3.000	2.250	0.075	0.500	0.637	0.511	0.946
I _x (in ⁴)	S _x (in ³)	I _y (in ⁴)	S _y (in ³)	C _w (in ⁶)	J (in ⁴)	r _o (in)
0.937	0.511	0.387	0.297	0.514	0.00119	2.502
r _x (in) =	1.354	r _y (in) =	0.870			

Upright Frame Horizontal (UH) / Diagonal (UD) Brace Section Properties

Upright H-Shape: Horizontal Orientation (UB) - Grade Section Properties						
Mark :		C275x1063x0062				
b_w (in)	h_w (in)	t_w (in)	w_w (in)	A_g (in ²)	x_{50s} (in)	x_0 (in)
2.750	1.063	0.062	0.438	0.325	0.352	0.834
I_x (in ⁴)	S_x (in ³)	I_y (in ⁴)	S_y (in ³)	C_w (in ⁶)	J (in ⁴)	r_0 (in)
0.360	0.262	0.050	0.070	0.093	0.00042	1.399
r_x (in) =	1.053	r_y (in) =	0.391			

Upright Frame Shelf Beam Section Properties

Mark : B410x250x0066			
d (in)	b (in)	c_h (in)	c_w (in)
4.100	2.500	1.625	0.875
t (in)	I_x (in ⁴)	S_x (in ³)	r_x (in)
0.066	1.716	0.792	1.441
A_g (in ²)	I_y (in ⁴)	S_y (in ³)	r_y (in)
0.827	0.761	0.557	0.960
x_{bar} (in) =	1.133	y_{bar} (in) =	1.932

Storage Rack - Seismic Design

Rack D

24-120 075A

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Upright Post Base Plate Design:

Check for Axial Compression, P_{max} :

Base Plate Type = BP-1
Base Plate Depth = 5.00 in
Base Plate Width = 3.75 in
Default Plate Thickness = 0.2500 in
Base Plate Area, A_{BP} = 18.75 in²
Upright Width, b_c = 3.000 in
Upright Depth, h_c = 2.250 in
Upright Post Brg Area, A_{Post} = 6.75 in²
 A_{reqd} / A_{Post} = 0.294 < 1.0 O.K.
 P_{max} (per RISA) = 4853.816 lbs
 T_{max} (per RISA) = 1104.443 lbs
Design Bearing Pressure, f_p = 258.87 psi
Required Bearing Area, $A_{reqd} = P_{max} / (0.7f_c)$ = 1.9811 in²

Upright Frame Steel Material:

ASTM A570, Grade 55
 F_y = 55,000 psi
 F_u = 70,000 psi
 E = 29,000 ksi

----- Base Plate Size and Thickness is acceptable for Axial Compression

Check for Axial Tension, T_{max} :

Tension force per bolt, f_t = 1104.44 lbs
Bolt CL dist to face of Post = 0.25 in
Effective Plate Width, b_{eff} = 3.75 in

Min. Thickness required, t_{pl} = 0.08190 in ----- Base Plate Thickness is Adequate

Shelf Beam End Connections (2 Lug Connector)

ASTM A570, GR. 35 (F_y = 55 ksi, F_u = 70 ksi) $\Omega_b = 1.6$

$\Omega_b = 1.67$

Beam End Connector Bending Capacity check:

$\lambda_p = 0.54 \sqrt{E/F_y} = 12.3997$
Connector PL Thickness, t = 0.1875 in
Net Lug width, b_{lug} = 0.6563 in
Min. Beam Depth, H_{bm} = 4.100 in
Net Lug Height, $b_{lug,h}$ = 0.875 in
Uniform beam load, w = 64.7 lb/ft ----- (1/2 Max. Shelf Load) / (Rack Trib width)

$\lambda_{min}, b/t = 4.6667 < \lambda_p$
 $A_{lug} = (t)(b_{lug,h}) = 0.16406$ in²
 $A_{brg,col} = (t_c)(b_{lug,h}) = 0.06563$ in²
 $d_{CL} = 4" + b_{lug,h} - b_{lug,h}/2 = 4.4375$ in

Determine max. T_A for connector lug (shear or bearing on column):

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs ----- Shear at Lug tab
 $P_a = (A_{brg,col})(2.1F_y/\Omega_b) = 4539$ lbs ----- Lug Brg on Column Wall
 $T_A = \min(V_a, P_a) = 3384$ lbs
 $M_A = (T_A)(d_{CL}) + (T_A)(b_{lug,h}/2) + M_{x,pl,all} = 19940$ in-lbs
 M_{lat} (per RISA, Joint J47) = 13817.408 in-lbs
 $M_{graviv} = (1/2)[wL^2/12] = 2070$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} = 15887$ in-lbs
 $M / M_A = 0.797 < 1.0$ O.K.

Connector Plate Bending Capacity:

$A_{0,pl} = 0.5215$ in²


$r_o = r_i + t = 0.3125$ in L_x (long leg) = 2.1875 in
 $r_i = 0.1250$ in L_y (short leg) = 0.8750 in
 $x_{bar} = 0.8907$ in $y_{bar} = 0.2121$ in
 $I_x = 0.0199$ in⁴ $S_x = I_x / y_{bar} = 0.0938$ in³
 $M_{x,pl,all} = (\text{bent about Long Leg} - (x\text{-axis})) = (1.5)(F_y)(S_x)/\Omega_b = 4632$ in-lbs (AISC Eq. F10-1)

Shear Capacity check:


$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs / lug
 V (Impact) = 258.75 lbs - 25% Max. Shelf Load at beam end (RMI section 2.3)
 V (per RISA, member SB42) = 956.634 lbs - total beam end shear
 $V / V_A = 0.180 < 1.0$ O.K.

Beam to Connector Weld check:

Shelf Beam Wall thickness, t_{beam} = 0.075 in
Shelf Beam Depth, $H_{bm} = H_{weld} = 4.100$ in
Top Beam Flange width, $B_{weld} = 1.625$ in
Beam Haunch depth, $Y_{weld} = 1.500$ in
Corner offset distance, $d_{corner} = 0.200$ in
Vertical Weld length, $L_1 = 3.700$ in
Top Weld length, $L_2 = 1.225$ in
Vertical Weld length, $L_3 = 1.175$ in
Total Length of Weld, $L_w = 6.100$ in
Distance to Y-axis Centroid, = 0.47618 in
Distance to X-axis Centroid, = 2.70487 in
Moment Inertia of Weld - X-axis, $I_{x,weld} = 0.71829$ in⁴
Moment Inertia of Weld - Y-axis, $I_{y,weld} = 0.23701$ in⁴
Polar Moment of Inertia, $I_p = I_x + I_y = 0.95530$ in⁴
 $F_{w,all} = [(0.6)F_{exx}/\Omega_{weld}](1+0.5\sin^{1.5}(\theta)) = 31500$ psi
 $M_{all} = (F_{w,all})(I_p)/c = 12013$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} = 15887$ in-lbs
 $M / M_{all} = 1.322$ N.G.
Interior Bend Radius = 0.125 in
Fillet Weld leg width = 0.125 in
Weld throat width, $w_w = 0.08839$ in
 $\Omega_{weld} = 2.00$
 $F_{exx} = 70$ ksi
2.73 in ----- distance to bottom of L_3



Beam End Section at 2 Lug Connector



Storage Rack - Seismic Design


Rack T 36

36-60 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor (I_p) =	1.5	<--- Public Access Allowed (Typ. at Sales Floor / Garden Center Areas)
Supported on Elevated Floor (Y/N):	No	
Max. Weight per level (2 Pallets / shelf) =	600 lbs/shelf	
Weight of Unit =	250 lbs	<--- Shipping weight per Manuf.
Rack Trib width (CL-to-CL of frames) =	96 in	Total Shelf Load
h_9 =	0 in	0 lbs
h_8 =	0 in	0 lbs
h_7 =	0 in	0 lbs
h_6 =	0 in	0 lbs
h_5 =	0 in	0 lbs
h_4 =	0 in	0 lbs
h_3 =	26 in	600 lbs
h_2 =	26 in	600 lbs
h_1 =	8 in	600 lbs
Total Shelf Height, H_t =	60 in	
Unit Height, H_u =	60 in	
Unit Base Depth, D =	36 in	

Note: Per ANSI MH16.1, Section 6.3, effective lengths may be determined by rational methods consistent with AISI or AISC. AISC Design by Second-Order Analysis, Section C2.2a is used. Notional loads are applied to gravity load cases and $K=1.0$ is used since the ratio of second-order drift to first-order drift ($P-\delta$) / ($P-\Delta$) < 1.1.



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1 [RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[RMI sect 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Braced)
0.108 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 1058.0$ lbs
Base Shear, $V = C_s I_p W_s = 333.7$ lbs (Braced)
114.6 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)
 $F_9 = 0.0$ lbs @ 0 in (CM)
 $F_8 = 0.0$ lbs @ 0 in (CM)
 $F_7 = 0.0$ lbs @ 0 in (CM)
 $F_6 = 0.0$ lbs @ 0 in (CM)
 $F_5 = 0.0$ lbs @ 0 in (CM)
 $F_4 = 0.0$ lbs @ 0 in (CM)
 $F_3 = 112.1$ lbs @ 80 in (CM)
 $F_2 = 65.9$ lbs @ 47 in (CM)
 $F_1 = 29.4$ lbs @ 21 in (CM)
 $F_u = 26.1$ lbs @ 30 in (CM)

Note:
(CM) = Product Center of Mass typically 20 inches above the top of shelf at each level.

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$

$M_{OT} = 13468$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 26208$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.946$

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2 [RMI sect. 2.6.8(2), $PL=1.0(PL)$]

[RMI 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Braced)
0.108 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 652.0$ lbs
Base Shear, $V = C_s I_p W_s = 205.6$ lbs (Braced)
70.6 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads) $F_9 = 0.0$ lbs
 $F_8 = 0.0$ lbs
 $F_7 = 0.0$ lbs
 $F_6 = 0.0$ lbs
 $F_5 = 0.0$ lbs
 $F_4 = 0.0$ lbs
 $F_3 = 124.5$ lbs @ 80 in (CM)
 $F_2 = 0.0$ lbs
 $F_1 = 0.0$ lbs
 $F_u = 19.5$ lbs @ 30 in (CM)

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$


$M_{OT} = 10542$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 15300$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.451$

NO UPLIFT - ANCHORS REQUIRED



Anchor Design (using "Cracked Concrete" Properties)

Upright Post Type = UB

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment (h_{nom}) = 2.5 in

$f_c = 3500$ psi

$e_{a1} = 3.3125$ in <-- Eccen. of Anchor

$h_{ef} = 2$ in 1.5(h_{ef}) = 3.000 in

Conc. thickness, $t = 4$ in 1.5(C_a) = 5.250 in

of Anchors, $n = 1$

$S_x = 0.00$ in

$S_y = 0.00$ in

$A_{se} = 0.051$ in²

Base Reactions:

	LC #1	LC #2
R_n =	117 lbs	72 lbs
R_v =	0 lbs	0 lbs
Overturning FOS =	1.946	1.451 < 1.5 Abs Reqd
Sliding Restraint, R_{RST}/FOS =	226 lbs / 1.933 >= 1.5 OK	155 lbs / 2.15 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	334 lbs	206 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	1885 lbs	1101 lbs

Tension Allowables

Steel Strength, ϕN_{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1b
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<--ACI 318-14 Eq 17.4.3.1
Factored Tension Load, (N_u) =	0 lbs	(LC #1)
max tension stress ratio (TSR) =	0.000	OK (LC#1) 0.000 OK (LC#2)

Shear Allowables

Steel Strength, ϕV_{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout (Y_g), ϕV_{cbg} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete breakout (X_g), ϕV_{cbg} =	759 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpa} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b
Factored Shear Load (V_u):	Braced = 334 lbs	206 lbs
	Down Aisle = 115 lbs	71 lbs
Max shear stress ratio (VSR):	Braced = 0.270	OK 0.166 OK
	Down Aisle = 0.151	OK 0.093 OK
Braced (TSR+VSR <= 1.2) =	0.270	<= 1.2 OK - LC #1 Controls
Down Aisle (VSR <= 1.0) =	0.151	OK - LC #1 Controls

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Storage Rack - Seismic Design

Rack T 36


36-60 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	1885 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	3.00 in.
Rack Post Y-Y =	4.75 in.
b_o =	31.50 in.
β =	1.58
V_n =	22494 lbs Eq. (22-10)
V_n max =	19828 lbs Eq. (22-10)
ϕV_n =	11897 lbs
$V_u / \phi V_n$ =	0.158 < 1.0 O.K.



Max Vertical Load (ASD) - RMI, sect 2.1 - LC#4:

$$P = (1+0.11S_d)DL + (3/4)[(1+0.14S_d)PL + (0.7)EL]$$

S_{DS} =	0.841 ($I_p=1.5$)
DL = (Frame Wt/2) =	125 lbs
PL = Σ (Shelf Load $h_1 - h_2$)/2 =	900 lbs
EL = $M_{OT, LCH1} / ((0.7)(D))$ =	798 lbs
P =	1172 lbs <-- At Each Post

Max Vertical Load (LRFD) - RMI, sect 2.2 - LC#5:


$$P = (1.2+0.2S_d)DL + (0.85+0.2S_d)PL + EL$$

P_u =	1885 lbs <-- At Each Post
---------	---------------------------

Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Service Vertical Load (P) =	1172 lbs
Area reqd. for bearing (A_{reqd}) =	0.78 ft ²
"b" distance =	10.61 in
Slab thickness (t) =	4.00 in
$S = (1'')(t)^2/6 =$	2.67 in ³ /in
ϕM_{rt} (tension allowable) = $f_t^* 7.5 * [(f'_c)^{1/2}] * S =$	709.93 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd} =$	16.75 lb/in/in
$M_u = wL^2/3 = (w_u)[(b-\min(X-X, Y-Y))/2]^2 / 3 =$	80.79 in-lb/in - Defl. End M1 = 41 in-lb/in
$M_u / \phi M_{rt} =$	0.114 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Rack FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	36 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 * \text{SQRT}(f'_c) =$	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6 =$	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S * f_r / 1.5 =$	788.8 ft*lbs/ft
Effective Cantilever Span Length (l_c) at $M_{all} =$	5.6 ft
Total Length of Slab (l_c + Width of Single Rack) =	8.6 ft
Trib. Width of Slab = Trib width of Rack =	8.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	3446.9 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} * l_c/2 =$	178213 in*lbs
Load Combination #1: $M_{OT} =$	13468 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	204421 in*lbs
Total Overturning FOS =	15.178 OK
Load Combination #2: $M_{OT} =$	10542 in*lbs
$M_{RST(Rack)} + M_{RST(slab)} =$	193513 in*lbs
Total Overturning FOS =	18.356 OK



Upright Frame Member/Connection Design:



Upright Frame Geometry

Height, H (in)	Width, B (in)	Panel - D1, in	Panel - D2, in	Panel - D3, in	Frame Post Type	Base PL Type	Frame Type
60	36	40	0	0	UB	BP-2	Typical

Upright Column (UC) Section Properties

Mark : UCA300x225x0075						
b _c (in)	h _c (in)	t _c (in)	w _c (in)	A _g (in ²)	A _w (in ²)	x _{bar} (in)
3.000	2.250	0.075	0.500	0.637	0.511	0.946
I _x (in ⁴)	S _x (in ³)	I _y (in ⁴)	S _y (in ³)	C _w (in ⁶)	J (in ⁴)	r _o (in)
0.937	0.511	0.387	0.297	0.514	0.00119	2.502
r _x (in) =	1.354	r _y (in) =	0.870			

Upright Frame Horizontal (UH) / Diagonal (UD) Brace Section Properties

Mark : C275x1063x0062						
b_w (in)	h_w (in)	t_w (in)	w_w (in)	A_g (in ²)	x_{cw} (in)	x_0 (in)
2.750	1.063	0.062	0.438	0.325	0.352	0.834
I_x (in ⁴)	S_x (in ³)	I_y (in ⁴)	S_y (in ³)	C_w (in ⁶)	J (in ⁴)	r_o (in)
0.360	0.262	0.050	0.070	0.093	0.00042	1.399
r_x (in) =	1.053	r_y (in) =	0.391			

Upright Frame Shelf Beam Section Properties

Mark :		B410x250x0066	
d (in)	b (in)	c_h (in)	c_w (in)
4.100	2.500	1.625	0.875
t (in)	I_x (in ⁴)	S_x (in ³)	r_x (in)
0.066	1.716	0.792	1.441
A_g (in ²)	I_y (in ⁴)	S_y (in ³)	r_y (in)
0.827	0.761	0.557	0.960
x_{bar} (in) =	1.133	y_{bar} (in) =	1.932

Storage Rack - Seismic Design

Rack T 36

36-60 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Upright Post Base Plate Design:

Check for Axial Compression, P_{max} :

Base Plate Type = BP-2
Base Plate Depth = 3.00 in
Base Plate Width = 4.75 in
Default Plate Thickness = 0.1250 in
Base Plate Area, A_{BP} = 14.25 in²
Upright Width, b_c = 3.000 in
Upright Depth, h_c = 2.250 in
Upright Post Brg Area, A_{Post} = 6.75 in²
 A_{reqd} / A_{Post} = 0.396 < 1.0 O.K.
 P_{max} (per RISA) = 6554 lbs
 T_{max} (per RISA) = 2021 lbs
Design Bearing Pressure, f_p = 459.93 psi
Required Bearing Area, $A_{reqd} = P_{max} / (0.7f_c)$ = 2.6751 in²

Upright Frame Steel Material:

ASTM A570, Grade 55
 F_y = 55,000 psi
 F_u = 70,000 psi
 E = 29,000 ksi

----- Base Plate Size and Thickness is acceptable for Axial Compression

Check for Axial Tension, T_{max} :

Tension force per bolt, f_t = 2021.00 lbs
Bolt CL dist to face of Post = 0.63 in
Effective Plate Width, b_{eff} = 3.75 in

Min. Thickness required, t_{pl} = 0.17516 in <--- No Good - Increase Thickness

Shelf Beam End Connections (2 Lug Connector)

ASTM A570, GR. 35 (F_y = 55 ksi, F_u = 70 ksi) $\Omega_c = 1.6$

$\Omega_b = 1.67$

Beam End Connector Bending Capacity check:

$\lambda_p = 0.54 \sqrt{E/F_y} = 12.3997$
Connector PL Thickness, t = 0.1875 in
Net Lug width, b_{lug} = 0.6563 in
Min. Beam Depth, H_{bm} = 4.100 in
Net Lug Height, $b_{lug,h}$ = 0.875 in
Uniform beam load, w = 37.5 lb/ft <--- (1/2 Max. Shelf Load) / (Rack Trib width)

$\lambda_{min}, b/t = 4.6667 < \lambda_p$
 $A_{lug} = (t)(b_{lug,h}) = 0.16406$ in²
 $A_{brg,col} = (t_c)(b_{lug,h}) = 0.06563$ in²
 $d_{CL} = 4" + b_{lug,h} - b_{lug,h}/2 = 4.4375$ in

Determine max. T_A for connector lug (shear or bearing on column):

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs <--- Shear at Lug tab
 $P_a = (A_{brg,col})(2.1F_y)/\Omega_b = 4539$ lbs <--- Lug Brg on Column Wall
 $T_A = \min(V_a, P_a) = 3384$ lbs
 $M_A = (T_A)(d_{CL}) + (T_A)(b_{lug,h}/2) + M_{x,pl,all} = 19940$ in-lbs
 M_{lat} (per RISA, Joint J47) = 1800 in-lbs
 $M_{graviv} = (1/2)[wL^2/12] = 1200$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} = 3000$ in-lbs
 $M / M_A = 0.150 < 1.0$ O.K.

Connector Plate Bending Capacity:

$A_{0,pl} = 0.5215$ in²



$r_o = r_i + t = 0.3125$ in L_x (long leg) = 2.1875 in
 $r_i = 0.1250$ in L_y (short leg) = 0.8750 in
 $x_{bar} = 0.8907$ in $y_{bar} = 0.2121$ in
 $I_x = 0.0199$ in⁴ $S_x = I_x / y_{bar} = 0.0938$ in³
 $M_{x,pl,all} = (\text{bent about Long Leg} - (x\text{-axis})) = (1.5)(F_y)(S_x)/\Omega_b = 4632$ in-lbs (AISC Eq. F10-1)

Shear Capacity check:

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs / lug
 V (Impact) = 150 lbs - 25% Max. Shelf Load at beam end (RMI section 2.3)
 V (per RISA, member SB42) = 587 lbs - total beam end shear
 $V / V_A = 0.109 < 1.0$ O.K.

Beam to Connector Weld check:

Shelf Beam Wall thickness, t_{beam} = 0.075 in
Shelf Beam Depth, $H_{bm} = H_{weld} = 4.100$ in
Top Beam Flange width, $B_{weld} = 1.625$ in
Beam Haunch depth, $Y_{weld} = 1.500$ in
Corner offset distance, $d_{corner} = 0.200$ in
Vertical Weld length, $L_1 = 3.700$ in
Top Weld length, $L_2 = 1.225$ in
Vertical Weld length, $L_3 = 1.175$ in
Total Length of Weld, $L_w = 6.100$ in
Distance to Y-axis Centroid, = 0.47618 in
Distance to X-axis Centroid, = 2.70487 in
Moment Inertia of Weld - X-axis, $I_{x,weld} = 0.71829$ in⁴
Moment Inertia of Weld - Y-axis, $I_{y,weld} = 0.23701$ in⁴
Polar Moment of Inertia, $I_p = I_x + I_y = 0.95530$ in⁴
 $F_{w,all} = [(0.6)F_{exx}/\Omega_{weld}](1+0.5\sin^{1.5}(\theta)) = 31500$ psi
 $M_{all} = (F_{w,all})(I_p)/c = 12013$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} = 3000$ in-lbs
 $M / M_{all} = 0.250 < 1.0$ O.K.
Interior Bend Radius = 0.125 in
Fillet Weld leg width = 0.125 in
Weld throat width, $w_w = 0.08839$ in
 $\Omega_{weld} = 2.00$
 $F_{exx} = 70$ ksi
2.73 in <--- distance to bottom of L_3



Storage Rack - Seismic Design


Rack W-int

48-84 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor (I_p) =	1.5	<--- Public Access Allowed (Typ. at Sales Floor / Garden Center Areas)
Supported on Elevated Floor (Y/N):	No	
Max. Weight per level (2 Pallets / shelf) =	1200 lbs/shelf	
Weight of Unit =	150 lbs	<--- Shipping weight per Manuf.
Rack Trib width (CL-to-CL of frames) =	96 in	Total Shelf Load
h_9 =	0 in	0 lbs
h_8 =	0 in	0 lbs
h_7 =	0 in	0 lbs
h_6 =	0 in	0 lbs
h_5 =	0 in	0 lbs
h_4 =	0 in	0 lbs
h_3 =	36 in	1200 lbs
h_2 =	36 in	1200 lbs
h_1 =	12 in	1200 lbs
Total Shelf Height, H_t =	84 in	
Unit Height, H_u =	84 in	
Unit Base Depth, D =	48 in	

Note: Per ANSI MH16.1, Section 6.3, effective lengths may be determined by rational methods consistent with AISI or AISC. AISC Design by Second-Order Analysis, Section C2.2a is used. Notional loads are applied to gravity load cases and $K=1.0$ is used since the ratio of second-order drift to first-order drift ($P-\delta$) / ($P-\Delta$) < 1.1.



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1 [RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[RMI sect 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Braced)
0.108 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL = 1766.0$ lbs
Base Shear, $V = C_s I_p W_s = 557.0$ lbs (Braced)
191.2 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)
 $F_9 = 0.0$ lbs @ 0 in (CM)
 $F_8 = 0.0$ lbs @ 0 in (CM)
 $F_7 = 0.0$ lbs @ 0 in (CM)
 $F_6 = 0.0$ lbs @ 0 in (CM)
 $F_5 = 0.0$ lbs @ 0 in (CM)
 $F_4 = 0.0$ lbs @ 0 in (CM)
 $F_3 = 195.1$ lbs @ 104 in (CM)
 $F_2 = 123.8$ lbs @ 66 in (CM)
 $F_1 = 56.3$ lbs @ 30 in (CM)
 $F_u = 14.7$ lbs @ 42 in (CM)

Note:
(CM) = Product Center of Mass typically 20 inches above the top of shelf at each level.

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$

$M_{OT} = 30767$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 61488$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.999$

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2 [RMI sect. 2.6.8(2), $PL=1.0(PL)$]

[RMI 2.6.2, $PL_{RF}=1.0$]

Seismic (C_s)(I_p) = 0.315 W_s (Braced)
0.108 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL = 954.0$ lbs
Base Shear, $V = C_s I_p W_s = 300.9$ lbs (Braced)
103.3 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads) $F_9 = 0.0$ lbs
 $F_8 = 0.0$ lbs
 $F_7 = 0.0$ lbs
 $F_6 = 0.0$ lbs
 $F_5 = 0.0$ lbs
 $F_4 = 0.0$ lbs
 $F_3 = 200.5$ lbs @ 104 in (CM)
 $F_2 = 0.0$ lbs
 $F_1 = 0.0$ lbs
 $F_u = 10.1$ lbs @ 42 in (CM)

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$


$M_{OT} = 21276$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 32400$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.523$

NO UPLIFT - NO ANCHORS REQUIRED



Anchor Design (using "Cracked Concrete" Properties)

Upright Post Type = UB

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment (h_{nom}) = 2.5 in

$f_c = 3500$ psi

$e_{a'} = 3.3125$ in <-- Eccen. of Anchor

$h_{ef} = 2$ in 1.5(h_{ef}) = 3.000 in

Conc. thickness, $t = 4$ in 1.5(C_a) = 5.250 in

of Anchors, $n = 1$

$S_x = 0.00$ in

$S_y = 0.00$ in

$A_{se} = 0.051$ in²

Base Reactions:

	LC #1	LC #2
R_n =	195 lbs	105 lbs
R_v =	0 lbs	0 lbs
Overturning FOS =	1.999	1.523
Sliding Restraint, R_{RST}/FOS =	381lbs / 1.954 >= 1.5 OK	230lbs / 2.185 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	557 lbs	301 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	3302 lbs	1659 lbs

Tension Allowables

Steel Strength, ϕN_{sa} =	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg}$ =	1713 lbs	<--ACI 318-14 Eq 17.4.2.1b
Pullout Strength, $(0.75)\phi N_{pn}$ =	NA	<--ACI 318-14 Eq 17.4.3.1
Factored Tension Load, (N_u) =	0 lbs	0 lbs (LC #2)
max tension stress ratio (TSR) =	0.000	OK (LC#1) 0.000 OK (LC#2)

Shear Allowables

Steel Strength, ϕV_{sa} =	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout (Y_g), ϕV_{cbg} =	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete breakout (X_g), ϕV_{cbg} =	759 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, ϕV_{cpa} =	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b
Factored Shear Load (V_u) :	Braced = 557 lbs	301 lbs
	Down Aisle = 191 lbs	103 lbs
Max shear stress ratio (VSR) :	Braced = 0.450	OK 0.243 OK
	Down Aisle = 0.252	OK 0.136 OK
Braced (TSR+VSR <= 1.2) =	0.450	<= 1.2 OK - LC #1 Controls
Down Aisle (VSR <= 1.0) =	0.252	OK - LC #1 Controls

USE: NO UPLIFT - NO ANCHORS REQUIRED

Storage Rack - Seismic Design

Rack W-int


48-84 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	3302 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-X =	3.00 in.
Rack Post Y-Y =	4.75 in.
b_o =	31.50 in.
β =	1.58
V_n =	22494 lbs Eq. (22-10)
V_n max =	19828 lbs Eq. (22-10)
ϕV_n =	11897 lbs
$V_u / \phi V_n$ =	0.278 < 1.0 O.K.



Max Vertical Load (ASD) - RMI, sect 2.1 - LC#4:

$$P = (1+0.11S_d)DL + (3/4)[(1+0.14S_d)PL + (0.7)EL]$$

S_{DS} =	0.841 ($I_p=1.5$)
DL = (Frame Wt/2) =	75 lbs
PL = Σ (Shelf Load $h_1 - h_2$)/2 =	1800 lbs
EL = $M_{OT, LCH1} / ((0.7)(D))$ =	1367 lbs
P =	2072 lbs <-- At Each Post

Max Vertical Load (LRFD) - RMI, sect 2.2 - LC#5:


$$P = (1.2+0.2S_d)DL + (0.85+0.2S_d)PL + EL$$

P_u =	3302 lbs <-- At Each Post
---------	---------------------------

Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Service Vertical Load (P) =	2072 lbs
Area reqd. for bearing (A_{reqd}) =	1.38 ft ²
"b" distance =	14.10 in
Slab thickness (t) =	4.00 in
$S = (1^3)(t)^2/6$ =	2.67 in ³ /in
ϕM_{rt} (tension allowable) = $f_t^* 7.5 * [(f'_c)^{1/2}] * S$ =	709.93 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	16.60 lb/in/in
$M_u = wL^2/3 = (w_u)[(b-\min(X-X, Y-Y))/2]^3 / 3$ =	170.55 in-lb/in - Defl. End M1 = 86 in-lb/in
$M_u / \phi M_{rt}$ =	0.240 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Rack FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	48 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 * \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S * f_r / 1.5$ =	788.8 ft*lbs/ft
Effective Cantilever Span Length (l_c) at M_{all} =	5.6 ft
Total Length of Slab (l_c + Width of Single Rack) =	9.6 ft
Trib. Width of Slab = Trib width of Rack =	8.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	3846.9 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} * l_c/2$ =	221975 in*lbs
Load Combination #1: M_{OT} =	30767 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	283463 in*lbs
Total Overturning FOS =	9.213 OK
Load Combination #2: M_{OT} =	21276 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	254375 in*lbs
Total Overturning FOS =	11.956 OK



Upright Frame Member/Connection Design:



Upright Frame Geometry

Height, H (in)	Width, B (in)	Panel - D ₁ , in	Panel - D ₂ , in	Panel - D ₃ , in	Frame Post Type	Base PL Type	Frame Type
84	48	40	28	0	UB	BP-2	Typical

Upright Column (UC) Section Properties

Mark :		UCA300x225x0075				
b _c (in)	h _c (in)	t _c (in)	w _c (in)	A _g (in ²)	A _g (in ²)	x _{bar} (in)
3.000	2.250	0.075	0.500	0.637	0.511	0.946
I _x (in ⁴)	S _x (in ³)	I _y (in ⁴)	S _y (in ³)	C _w (in ⁶)	J (in ⁴)	r _o (in)
0.937	0.511	0.387	0.297	0.514	0.00119	2.502
r _x (in) =	1.354	r _y (in) =	0.870			

Upright Frame Horizontal (UH) / Diagonal (UD) Brace Section Properties

Upright H-Shape: Horizontal Orientation (UB) - Grade Section Properties						
Mark :		C275x1063x0062				
b_w (in)	h_w (in)	t_w (in)	w_w (in)	A_g (in ²)	x_{50s} (in)	x_0 (in)
2.750	1.063	0.062	0.438	0.325	0.352	0.834
I_x (in ⁴)	S_x (in ³)	I_y (in ⁴)	S_y (in ³)	C_w (in ⁶)	J (in ⁴)	r_o (in)
0.360	0.262	0.050	0.070	0.093	0.00042	1.399
r_x (in) =	1.053	r_y (in) =	0.391			

Upright Frame Shelf Beam Section Properties

Mark : B410x250x0066			
d (in)	b (in)	c_h (in)	c_w (in)
4.100	2.500	1.625	0.875
t (in)	I_x (in ⁴)	S_x (in ³)	r_x (in)
0.066	1.716	0.792	1.441
A_g (in ²)	I_y (in ⁴)	S_y (in ³)	r_y (in)
0.827	0.761	0.557	0.960
x_{bar} (in) =	1.133	y_{bar} (in) =	1.932

Storage Rack - Seismic Design **Rack W-int** **48-84 075B**
IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Upright Post Base Plate Design:

Check for Axial Compression, P_{max} :

Base Plate Type = BP-2
Base Plate Depth = 3.00 in
Base Plate Width = 4.75 in
Default Plate Thickness = 0.1250 in
Base Plate Area, A_{BP} = 14.25 in²
Upright Width, b_c = 3.000 in
Upright Depth, h_c = 2.250 in
Upright Post Brg Area, A_{Post} = 6.75 in²
 A_{reqd} / A_{Post} = 0.396 < 1.0 O.K.
 P_{max} (per RISA) = 6554 lbs
 T_{max} (per RISA) = 2021 lbs
Design Bearing Pressure, f_p = 459.93 psi
Required Bearing Area, $A_{reqd} = P_{max} / (0.7f_c)$ = 2.6751 in²

Upright Frame Steel Material:

ASTM A570, Grade 55
 F_y = 55,000 psi
 F_u = 70,000 psi
 E = 29,000 ksi

Base Plate Size and Thickness is acceptable for Axial Compression

Check for Axial Tension, T_{max} :

Tension force per bolt, f_t = 2021.00 lbs
Bolt CL dist to face of Post = 0.63 in
Effective Plate Width, b_{eff} = 3.75 in

Min. Thickness required, t_{pl} = 0.17516 in <--- No Good - Increase Thickness

Shelf Beam End Connections (2 Lug Connector)

ASTM A570, GR. 35 (F_y = 55 ksi, F_u = 70 ksi) $\Omega_c = 1.6$

$\Omega_b = 1.67$

Beam End Connector Bending Capacity check:

$\lambda_p = 0.54 \sqrt{E/F_y} = 12.3997$
Connector PL Thickness, t = 0.1875 in
Net Lug width, b_{lug} = 0.6563 in
Min. Beam Depth, H_{bm} = 4.100 in
Net Lug Height, $b_{lug,h}$ = 0.875 in
Uniform beam load, w = 75.0 lb/ft <--- (1/2 Max. Shelf Load) / (Rack Trib width)

$\lambda_{min}, b/t = 4.6667 < \lambda_p$
 $A_{lug} = (t)(b_{lug,h}) = 0.16406$ in²
 $A_{brg,col} = (t_c)(b_{lug,h}) = 0.06563$ in²
 $d_{CL} = 4" + b_{lug,h} - b_{lug,h}/2 = 4.4375$ in

Determine max. T_A for connector lug (shear or bearing on column):

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs <--- Shear at Lug tab
 $P_a = (A_{brg,col})(2.1F_y)/\Omega_b = 4539$ lbs <--- Lug Brg on Column Wall
 $T_A = \min(V_a, P_a) = 3384$ lbs
 $M_A = (T_A)(d_{CL}) + (T_A)(b_{lug,h}/2) + M_{x,pl,all} = 19940$ in-lbs
 M_{lat} (per RISA, Joint J47) = 1800 in-lbs
 $M_{graviv} = (1/2)[wL^2/12] = 2400$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} = 4200$ in-lbs
 $M / M_A = 0.211 < 1.0$ O.K.

Connector Plate Bending Capacity:


$A_{0,pl} = 0.5215$ in²
 $r_o = r_i + t = 0.3125$ in L_x (long leg) = 2.1875 in
 $r_i = 0.1250$ in L_y (short leg) = 0.8750 in
 $x_{bar} = 0.8907$ in $y_{bar} = 0.2121$ in
 $I_x = 0.0199$ in⁴ $S_x = I_x / y_{bar} = 0.0938$ in³
 $M_{x,pl,all} = (\text{bent about Long Leg} - (x\text{-axis})) = (1.5)(F_y)(S_x)/\Omega_b = 4632$ in-lbs (AISC Eq. F10-1)

Shear Capacity check:


$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v = 3384$ lbs / lug
 V (Impact) = 300 lbs - 25% Max. Shelf Load at beam end (RMI section 2.3)
 V (per RISA, member SB42) = 587 lbs - total beam end shear
 $V / V_A = 0.131 < 1.0$ O.K.

Beam to Connector Weld check:

Shelf Beam Wall thickness, $t_{beam} = 0.075$ in
Shelf Beam Depth, $H_{bm} = H_{weld} = 4.100$ in
Top Beam Flange width, $B_{weld} = 1.625$ in
Beam Haunch depth, $Y_{weld} = 1.500$ in
Corner offset distance, $d_{corner} = 0.200$ in
Vertical Weld length, $L_1 = 3.700$ in
Top Weld length, $L_2 = 1.225$ in
Vertical Weld length, $L_3 = 1.175$ in
Total Length of Weld, $L_w = 6.100$ in
Distance to Y-axis Centroid, = 0.47618 in
Distance to X-axis Centroid, = 2.70487 in
Moment Inertia of Weld - X-axis, $I_{x,weld} = 0.71829$ in⁴
Moment Inertia of Weld - Y-axis, $I_{y,weld} = 0.23701$ in⁴
Polar Moment of Inertia, $I_p = I_x + I_y = 0.95530$ in⁴
 $F_{w,all} = [(0.6)F_{exx}/\Omega_{weld}](1+0.5\sin^{1.5}(\theta)) = 31500$ psi
 $M_{all} = (F_{w,all})(I_p)/c = 12013$ in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} = 4200$ in-lbs
 $M / M_{all} = 0.350 < 1.0$ O.K.
Interior Bend Radius = 0.125 in
Fillet Weld leg width = 0.125 in
Weld throat width, $w_w = 0.08839$ in
 $\Omega_{weld} = 2.00$
 $F_{exx} = 70$ ksi
2.73 in <--- distance to bottom of L_3



Beam End Section at 2 Lug Connector



Storage Rack - Seismic Design


Rack W-int 44

44-84 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Seismic Importance Factor (I_p) =	1.5	<--- Public Access Allowed (Typ. at Sales
Supported on Elevated Floor (Y/N):	No	Floor / Garden Center Areas)
Max. Weight per level (2 Pallets / shelf) =	1200 lbs/shelf	
Weight of Unit =	150 lbs	<--- Shipping weight per Manuf.
Rack Trib width (CL-to-CL of frames) =	96 in	Total Shelf Load
h_9 =	0 in	0 lbs
h_8 =	0 in	0 lbs
h_7 =	0 in	0 lbs
h_6 =	0 in	0 lbs
h_5 =	0 in	0 lbs
h_4 =	0 in	0 lbs
h_3 =	36 in	1200 lbs
h_2 =	36 in	1200 lbs
h_1 =	12 in	1200 lbs
Total Shelf Height, H_t =	84 in	
Unit Height, H_u =	84 in	
Unit Base Depth, D =	44 in	

Note: Per ANSI MH16.1, Section 6.3, effective lengths may be determined by rational methods consistent with AISI or AISC. AISC Design by Second-Order Analysis, Section C2.2a is used. Notional loads are applied to gravity load cases and $K=1.0$ is used since the ratio of second-order drift to first-order drift $(P-\delta) / (P-\Delta) < 1.1$.



Overturning Stability (Load cases are per ASCE 7 sect. 15.5.3.6):

Load Case 1 [RMI sect. 2.6.8(1) - $PL=0.67(PL)$]

[RMI sect 2.6.2, $PL_{RF}=1.0$]

Seismic $(C_s)(I_p) =$
0.315 W_s (Braced)
0.108 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((0.67)PL) + DL =$ 1766.0 lbs
Base Shear, $V = C_s I_p W_s =$ 557.0 lbs (Braced)
191.2 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads, $E = 0.7$)
 $F_9 = 0.0$ lbs @ 0 in (CM)
 $F_8 = 0.0$ lbs @ 0 in (CM)
 $F_7 = 0.0$ lbs @ 0 in (CM)
 $F_6 = 0.0$ lbs @ 0 in (CM)
 $F_5 = 0.0$ lbs @ 0 in (CM)
 $F_4 = 0.0$ lbs @ 0 in (CM)
 $F_3 = 195.1$ lbs @ 104 in (CM)
 $F_2 = 123.8$ lbs @ 66 in (CM)
 $F_1 = 56.3$ lbs @ 30 in (CM)
 $F_u = 14.7$ lbs @ 42 in (CM)

Note:
(CM) = Product Center of
Mass typically 20 inches
above the top of shelf at
each level.

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$

$M_{OT} = 30767$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 56364$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.832$

NO UPLIFT - NO ANCHORS REQUIRED

Load Case 2 [RMI sect. 2.6.8(2), $PL=1.0(PL)$]

[RMI 2.6.2, $PL_{RF}=1.0$]

Seismic $(C_s)(I_p) =$
0.315 W_s (Braced)
0.108 W_s (Down Aisle)

$W_s = (0.67)(PL_{RF})((1)PL) + DL =$ 954.0 lbs
Base Shear, $V = C_s I_p W_s =$ 300.9 lbs (Braced)
103.3 lbs (Down Aisle)

Horizontal forces / level, $F_x = C_{vx} V$ (RMI sect 2.6.6)

(Service Loads) $F_9 = 0.0$ lbs
 $F_8 = 0.0$ lbs
 $F_7 = 0.0$ lbs
 $F_6 = 0.0$ lbs
 $F_5 = 0.0$ lbs
 $F_4 = 0.0$ lbs
 $F_3 = 200.5$ lbs @ 104 in (CM)
 $F_2 = 0.0$ lbs
 $F_1 = 0.0$ lbs
 $F_u = 10.1$ lbs @ 42 in (CM)

Calculate Overturning Moment (Service), $M_{OT} = \sum F_i h_i$


$M_{OT} = 21276$ in-lbs

Calculate Resisting Moment (Service), M_{RST}

$M_{RST} = 29700$ in-lbs

Factor of Safety, $FOS_{OT} = M_{RST}/M_{OT} = 1.396$

NO UPLIFT - ANCHORS REQUIRED



Anchor Design (using "Cracked Concrete" Properties)

Upright Post Type = UB

Try: 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed.

Embedment (h_{nom}) = 2.5 in

$f_c =$ 3500 psi

$e_n =$ 3.3125 in <-- Eccen. of Anchor

$h_{ef} =$ 2 in 1.5(h_{ef}) = 3.000 in

Conc. thickness, $t =$ 4 in 1.5(C_a) = 5.250 in

of Anchors, $n =$ 1

$S_x =$ 0.00 in

$S_y =$ 0.00 in

$A_{se} =$ 0.051 in²

Base Reactions:

	LC #1	LC #2
R_n =	195 lbs	105 lbs
R_v =	0 lbs	0 lbs
Overturning FOS =	1.832	1.396 < 1.5 Abs Req'd
Sliding Restraint, $R_{RST}/FOS =$	396 lbs / 2.029 >= 1.5 OK	240 lbs / 2.28 >= 1.5 OK
Reactions (Factored Loads):	LC #1	LC #2
Base Shear (R_{uh}) =	557 lbs	301 lbs
Net Uplift (R_{uv}) =	0 lbs	0 lbs
Overturning + Gravity (P_u) =	3426 lbs	1745 lbs

Tension Allowables

Steel Strength, $\phi N_{sa} =$	4219 lbs	<--ACI 318-14 Eq 17.4.1.2
Concrete Breakout, $(0.75)\phi N_{cbg} =$	1713 lbs	<--ACI 318-14 Eq 17.4.2.1b
Pullout Strength, $(0.75)\phi N_{pn} =$	NA	<--ACI 318-14 Eq 17.4.3.1
Factored Tension Load, (N_u) =	0 lbs	0 lbs (LC #2)
max tension stress ratio (TSR) =	0.000	OK (LC#1) 0.000 OK (LC#2)

Shear Allowables

Steel Strength, $\phi V_{sa} =$	2031 lbs	<--ACI 318-14 Eq 17.5.1.2c
Concrete breakout (Y_g), $\phi V_{cbg} =$	1238 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete breakout (X_g), $\phi V_{cbg} =$	759 lbs	<--ACI 318-14 Eq 17.5.2.1b
Concrete pryout, $\phi V_{cpa} =$	2460 lbs	<--ACI 318-14 Eq 17.5.3.1b
Factored Shear Load (V_u):	Braced = 557 lbs	301 lbs
	Down Aisle = 191 lbs	103 lbs
Max shear stress ratio (VSR):	Braced = 0.450 OK	0.243 OK
	Down Aisle = 0.252 OK	0.136 OK
Braced (TSR+VSR <= 1.2) =	0.450	<= 1.2 OK - LC #1 Controls
Down Aisle (VSR <= 1.0) =	0.252	OK - LC #1 Controls

USE: (1) 3/8" DIA Hilti Kwik Bolt-TZ2 (CS) Anchor - 2 1/2" embed. ICC REPORT #ESR-4266

Storage Rack - Seismic Design

Rack W-int 44


44-84 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Punching Shear Check:

(Design per ACI 318-14 section 14.5.5)

Max. Factored Vertical Load (P_u) =	3426 lbs
Slab Concrete f'_c =	3500 psi
Slab thickness (t) =	4 in.
Rack Post X-Y =	3.00 in.
Rack Post Y-Y =	4.75 in.
b_o =	31.50 in.
β =	1.58
V_n =	22494 lbs Eq. (22-10)
V_n max =	19828 lbs Eq. (22-10)
ϕV_n =	11897 lbs
$V_u / \phi V_n$ =	0.288 < 1.0 O.K.



Max Vertical Load (ASD) - RMI, sect 2.1 - LC#4:

$$P = (1+0.11S_d)DL + (3/4)[(1+0.14S_d)PL + (0.7)EL]$$

S_{DS} =	0.841 ($I_p=1.5$)
DL = (Frame Wt/2) =	75 lbs
PL = Σ (Shelf Load $h_1 - h_2$)/2 =	1800 lbs
EL = $M_{OT, LCH1} / ((0.7)(D))$ =	1491 lbs
P =	2115 lbs <-- At Each Post

Max Vertical Load (LRFD) - RMI, sect 2.2 - LC#5:


$$P = (1.2+0.2S_d)DL + (0.85+0.2S_d)PL + EL$$

P_u =	3426 lbs <-- At Each Post
---------	---------------------------

Slab tension based on Soil bearing area check:


Allowable soil bearing =	1500 psf
Max. Service Vertical Load (P) =	2115 lbs
Area reqd. for bearing (A_{reqd}) =	1.41 ft ²
"b" distance =	14.25 in
Slab thickness (t) =	4.00 in
$S = (1^3)(t)^2/6$ =	2.67 in ³ /in
ϕM_{nt} (tension allowable) = $f_t^* 7.5 * [(f'_c)^{1/2}] * S$ =	709.93 in-lb/in
Factored uniform bearing, $w_u = P_u / A_{reqd}$ =	16.87 lb/in/in
$M_u = wL^2/3 = (w_u)[(b-\min(X-X, Y-Y))/2]^2 / 3$ =	177.94 in-lb/in - Defl. End M1 = 89 in-lb/in
$M_u / \phi M_{nt}$ =	0.251 < 1.0 O.K.

20. BEAM FIXED AT ONE END, FREE TO DEFLECT VERTICALLY BUT NOT ROTATE AT OTHER—UNIFORMLY DISTRIBUTED LOAD




Rack FOS Overturning with Resistance from Effective Weight of Slab on Grade:

Width of Single Rack =	44 in
Slab thickness (t) =	4.0 in
Modulus of Rupture, $f_r = 7.5 * \text{SQRT}(f'_c)$ =	443.7 psi
Concrete Slab Section Modulus, $S = b(t)^2/6$ =	32.0 in ³ /ft
Allowable Concrete Slab Bending Moment, $M_{all}/FS = S * f_r / 1.5$ =	788.8 ft*lbs/ft
Effective Cantilever Span Length (l_c) at M_{all} =	5.6 ft
Total Length of Slab (l_c + Width of Single Rack) =	9.3 ft
Trib. Width of Slab = Trib width of Rack =	8.0 ft
Weight of Concrete Slab at Rack (P_{conc}) =	3713.5 lbs
Resisting Moment - Concrete Slab at Rack, $M_{RST(slab)} = P_{conc} * l_c/2$ =	206854 in*lbs
Load Combination #1: M_{OT} =	30767 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	263218 in*lbs
Total Overturning FOS =	8.555 OK
Load Combination #2: M_{OT} =	21276 in*lbs
$M_{RST(Rack)} + M_{RST(slab)}$ =	236554 in*lbs
Total Overturning FOS =	11.119 OK



Upright Frame Member/Connection Design:



Upright Frame Geometry

Height, H (in)	Width, B (in)	Panel - D ₁ , in	Panel - D ₂ , in	Panel - D ₃ , in	Frame Post Type	Base PL Type	Frame Type
84	44	40	28	0	UB	BP-2	Typical

Upright Column (UC) Section Properties

Mark :		UCA300x225x0075				
b _c (in)	h _c (in)	t _c (in)	w _c (in)	A _g (in ²)	A _g (in ²)	x _{bar} (in)
3.000	2.250	0.075	0.500	0.637	0.511	0.946
I _x (in ⁴)	S _x (in ³)	I _y (in ⁴)	S _y (in ³)	C _w (in ⁶)	J (in ⁴)	r _o (in)
0.937	0.511	0.387	0.297	0.514	0.00119	2.502
r _x (in) =	1.354	r _y (in) =	0.870			

Upright Frame Horizontal (UH) / Diagonal (UD) Brace Section Properties

Upright H-Shape: Horizontal Dimensions (in) (US) Grade Section Properties						
Mark :		C275x1063x0062				
b_w (in)	h_w (in)	t_w (in)	w_w (in)	A_g (in ²)	x_{50s} (in)	x_0 (in)
2.750	1.063	0.062	0.438	0.325	0.352	0.834
I_x (in ⁴)	S_x (in ³)	I_y (in ⁴)	S_y (in ³)	C_w (in ⁶)	J (in ⁴)	r_0 (in)
0.360	0.262	0.050	0.070	0.093	0.00042	1.399
r_x (in) =	1.053	r_y (in) =	0.391			

Upright Frame Shelf Beam Section Properties

Mark : B410x250x0066			
d (in)	b (in)	c_h (in)	c_w (in)
4.100	2.500	1.625	0.875
t (in)	I_x (in ⁴)	S_x (in ³)	r_x (in)
0.066	1.716	0.792	1.441
A_g (in ²)	I_y (in ⁴)	S_y (in ³)	r_y (in)
0.827	0.761	0.557	0.960
x_{bar} (in) =	1.133	y_{bar} (in) =	1.932

Storage Rack - Seismic Design

Rack W-int 44

44-84 075B

IBC 2021 / ASCE 7-16 / 2016 RMI (ANSI/MH16.3-16)

Upright Post Base Plate Design:

Check for Axial Compression, P_{max} :

Base Plate Type =	BP-2
Base Plate Depth =	3.00 in
Base Plate Width =	4.75 in
Default Plate Thickness =	0.1250 in
Base Plate Area, A_{BP} =	14.25 in ²
Upright Width, b_c =	3.000 in
Upright Depth, h_c =	2.250 in
Upright Post Brg Area, A_{Post} =	6.75 in ²
A_{reqd} / A_{Post} =	0.396 < 1.0 O.K.
P_{max} (per RISA) =	6554 lbs
T_{max} (per RISA) =	2021 lbs
Design Bearing Pressure, f_p =	459.93 psi
Required Bearing Area, $A_{reqd} = P_{max} / (0.7f_c)$ =	2.6751 in ²

Upright Frame Steel Material:

ASTM A570, Grade 55	
F_y =	55,000 psi
F_u =	70,000 psi
E =	29,000 ksi

----- Base Plate Size and Thickness is acceptable for Axial Compression

Check for Axial Tension, T_{max} :

Tension force per bolt, f_t =	2021.00 lbs
Bolt CL dist to face of Post =	0.63 in
Effective Plate Width, b_{eff} =	3.75 in

Min. Thickness required, t_{pl} = 0.17516 in <--- No Good - Increase Thickness

Shelf Beam End Connections (2 Lug Connector)

ASTM- A570, GR. 35 (F_y = 55 ksi, F_u = 70 ksi) $\Omega_c = 1.6$

$\Omega_b = 1.67$

Beam End Connector Bending Capacity check:

$\lambda_p = 0.54 \sqrt{E/F_y} =$	12.3997	$\lambda_{min}, b/t =$	4.6667 < λ_p
Connector PL Thickness, $t =$	0.1875 in	$A_{lug} = (t)(b_{lug,h}) =$	0.16406 in ²
Net Lug width, $b_{lug} =$	0.6563 in	$A_{brg,col} = (t_c)(b_{lug,h}) =$	0.06563 in ²
Min. Beam Depth, $H_{bm} =$	4.100 in	$d_{CL} = 4" + b_{lug,h} - b_{lug,h}/2 =$	4.4375 in
Net Lug Height, $b_{lug,h} =$	0.875 in		
Uniform beam load, $w =$	75.0 lb/ft <--- (1/2 Max. Shelf Load) / (Rack Trib width)		

Determine max. T_A for connector lug (shear or bearing on column):

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v =$	3384 lbs <--- Shear at Lug tab
$P_a = (A_{brg,col})(2.1F_u)/\Omega_b =$	4539 lbs <--- Lug Brg on Column Wall
$T_A = \min(V_a, P_a) =$	3384 lbs
$M_A = (T_A)(d_{CL}) + (T_A)(b_{lug,h}/2) + M_{x,pl,all} =$	19940 in-lbs
M_{lat} (per RISA, Joint J47) =	1800 in-lbs
$M_{graviv} = (1/2)[wL^2/12] =$	2400 in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} =$	4200 in-lbs
$M / M_A =$	0.211 < 1.0 O.K.

Connector Plate Bending Capacity:



$A_{0,pl} =$	0.5215 in ²		
$r_o = r_i + t =$	0.3125 in	L_x (long leg) =	2.1875 in
$r_i =$	0.1250 in	L_y (short leg) =	0.8750 in
$x_{bar} =$	0.8907 in	$y_{bar} =$	0.2121 in
$I_x =$	0.0199 in ⁴	$S_x = I_x / y_{bar} =$	0.0938 in ³
$M_{x,pl,all} =$ (bent about Long Leg - (x-axis)) =	$(1.5)(F_y)(S_x)/\Omega_b =$		4632 in-lbs (AISC Eq. F10-1)



Shear Capacity check:

$V_a = V_r/\Omega_v = 0.6A_{lug}F_y/\Omega_v =$	3384 lbs / lug
V (Impact) =	300 lbs - 25% Max. Shelf Load at beam end (RMI section 2.3)
V (per RISA, member SB42) =	587 lbs - total beam end shear
$V / V_A =$	0.131 < 1.0 O.K.

Beam to Connector Weld check:

Shelf Beam Wall thickness, $t_{beam} =$	0.075 in
Shelf Beam Depth, $H_{bm} = H_{weld} =$	4.100 in
Top Beam Flange width, $B_{weld} =$	1.625 in
Beam Haunch depth, $Y_{weld} =$	1.500 in
Corner offset distance, $d_{corner} =$	0.200 in
Vertical Weld length, $L_1 =$	3.700 in
Top Weld length, $L_2 =$	1.225 in
Vertical Weld length, $L_3 =$	1.175 in
Total Length of Weld, $L_w =$	6.100 in
Distance to Y-axis Centroid, =	0.47618 in
Distance to X-axis Centroid, =	2.70487 in
Moment Inertia of Weld - X-axis, $I_{x,weld} =$	0.71829 in ⁴
Moment Inertia of Weld - Y-axis, $I_{y,weld} =$	0.23701 in ⁴
Polar Moment of Inertia, $I_p = I_x + I_y =$	0.95530 in ⁴
$F_{w,all} = [(0.6)F_{exx}/\Omega_{weld}](1+0.5\sin^{1.5}(\theta)) =$	31500 psi
$M_{all} = (F_{w,all})(I_p)/c =$	12013 in-lbs
Total Connector Moment, $M = M_{lat} + M_{grav} =$	4200 in-lbs
$M / M_{all} =$	0.350 < 1.0 O.K.
Interior Bend Radius =	0.125 in
Fillet Weld leg width =	0.125 in
Weld throat width, $w_w =$	0.08839 in
$\Omega_{weld} =$	2.00
$F_{exx} =$	70 ksi
	2.73 in <--- distance to bottom of L_3





Envelope Only Solution

Johnston Burkholder Asso...
KSH
2401802403

44W x 120H - B Frame

SK - 1

Apr 17, 2024 at 2:54 PM

44W x 120H - B Frame (5000lbs (4...

Joint Coordinates and Temperatures

	Label	X [in]	Y [in]	Temp [F]
1	J1	0	0	0
2	J2	0	120	0
3	J3	44	120	0
4	J4	44	0	0
5	J5	0	8.5	0
6	J5A	0	28.5	0
7	J6	44	8.5	0
8	J6A	44	28.5	0
9	J7	0	48.5	0
10	J7A	0	68.5	0
11	J8	44	48.5	0
12	J8A	44	68.5	0
13	J9	0	88.5	0
14	J10	44	88.5	0
15	J11	0	112.5	0
16	J12	44	112.5	0
17	J15	104	120	0
18	J16	104	0	0
19	J17	200	120	0
20	J18	200	0	0
21	J19	296	120	0
22	J20	296	0	0
23	J21	105.5	120	0
24	J22	201.5	120	0
25	J23	198.5	120	0
26	J24	294.5	120	0
27	J25	104	84	0
28	J26	200	84	0
29	J26A	200	102	0
30	J27	296	84	0
31	J28	105.5	84	0
32	J29	201.5	84	0
33	J30	198.5	84	0
34	J31	294.5	84	0
35	J34	104	48	0
36	J35	200	48	0
37	J35A	200	64	0
38	J36	296	48	0
39	J37	105.5	48	0
40	J38	201.5	48	0
41	J39	198.5	48	0
42	J40	294.5	48	0
43	J43	104	12	0
44	J44	200	12	0
45	J44A	200	30	0
46	J45	296	12	0
47	J46	105.5	12	0
48	J47	201.5	12	0
49	J48	198.5	12	0
50	J49	294.5	12	0
51	J9A	0	100.5	0
52	J10A	44	100.5	0

Joint Boundary Conditions

	Joint Label	X [k/in]	Y [k/in]	Rotation[k-ft/rad]
1	J1	Reaction	Reaction	
2	J4	Reaction	Reaction	
3	J16	Reaction	Reaction	
4	J18	Reaction	Reaction	
5	J20	Reaction	Reaction	
6	J21			S71.96
7	J22			S71.96
8	J23			S71.96
9	J24			S71.96
10	J28			S71.96
11	J29			S71.96
12	J30			S71.96
13	J31			S71.96
14	J37			S71.96
15	J38			S71.96
16	J39			S71.96
17	J40			S71.96
18	J46			S71.96
19	J47			S71.96
20	J48			S71.96
21	J49			S71.96

Member Primary Data

	Label	I Joint	J Joint	Rotate(deg)	Section/Shape	Type	Design List	Material	Design Rules
1	SB42	J24	J22		FBts	Beam	Tube	A570 Gr. 55	Typical
2	SB41	J23	J21		FBts	Beam	Tube	A570 Gr. 55	Typical
3	SB32	J31	J29		FBts	Beam	Tube	A570 Gr. 55	Typical
4	SB31	J30	J28		FBts	Beam	Tube	A570 Gr. 55	Typical
5	SB22	J40	J38		FBts	Beam	Tube	A570 Gr. 55	Typical
6	SB21	J39	J37		FBts	Beam	Tube	A570 Gr. 55	Typical
7	SB12	J49	J47		FBts	Beam	Tube	A570 Gr. 55	Typical
8	SB11	J48	J46		FBts	Beam	Tube	A570 Gr. 55	Typical
9	P34B	J26A	J17	180	UC	Column	HU	A570_Gr55	Typical
10	P34A	J26	J26A	180	UC	Column	HU	A570_Gr55	Typical
11	P33B	J35A	J26	180	UC	Column	HU	A570_Gr55	Typical
12	P33A	J35	J35A	180	UC	Column	HU	A570_Gr55	Typical
13	P32B	J44A	J35	180	UC	Column	HU	A570_Gr55	Typical
14	P32A	J44	J44A	180	UC	Column	HU	A570_Gr55	Typical
15	P31	J18	J44	180	UC	Column	HU	A570_Gr55	Typical
16	P25	J12	J3	270	UC	Column	HU	A570_Gr55	Typical
17	P24B	J10A	J12	270	UC	Column	HU	A570_Gr55	Typical
18	P24A	J10	J10A	270	UC	Column	HU	A570_Gr55	Typical
19	P23B	J8A	J10	270	UC	Column	HU	A570_Gr55	Typical
20	P23A	J8	J8A	270	UC	Column	HU	A570_Gr55	Typical
21	P22B	J6A	J8	270	UC	Column	HU	A570_Gr55	Typical
22	P22A	J6	J6A	270	UC	Column	HU	A570_Gr55	Typical
23	P21	J4	J6	270	UC	Column	HU	A570_Gr55	Typical
24	P15	J11	J2	90	UC	Column	HU	A570_Gr55	Typical
25	P14B	J9A	J11	90	UC	Column	HU	A570_Gr55	Typical
26	P14A	J9	J9A	90	UC	Column	HU	A570_Gr55	Typical
27	P13B	J7A	J9	90	UC	Column	HU	A570_Gr55	Typical
28	P13A	J7	J7A	90	UC	Column	HU	A570_Gr55	Typical
29	P12B	J5A	J7	90	UC	Column	HU	A570_Gr55	Typical
30	P12A	J5	J5A	90	UC	Column	HU	A570_Gr55	Typical

Member Primary Data (Continued)

	Label	I Joint	J Joint	Rotate(deg)	Section/Shape	Type	Design List	Material	Design Rules
31	P11	J1	J5	90	UC	Column	HU	A570_Gr55	Typical
32	P5	J19	J20	180	UC	Column	HU	A570_Gr55	Typical
33	P4	J15	J16	180	UC	Column	HU	A570_Gr55	Typical
34	LB16	J19	J24		RIGID	None	None	RIGID	Typical
35	LB15	J22	J17		RIGID	None	None	RIGID	Typical
36	LB14	J17	J23		RIGID	None	None	RIGID	Typical
37	LB13	J21	J15		RIGID	None	None	RIGID	Typical
38	LB12	J27	J31		RIGID	None	None	RIGID	Typical
39	LB11	J29	J26		RIGID	None	None	RIGID	Typical
40	LB10	J26	J30		RIGID	None	None	RIGID	Typical
41	LB9	J28	J25		RIGID	None	None	RIGID	Typical
42	LB8	J36	J40		RIGID	None	None	RIGID	Typical
43	LB7	J38	J35		RIGID	None	None	RIGID	Typical
44	LB6	J35	J39		RIGID	None	None	RIGID	Typical
45	LB5	J37	J34		RIGID	None	None	RIGID	Typical
46	LB4	J45	J49		RIGID	None	None	RIGID	Typical
47	LB3	J47	J44		RIGID	None	None	RIGID	Typical
48	LB2	J44	J48		RIGID	None	None	RIGID	Typical
49	LB1	J46	J43		RIGID	None	None	RIGID	Typical
50	H4	J11	J12	90	UWh	Beam	CS	A570_Gr55	Typical
51	H3	J9	J10	90	UWh	Beam	CS	A570_Gr55	Typical
52	H2	J7	J8	90	UWh	Beam	CS	A570_Gr55	Typical
53	H1	J5	J6	90	UWh	Beam	CS	A570_Gr55	Typical
54	D2	J8	J9	270	UWd	VBrace	CS	A570_Gr55	Typical
55	D1	J6	J7	270	UWd	VBrace	CS	A570_Gr55	Typical

Member Advanced Data

	Label	I Release	J Release	I Offset[in]	J Offset[in]	T/C Only	Physical	Defl Rati...	TOM	Inactive
1	SB42	PIN	PIN				Yes		Yes	
2	SB41	PIN	PIN				Yes		Yes	
3	SB32	PIN	PIN				Yes		Yes	
4	SB31	PIN	PIN				Yes		Yes	Exclude
5	SB22	PIN	PIN				Yes		Yes	
6	SB21	PIN	PIN				Yes		Yes	Exclude
7	SB12	PIN	PIN				Yes		Yes	
8	SB11	PIN	PIN				Yes		Yes	Exclude
9	P34B						Yes	** NA **	Yes	
10	P34A						Yes	** NA **	Yes	
11	P33B						Yes	** NA **	Yes	
12	P33A						Yes	** NA **	Yes	
13	P32B						Yes	** NA **	Yes	
14	P32A						Yes	** NA **	Yes	
15	P31						Yes	** NA **	Yes	
16	P25						Yes	** NA **	Yes	
17	P24B						Yes	** NA **		
18	P24A						Yes	** NA **	Yes	
19	P23B						Yes	** NA **	Yes	
20	P23A						Yes	** NA **	Yes	
21	P22B						Yes	** NA **	Yes	
22	P22A						Yes	** NA **	Yes	
23	P21						Yes	** NA **	Yes	
24	P15						Yes	** NA **	Yes	
25	P14B						Yes	** NA **		
26	P14A						Yes	** NA **	Yes	
27	P13B						Yes	** NA **	Yes	

Member Advanced Data (Continued)

	Label	I Release	J Release	I Offset[in]	J Offset[in]	T/C Only	Physical	Defl Rati...	TOM	Inactive
28	P13A						Yes	** NA **	Yes	
29	P12B						Yes	** NA **	Yes	
30	P12A						Yes	** NA **	Yes	
31	P11						Yes	** NA **	Yes	
32	P5						Yes	** NA **	Yes	Exclude
33	P4						Yes	** NA **	Yes	Exclude
34	LB16						Yes	** NA **		Exclude
35	LB15						Yes	** NA **		Exclude
36	LB14						Yes	** NA **		Exclude
37	LB13						Yes	** NA **		Exclude
38	LB12						Yes	** NA **		Exclude
39	LB11						Yes	** NA **		Exclude
40	LB10						Yes	** NA **		Exclude
41	LB9						Yes	** NA **		Exclude
42	LB8						Yes	** NA **		Exclude
43	LB7						Yes	** NA **		Exclude
44	LB6						Yes	** NA **		Exclude
45	LB5						Yes	** NA **		Exclude
46	LB4						Yes	** NA **		Exclude
47	LB3						Yes	** NA **		Exclude
48	LB2						Yes	** NA **		Exclude
49	LB1						Yes	** NA **		Exclude
50	H4		PIN	2.25	2.25		Yes		Yes	
51	H3	PIN		2.25	2.25		Yes		Yes	
52	H2		PIN	2.25	2.25		Yes		Yes	
53	H1	PIN		2.25	2.25		Yes		Yes	
54	D2	PIN	PIN	4.625	4.625		Yes	** NA **	Yes	
55	D1	PIN	PIN	4.625	4.625		Yes	** NA **	Yes	

Cold Formed Steel Design Parameters

	Label	Shape	Length...	Lb-out[in]	Lb-in[in]	Lcomp to...	Lcom...L-tor...	K-out	K-in	Cm	Cb	R	a[in]	Out s...In sw...
1	P34B	UC	18	22	31.5	31.5	31.5	1	1					Yes
2	P34A	UC	18	22	31.5	31.5	31.5	1	1					Yes
3	P33B	UC	20	35	31.5	31.5	31.5	1	1					Yes
4	P33A	UC	16	35	31.5	31.5	31.5	1	1					Yes
5	P32B	UC	18	35	31.5	31.5	31.5	1	1					Yes
6	P32A	UC	18	35	31.5	31.5	31.5	1	1					Yes
7	P31	UC	12	7.5	7.5	7.5	7.5	1	1				Yes	Yes
8	P25	UC	7.5	7.5	7.5	7.5	7.5	1	1				Yes	Yes
9	P24B	UC	12	31.5	22	22	22	1	1				Yes	Yes
10	P24A	UC	12	31.5	22	22	22	1	1				Yes	Yes
11	P23B	UC	20	31.5	35	35	35	1	1				Yes	
12	P23A	UC	20	31.5	35	35	35	1	1				Yes	
13	P22B	UC	20	31.5	35	35	35	1	1				Yes	
14	P22A	UC	20	31.5	35	35	35	1	1				Yes	
15	P21	UC	8.5	7.5	7.5	7.5	7.5	1	1				Yes	Yes
16	P15	UC	7.5	7.5	7.5	7.5	7.5	1	1				Yes	Yes
17	P14B	UC	12	31.5	22	22	22	1	1				Yes	Yes
18	P14A	UC	12	31.5	22	22	22	1	1				Yes	Yes
19	P13B	UC	20	31.5	35	35	35	1	1				Yes	
20	P13A	UC	20	31.5	35	35	35	1	1				Yes	
21	P12B	UC	20	31.5	35	35	35	1	1				Yes	
22	P12A	UC	20	31.5	35	35	35	1	1				Yes	
23	P11	UC	8.5	7.5	7.5	7.5	7.5	1	1				Yes	Yes
24	P5	UC	120	40	36	36	36							

Cold Formed Steel Design Parameters (Continued)

	Label	Shape	Length...	Lb-out[in]	Lb-in[in]	Lcomp to...	Lcom...L-tor...	K-out	K-in	Cm	Cb	R	a[in]	Out s...In sw...
25	P4	UC	120	40	36	36	36							
26	H4	UWh	44			Lb out								
27	H3	UWh	44			Lb out								
28	H2	UWh	44			Lb out								
29	H1	UWh	44			Lb out								
30	D2	UWd	59.464			Lb out								
31	D1	UWd	59.464			Lb out								

Hot Rolled Steel Design Parameters

	Label	Shape	Length[in]	Lb-out[in]	Lb-in[in]	Lcomp top[in]	Lcomp bot[in]	L-torqu...	K-out	K-in	Cb	Function
1	SB42	FBts	93			Lb out						Lateral
2	SB41	FBts	93			Lb out						Lateral
3	SB32	FBts	93			Lb out						Lateral
4	SB31	FBts	93			Lb out						Lateral
5	SB22	FBts	93			Lb out						Lateral
6	SB21	FBts	93			Lb out						Lateral
7	SB12	FBts	93			Lb out						Lateral
8	SB11	FBts	93			Lb out						Lateral

Member Point Loads (BLC 1 : DL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-27.5	%100
2	P25	Y	-27.5	%100
3	P13B	Y	-27.5	15.5
4	P23B	Y	-27.5	15.5
5	P12B	Y	-27.5	19.5
6	P22B	Y	-27.5	19.5
7	P12A	Y	-27.5	3.5
8	P22A	Y	-27.5	3.5

Member Point Loads (BLC 2 : #1/ #2 / #5 - PL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-1650	%100
2	P25	Y	-1650	%100
3	P13B	Y	-1650	15.5
4	P23B	Y	-1650	15.5
5	P12B	Y	-1650	19.5
6	P22B	Y	-1650	19.5
7	P12A	Y	-1650	3.5
8	P22A	Y	-1650	3.5

Member Point Loads (BLC 3 : #6a - (0.67)PL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-1105.5	%100
2	P25	Y	-1105.5	%100
3	P13B	Y	-1105.5	15.5
4	P23B	Y	-1105.5	15.5
5	P12B	Y	-1105.5	19.5
6	P22B	Y	-1105.5	19.5
7	P12A	Y	-1105.5	3.5
8	P22A	Y	-1105.5	3.5

Member Point Loads (BLC 4 : #6a - (0.67)PL - horiz - Trans)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	X	268	%100
2	P25	X	268	%100
3	P13B	X	189.9	15.5
4	P23B	X	189.9	15.5
5	P12B	X	122.8	19.5
6	P22B	X	122.8	19.5
7	P12A	X	55.8	3.5
8	P22A	X	55.8	3.5

Member Point Loads (BLC 5 : #6b - (1)PL - horiz - Trans)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	X	250.6	%100
2	P25	X	250.6	%100

Member Point Loads (BLC 6 : #5 - (1)PL - horiz - Trans)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	X	400	%100
2	P25	X	400	%100
3	P13B	X	283.4	15.5
4	P23B	X	283.4	15.5
5	P12B	X	183.4	19.5
6	P22B	X	183.4	19.5
7	P12A	X	83.3	3.5
8	P22A	X	83.3	3.5

Member Point Loads (BLC 7 : #6b - (1)PL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-1650	%100
2	P25	Y	-1650	%100

Member Distributed Loads (BLC 1 : DL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...]	Start Location[in,%]	End Location[in,%]
1	SB41	Y	-3.54	-3.54	0	0
2	SB42	Y	-3.54	-3.54	0	0
3	SB31	Y	-3.54	-3.54	0	0
4	SB32	Y	-3.54	-3.54	0	0
5	SB21	Y	-3.54	-3.54	0	0
6	SB22	Y	-3.54	-3.54	0	0
7	SB11	Y	-3.54	-3.54	0	0
8	SB12	Y	-3.54	-3.54	0	0

Member Distributed Loads (BLC 2 : #1/ #2 / #5 - PL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...]	Start Location[in,%]	End Location[in,%]
1	SB41	Y	-212.903	-212.903	0	0
2	SB42	Y	-212.903	-212.903	0	0
3	SB31	Y	-212.903	-212.903	0	0
4	SB32	Y	-212.903	-212.903	0	0
5	SB21	Y	-212.903	-212.903	0	0
6	SB22	Y	-212.903	-212.903	0	0
7	SB11	Y	-212.903	-212.903	0	0
8	SB12	Y	-212.903	-212.903	0	0

Member Distributed Loads (BLC 3 : #6a - (0.67)PL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb/ft,F,ksf]	Start Location[in, %]	End Location[in, %]
1	SB41	Y	-142.645	-142.645	0	0
2	SB42	Y	-142.645	-142.645	0	0
3	SB31	Y	-142.645	-142.645	0	0
4	SB32	Y	-142.645	-142.645	0	0
5	SB21	Y	-142.645	-142.645	0	0
6	SB22	Y	-142.645	-142.645	0	0
7	SB11	Y	-142.645	-142.645	0	0
8	SB12	Y	-142.645	-142.645	0	0

Member Distributed Loads (BLC 7 : #6b - (1)PL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb/ft,F,ksf]	Start Location[in, %]	End Location[in, %]
1	SB41	Y	-212.903	-212.903	0	0
2	SB42	Y	-212.903	-212.903	0	0

Member Distributed Loads (BLC 8 : #6a - (0.67)PL - horiz - Long)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb/ft,F,ksf]	Start Location[in, %]	End Location[in, %]
1	SB41	X	6.274	6.274	0	0
2	SB42	X	6.274	6.274	0	0
3	SB31	X	4.444	4.444	0	0
4	SB32	X	4.444	4.444	0	0
5	SB21	X	2.876	2.876	0	0
6	SB22	X	2.876	2.876	0	0
7	SB11	X	1.307	1.307	0	0
8	SB12	X	1.307	1.307	0	0

Member Distributed Loads (BLC 9 : #6b - (1)PL - horiz - Long)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb/ft,F,ksf]	Start Location[in, %]	End Location[in, %]
1	SB41	X	5.865	5.865	0	0
2	SB42	X	5.865	5.865	0	0

Member Distributed Loads (BLC 10 : #5 - (1)PL - horiz - Long)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb/ft,F,ksf]	Start Location[in, %]	End Location[in, %]
1	SB41	X	9.364	9.364	0	0
2	SB42	X	9.364	9.364	0	0
3	SB31	X	6.633	6.633	0	0
4	SB32	X	6.633	6.633	0	0
5	SB21	X	4.292	4.292	0	0
6	SB22	X	4.292	4.292	0	0
7	SB11	X	1.951	1.951	0	0
8	SB12	X	1.951	1.951	0	0

Joint Loads and Enforced Displacements (BLC 11 : Notional (+Xg) Lat All Shlvs)

	Joint Label	L,D,M	Direction	Magnitude[(lb,lb-in), (in,rad), (lb*s^2,...)]
1	J2	L	X	10.4
2	J3	L	X	10.4
3	J17	L	X	10.4
4	J26	L	X	7.1
5	J35	L	X	7.1
6	J44	L	X	7.1

Basic Load Cases

	BLC Description	Category	X Gravity	Y Gravity	Joint	Point	Distributed
1	DL	DL		-1		8	8
2	#1/ #2 / #5 - PL	LL				8	8
3	#6a - (0.67)PL	LL				8	8
4	#6a - (0.67)PL - horiz - Trans	EL	.187			8	
5	#6b - (1)PL - horiz - Trans	EL	.187			2	
6	#5 - (1)PL - horiz - Trans	EL	.187			8	
7	#6b - (1)PL	LL				2	2
8	#6a - (0.67)PL - horiz - Long	EL	.047				8
9	#6b - (1)PL - horiz - Long	EL	.047				2
10	#5 - (1)PL - horiz - Long	EL	.047				8
11	Notional (+Xg) Lat All Shlvs	NLX	.004		6		

Load Combinations

	Description	So...	P...	S...	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..
1	RMI - LC #1	Yes	Y		1	1.4	2	1.2	11	1										
2	RMI - LC #2	Yes	Y		1	1.2	2	1.4	11	1										
3	RMI - LC #6a - Trans	Yes	Y		1	.71	3	.71	4	1										
4	RMI - LC #6a - Long	Yes	Y		1	.71	3	.71	8	1										
5	RMI - LC #6b - Trans	Yes	Y		1	.71	7	.71	5	1										
6	RMI - LC #6b - Long	Yes	Y		1	.71	7	.71	9	1										
7	RMI - LC #5 - Trans	Yes	Y		1	1.39	2	1.04	6	1										
8	RMI - LC #5 - Long	Yes	Y		1	1.39	2	1.04	10	1										
9	RMI - LC #6a - Long-C...	Yes	Y		8	.7														
10	RMI - LC #6b - Long-C...	Yes	Y		9	.7														
11	RMI - LC #5 - Long-Co...	Yes	Y		10	.7														

Envelope Joint Reactions

	Joint		X [lb]	LC	Y [lb]	LC	Moment [lb-in]	LC
1	J46	max	0	11	0	11	4376.016	8
2		min	0	1	0	1	328.047	5
3	J40	max	0	11	0	11	2695.621	8
4		min	0	1	0	1	297.766	5
5	J47	max	0	11	0	11	2592.183	8
6		min	0	1	0	1	212.907	1
7	J48	max	0	11	0	11	2592.183	8
8		min	0	1	0	1	212.907	1
9	J37	max	0	11	0	11	2489.158	8
10		min	0	1	0	1	68.195	2
11	J38	max	0	11	0	11	2397.666	8
12		min	0	1	0	1	186.815	1
13	J39	max	0	11	0	11	2397.666	8
14		min	0	1	0	1	186.815	1
15	J28	max	0	11	0	11	2058.873	8
16		min	0	1	0	1	219.741	3
17	J31	max	0	11	0	11	1866.746	8
18		min	0	1	0	1	-76.656	5
19	J29	max	0	11	0	11	1839.545	8
20		min	0	1	0	1	138.028	1
21	J30	max	0	11	0	11	1839.545	8
22		min	0	1	0	1	138.028	1
23	J49	max	0	11	0	11	1740.34	11
24		min	0	1	0	1	-1904.487	2
25	J21	max	0	11	0	11	1590.587	8

Envelope Joint Reactions (Continued)

	Joint		X [lb]	LC	Y [lb]	LC	Moment [lb-in]	LC
26		min	0	1	0	1	225.871	3
27	J22	max	0	11	0	11	1156.655	8
28		min	0	1	0	1	85.865	1
29	J23	max	0	11	0	11	1156.655	8
30		min	0	1	0	1	85.865	1
31	J24	max	0	11	0	11	1090.289	8
32		min	0	1	0	1	-663.221	5
33	J1	max	-1.045	11	9361.78	2	0	11
34		min	-908.673	7	-133.897	5	0	1
35	J4	max	.177	8	10888.013	7	0	11
36		min	-1004.481	7	3.074	9	0	1
37	J16	max	-16.722	10	4769.962	2	0	11
38		min	-607.222	2	.873	10	0	1
39	J18	max	-16.328	2	9512.772	2	0	11
40		min	-183.245	8	0	10	0	1
41	J20	max	590.94	2	4769.951	2	0	11
42		min	-60.455	11	-3.093	11	0	1
43	Totals:	max	-53.7	2	37879.816	2		
44		min	-1961.215	7	0	10		

Envelope Joint Displacements

	Joint		X [in]	LC	Y [in]	LC	Rotation [rad]	LC
1	J1	max	0	11	0	11	2.848e-04	8
2		min	0	1	0	1	-1.123e-02	7
3	J2	max	.799	7	0	11	7.432e-05	8
4		min	-.022	8	-.031	2	-2.37e-02	7
5	J3	max	.79	7	0	11	8.727e-05	8
6		min	-.022	8	-.032	2	-2.408e-02	7
7	J4	max	0	11	0	11	3.094e-04	8
8		min	0	1	0	1	-1.253e-02	7
9	J5	max	.091	7	0	5	2.883e-04	8
10		min	-.002	8	-.004	2	-8.898e-03	7
11	J5A	max	.171	7	0	5	3.428e-04	2
12		min	-.009	2	-.012	2	-1.736e-04	5
13	J6	max	.101	7	0	11	3.035e-04	8
14		min	-.003	8	-.005	7	-9.723e-03	7
15	J6A	max	.187	7	0	11	3.207e-04	2
16		min	-.008	2	-.012	7	-1.565e-04	5
17	J7	max	.122	7	0	5	3.928e-03	7
18		min	-.015	2	-.019	2	2.455e-06	9
19	J7A	max	.065	7	0	5	4.978e-04	5
20		min	-.021	2	-.023	2	-6.984e-07	9
21	J8	max	.135	7	0	11	3.738e-03	7
22		min	-.015	2	-.019	7	2.032e-06	9
23	J8A	max	.083	7	0	11	3.62e-04	5
24		min	-.021	2	-.024	2	-4.828e-07	9
25	J9	max	.164	7	0	11	1.158e-04	8
26		min	-.023	2	-.028	2	-1.176e-02	7
27	J10	max	.173	7	0	11	1.179e-04	8
28		min	-.023	2	-.028	2	-1.056e-02	7
29	J11	max	.622	7	0	11	7.411e-05	8
30		min	-.021	8	-.03	2	-2.285e-02	7
31	J12	max	.61	7	0	11	8.702e-05	8
32		min	-.021	8	-.031	2	-2.323e-02	7
33	J15	max	.381	8	0	10	-2.616e-04	3

Envelope Joint Displacements (Continued)

	Joint		X [in]	LC	Y [in]	LC	Rotation [rad]	LC
34		min	.051	3	-.016	2	-1.842e-03	8
35	J16	max	0	11	0	11	-4.228e-04	5
36		min	0	1	0	1	-6.21e-03	8
37	J17	max	.342	8	0	11	-9.944e-05	1
38		min	.027	1	-.032	2	-1.339e-03	8
39	J18	max	0	11	0	11	-2.844e-04	1
40		min	0	1	0	1	-3.423e-03	8
41	J19	max	.303	8	0	11	7.68e-04	5
42		min	-.025	2	-.016	2	-1.263e-03	8
43	J20	max	0	11	0	11	3.438e-03	2
44		min	0	1	0	1	-2.138e-03	11
45	J21	max	.381	8	0	10	-2.616e-04	3
46		min	.051	3	-.017	2	-1.842e-03	8
47	J22	max	.342	8	0	10	-9.944e-05	1
48		min	.027	1	-.032	2	-1.339e-03	8
49	J23	max	.342	8	.001	11	-9.944e-05	1
50		min	.027	1	-.032	2	-1.339e-03	8
51	J24	max	.303	8	.002	11	7.68e-04	5
52		min	-.025	2	-.016	2	-1.263e-03	8
53	J25	max	.307	8	0	10	-2.545e-04	3
54		min	.028	5	-.014	2	-2.384e-03	8
55	J26	max	.269	8	0	11	-1.598e-04	1
56		min	.021	1	-.028	2	-2.13e-03	8
57	J26A	max	.309	8	0	11	-1.582e-04	1
58		min	.024	1	-.03	2	-2.124e-03	8
59	J27	max	.23	8	0	11	8.877e-05	5
60		min	-.029	2	-.014	2	-2.162e-03	8
61	J28	max	.307	8	0	10	-2.545e-04	3
62		min	.028	5	-.014	2	-2.384e-03	8
63	J29	max	.269	8	0	10	-1.598e-04	1
64		min	.021	1	-.028	2	-2.13e-03	8
65	J30	max	.269	8	.002	11	-1.598e-04	1
66		min	.021	1	-.027	2	-2.13e-03	8
67	J31	max	.23	8	.002	11	8.877e-05	5
68		min	-.029	2	-.014	2	-2.162e-03	8
69	J34	max	.205	8	0	10	-7.897e-05	2
70		min	.017	5	-.009	2	-2.883e-03	8
71	J35	max	.165	8	0	11	-2.163e-04	1
72		min	.013	1	-.019	2	-2.777e-03	8
73	J35A	max	.214	8	0	11	-2.332e-04	1
74		min	.017	1	-.023	2	-3.063e-03	8
75	J36	max	.124	8	0	11	-3.448e-04	5
76		min	-.04	2	-.009	2	-3.122e-03	8
77	J37	max	.205	8	-.001	10	-7.897e-05	2
78		min	.017	5	-.011	8	-2.883e-03	8
79	J38	max	.165	8	0	10	-2.163e-04	1
80		min	.013	1	-.019	2	-2.777e-03	8
81	J39	max	.165	8	.003	11	-2.163e-04	1
82		min	.013	1	-.018	2	-2.777e-03	8
83	J40	max	.124	8	.003	11	-3.448e-04	5
84		min	-.04	2	-.009	2	-3.122e-03	8
85	J43	max	.073	8	0	10	-3.799e-04	5
86		min	.005	5	-.003	2	-5.068e-03	8
87	J44	max	.04	8	0	11	-2.466e-04	1
88		min	.003	1	-.006	2	-3.002e-03	8
89	J44A	max	.104	8	0	11	-2.903e-04	1
90		min	.008	1	-.012	2	-3.63e-03	8

Envelope Joint Displacements (Continued)

	Joint		X [in]	LC	Y [in]	LC	Rotation [rad]	LC
91	J45	max	.025	11	0	11	2.205e-03	2
92		min	-.039	2	-.003	2	-2.015e-03	11
93	J46	max	.073	8	0	5	-3.799e-04	5
94		min	.005	5	-.01	8	-5.068e-03	8
95	J47	max	.04	8	0	10	-2.466e-04	1
96		min	.003	1	-.009	8	-3.002e-03	8
97	J48	max	.04	8	.003	11	-2.466e-04	1
98		min	.003	1	-.005	2	-3.002e-03	8
99	J49	max	.025	11	.003	11	2.205e-03	2
100		min	-.039	2	-.006	2	-2.015e-03	11
101	J9A	max	.36	7	0	11	1.024e-04	8
102		min	-.02	8	-.029	2	-1.978e-02	7
103	J10A	max	.354	7	0	11	9.424e-05	8
104		min	-.02	8	-.029	2	-1.869e-02	7

Envelope Maximum Member Section Forces

	Member		Axial[lb]	Loc[in]	LC	Shear[lb]	Loc[in]	LC	Moment[lb-in]	Loc[in]	LC
1	SB42	max	83.853	0	8	1185.684	93	2	27729.207	46.5	2
2		min	-48.326	93	6	-1185.679	0	2	-112.357	93	6
3	SB41	max	91.381	0	8	1185.685	93	2	27718.607	46.5	2
4		min	-49.037	93	6	-1185.68	0	2	-114.011	93	6
5	SB32	max	55.845	0	5	1185.684	93	2	27462.898	46.5	2
6		min	-53.358	93	8	-1185.679	0	2	-124.058	93	8
7	SB22	max	229.878	0	2	1185.684	93	2	28101.45	46.5	2
8		min	-29.575	93	5	-1185.679	0	2	-68.761	93	5
9	SB12	max	-7.638	0	5	1185.684	93	2	25600.279	46.5	2
10		min	-845.994	93	2	-1185.679	0	2	-1966.935	93	2
11	P34B	max	2375.458	0	2	84.825	0	8	-59.788	0	1
12		min	821.208	18	3	5.859	18	3	-2307.579	18	8
13	P34A	max	2379.55	0	2	85.705	0	8	759.08	0	8
14		min	823.629	18	3	6.287	18	1	-782.171	18	8
15	P33B	max	4755.435	0	2	126.54	0	8	34.127	0	6
16		min	1248.951	20	5	9.244	20	1	-2916.307	20	8
17	P33A	max	4759.072	0	2	127.707	0	8	1654.889	0	8
18		min	1251.641	16	5	9.364	16	1	-387.281	16	8
19	P32B	max	7134.572	0	2	161.822	0	8	23.768	0	6
20		min	1290.099	18	5	12.818	18	1	-3136.403	18	8
21	P32A	max	7138.663	0	2	162.61	0	8	2700.502	0	8
22		min	1292.52	18	5	12.928	18	1	-225.043	18	8
23	P31	max	9512.772	0	2	207.438	0	8	0	0	1
24		min	1331.249	12	5	18.641	12	1	-2488.617	12	8
25	P25	max	2344.705	0	2	442.264	0	7	3315.984	0	7
26		min	804.43	7.5	3	-.153	7.5	8	-.898	0	8
27	P24B	max	2350.18	0	2	369.712	0	7	7749.98	0	7
28		min	806.25	12	4	.868	12	6	-.898	12	8
29	P24A	max	2352.908	0	2	358.635	0	7	12051.054	0	7
30		min	807.864	12	4	.964	12	6	11.071	12	6
31	P23B	max	4703.402	0	2	.858	0	8	11308.545	20	7
32		min	811.031	20	4	-522.415	20	7	5.998	0	6
33	P23A	max	4707.948	0	2	.758	0	8	5260.035	20	7
34		min	1219.853	20	6	-259.948	20	7	-1007.289	0	5
35	P22B	max	7132.266	0	7	1.101	0	8	41.023	20	7
36		min	1227.194	20	6	-440.619	20	7	-5187.963	0	7
37	P22A	max	9440.327	0	2	.728	0	6	47.463	0	8
38		min	1249.409	20	6	-205.978	20	7	-9008.889	0	7

Envelope Maximum Member Section Forces (Continued)

	Member		Axial[lb]	Loc[in]	LC	Shear[lb]	Loc[in]	LC	Moment[lb-in]	Loc[in]	LC
39	P21	max	10888.013	0	7	1134.398	0	7	20.33	8.5	8
40		min	1277.108	8.5	6	-2.43	8.5	8	-9641.1	8.5	7
41	P15	max	2344.705	0	2	441.596	0	7	3310.972	0	7
42		min	804.43	7.5	3	-.13	7.5	8	-.727	0	8
43	P14B	max	2349.053	0	2	508.466	0	7	6784.214	0	7
44		min	768.584	12	3	-1.59	12	8	13.838	0	6
45	P14A	max	2351.781	0	2	499.494	0	7	12775.587	0	7
46		min	770.198	12	3	-1.52	12	8	7.703	0	8
47	P13B	max	4669.996	0	2	-.45	0	4	12802.728	20	7
48		min	-389.518	20	3	-574.983	20	7	.801	0	6
49	P13A	max	4674.542	0	2	-.324	0	4	5702.857	20	7
50		min	328.753	20	5	-299.83	20	7	-1221.076	0	5
51	P12B	max	7009.884	0	2	-.781	0	6	90.077	20	8
52		min	-897.135	20	3	-373.033	20	7	-4758.345	0	7
53	P12A	max	9357.43	0	2	-.608	0	6	44.998	20	8
54		min	-153.691	20	5	-177.926	20	7	-8018.229	0	7
55	P11	max	9361.78	0	2	943.472	0	7	0	0	1
56		min	-135.04	8.5	5	1.34	8.5	8	-8018.229	8.5	7
57	H4	max	4.067	39.5	8	3.369	0	8	33.617	0	8
58		min	-68.157	0	7	-62.374	39.5	7	-2474.748	0	7
59	H3	max	1.483	39.5	8	2.233	0	8	1001.329	39.5	7
60		min	-864.255	0	7	-19.227	39.5	7	-19.259	17.281	8
61	H2	max	2.317	39.5	8	3.613	0	8	703.605	39.5	7
62		min	-2090.92	0	7	-16.823	39.5	7	-6.544	28.391	8
63	H1	max	-.586	39.5	6	2.768	0	8	922.004	39.5	7
64		min	-1009.387	0	7	-16.104	39.5	7	-29.762	21.807	8
65	D2	max	2595.455	0	7	2.39	50.214	1	10.003	25.107	1
66		min	-1.573	50.214	8	-2.39	0	1	-20.005	0	1
67	D1	max	2937.18	0	7	2.39	50.214	1	10.003	25.107	1
68		min	-.16	50.214	8	-2.39	0	1	-20.005	0	1

Envelope Member Section Deflections Service

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
1	SB42	1	max	2	.016	2	NC	1
2			min	8	.004	6	NC	1
3		2	max	2	.251	2	1166.331	3
4			min	8	.086	4	403.772	2
5		3	max	2	.347	2	831.812	4
6			min	8	.12	4	287.794	2
7		4	max	2	.258	2	1168.562	4
8			min	8	.09	3	403.772	2
9		5	max	2	.032	2	NC	1
10			min	8	.008	5	NC	1
11	SB41	1	max	3	.032	2	NC	1
12			min	8	.007	6	NC	1
13		2	max	3	.258	2	1165.873	3
14			min	8	.089	4	403.967	2
15		3	max	3	.347	2	831.082	3
16			min	8	.12	3	287.926	2
17		4	max	3	.251	2	1166.88	4
18			min	8	.087	3	403.967	2
19		5	max	3	.017	2	NC	1
20			min	8	.005	5	NC	1
21	SB32	1	max	2	.014	2	NC	1
22			min	8	.002	6	NC	1

Envelope Member Section Deflections Service (Continued)

	Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
23		2	max	.003	2	.245	2	NC	5
24			min	-.25	8	.008	6	408.722	2
25		3	max	.003	2	.34	2	NC	5
26			min	-.25	8	.011	6	291.145	2
27		4	max	.004	2	.252	2	NC	5
28			min	-.25	8	.01	5	408.723	2
29		5	max	.004	2	.028	2	NC	1
30			min	-.25	8	.006	5	NC	1
31	SB22	1	max	.013	2	.009	2	NC	1
32			min	-.145	8	0	6	NC	1
33		2	max	.013	2	.246	2	NC	5
34			min	-.145	8	.004	6	397.049	2
35		3	max	.013	2	.342	2	NC	5
36			min	-.145	8	.006	6	283.236	2
37		4	max	.013	2	.251	2	NC	5
38			min	-.145	8	.006	5	397.05	2
39		5	max	.013	2	.019	2	NC	1
40			min	-.145	8	.004	5	NC	1
41	SB12	1	max	.016	2	.006	2	NC	1
42			min	-.026	8	0	6	NC	1
43		2	max	.017	2	.214	2	NC	5
44			min	-.025	8	.003	6	447.061	2
45		3	max	.018	2	.3	2	NC	5
46			min	-.025	8	.005	6	316.962	2
47		4	max	.019	2	.214	2	NC	5
48			min	-.024	8	.004	5	447.062	2
49		5	max	.02	2	.009	8	NC	1
50			min	-.023	8	.001	5	NC	1
51	P34B	1	max	-.007	6	-.024	1	NC	1
52			min	-.03	2	-.309	8	NC	1
53		2	max	-.007	6	-.025	1	NC	1
54			min	-.03	2	-.318	8	NC	1
55		3	max	-.007	6	-.026	1	NC	1
56			min	-.031	2	-.327	8	NC	1
57		4	max	-.007	6	-.026	1	NC	1
58			min	-.031	2	-.335	8	NC	1
59		5	max	-.008	6	-.027	1	NC	1
60			min	-.032	2	-.342	8	NC	1
61	P34A	1	max	-.005	6	-.021	1	NC	1
62			min	-.028	2	-.269	8	NC	1
63		2	max	-.006	6	-.022	1	NC	1
64			min	-.028	2	-.279	8	2793.031	4
65		3	max	-.006	6	-.023	1	NC	1
66			min	-.029	2	-.289	8	1381.007	4
67		4	max	-.006	6	-.023	1	NC	1
68			min	-.029	2	-.299	8	917.243	4
69		5	max	-.007	6	-.024	1	NC	1
70			min	-.03	2	-.309	8	690.426	4
71	P33B	1	max	-.004	6	-.017	1	NC	1
72			min	-.023	2	-.214	8	NC	1
73		2	max	-.005	6	-.018	1	NC	1
74			min	-.024	2	-.229	8	NC	1
75		3	max	-.005	6	-.019	1	NC	1
76			min	-.025	2	-.244	8	8579.501	8
77		4	max	-.005	6	-.02	1	NC	1
78			min	-.026	2	-.257	8	NC	1
79		5	max	-.005	6	-.021	1	NC	1

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
80		min	-.028	2	-.269	8	NC	1
81	P33A	1	max	6	-.013	1	NC	1
82		min	-.019	2	-.165	8	NC	1
83		2	max	6	-.014	1	NC	1
84		min	-.02	2	-.176	8	1372.492	8
85		3	max	6	-.015	1	8689.141	1
86		min	-.021	2	-.189	8	671.371	8
87		4	max	6	-.016	1	5722.706	1
88		min	-.022	2	-.201	8	440.867	8
89		5	max	6	-.017	1	4266.257	1
90		min	-.023	2	-.214	8	327.816	8
91	P32B	1	max	6	-.008	1	NC	1
92		min	-.012	2	-.104	8	NC	1
93		2	max	6	-.01	1	NC	1
94		min	-.014	2	-.12	8	NC	1
95		3	max	6	-.011	1	NC	1
96		min	-.016	2	-.136	8	9369.128	8
97		4	max	6	-.012	1	NC	1
98		min	-.017	2	-.151	8	NC	1
99		5	max	6	-.013	1	NC	1
100		min	-.019	2	-.165	8	NC	1
101	P32A	1	max	6	-.003	1	NC	1
102		min	-.006	2	-.04	8	NC	1
103		2	max	6	-.005	1	NC	1
104		min	-.007	2	-.055	8	1239.689	8
105		3	max	6	-.006	1	7330.594	1
106		min	-.009	2	-.071	8	596.725	8
107		4	max	6	-.007	1	4769.871	1
108		min	-.011	2	-.087	8	386.959	8
109		5	max	6	-.008	1	3523.957	1
110		min	-.012	2	-.104	8	285.001	8
111	P31	1	max	8	0	1	NC	1
112		min	0	1	0	1	NC	1
113		2	max	6	0	1	NC	1
114		min	-.001	2	-.011	8	NC	1
115		3	max	6	-.002	1	NC	1
116		min	-.003	2	-.021	8	NC	1
117		4	max	6	-.003	1	NC	1
118		min	-.004	2	-.031	8	NC	1
119		5	max	6	-.003	1	NC	1
120		min	-.006	2	-.04	8	NC	1
121	P25	1	max	6	.021	8	NC	1
122		min	-.031	2	-.61	7	NC	1
123		2	max	6	.021	8	NC	1
124		min	-.031	2	-.654	7	169.8	7
125		3	max	6	.021	8	NC	1
126		min	-.031	2	-.699	7	84.329	7
127		4	max	6	.022	8	NC	1
128		min	-.031	2	-.744	7	55.927	7
129		5	max	6	.022	8	NC	1
130		min	-.032	2	-.79	7	41.79	7
131	P24B	1	max	6	.02	8	NC	1
132		min	-.029	2	-.354	7	NC	1
133		2	max	6	.02	8	NC	1
134		min	-.03	2	-.412	7	204.539	7
135		3	max	6	.021	8	NC	1
136		min	-.03	2	-.475	7	98.826	7

Envelope Member Section Deflections Service (Continued)

	Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
137		4	max	-.007	6	.021	8	NC	1
138			min	-.03	2	-.541	7	63.97	7
139		5	max	-.007	6	.021	8	NC	1
140			min	-.031	2	-.61	7	46.788	7
141	P24A	1	max	-.006	6	.023	2	NC	1
142			min	-.028	2	-.173	7	NC	1
143		2	max	-.006	6	.022	2	NC	1
144			min	-.028	2	-.209	7	337.014	7
145		3	max	-.006	6	.021	2	NC	1
146			min	-.029	2	-.251	7	153.905	7
147		4	max	-.006	6	.021	2	NC	1
148			min	-.029	2	-.3	7	94.915	7
149		5	max	-.006	6	.02	8	NC	1
150			min	-.029	2	-.354	7	66.549	7
151	P23B	1	max	-.004	6	.021	2	NC	1
152			min	-.024	2	-.083	7	NC	1
153		2	max	-.005	6	.022	2	NC	1
154			min	-.025	2	-.087	7	5066.405	7
155		3	max	-.005	6	.023	2	NC	1
156			min	-.026	2	-.102	7	1056.6	7
157		4	max	-.005	6	.023	2	NC	1
158			min	-.027	2	-.13	7	425.685	7
159		5	max	-.006	6	.023	2	NC	1
160			min	-.028	2	-.173	7	221.125	7
161	P23A	1	max	-.003	6	.015	2	NC	1
162			min	-.019	7	-.135	7	386.609	7
163		2	max	-.003	6	.017	2	NC	1
164			min	-.02	7	-.116	7	604.62	7
165		3	max	-.004	6	.018	2	NC	1
166			min	-.021	7	-.1	7	1193.36	7
167		4	max	-.004	6	.02	2	NC	1
168			min	-.022	2	-.088	7	4005.549	7
169		5	max	-.004	6	.021	2	NC	1
170			min	-.024	2	-.083	7	NC	1
171	P22B	1	max	-.002	6	.008	2	NC	1
172			min	-.012	7	-.187	7	NC	1
173		2	max	-.002	6	.01	2	NC	1
174			min	-.014	7	-.182	7	2557.386	7
175		3	max	-.002	6	.012	2	NC	4
176			min	-.016	7	-.17	7	2231.311	7
177		4	max	-.003	6	.013	2	NC	4
178			min	-.018	7	-.153	7	3556.137	7
179		5	max	-.003	6	.015	2	NC	3
180			min	-.019	7	-.135	7	2994.085	2
181	P22A	1	max	0	6	.003	8	NC	1
182			min	-.005	7	-.101	7	NC	1
183		2	max	0	6	.004	8	NC	1
184			min	-.007	7	-.142	7	1029.112	7
185		3	max	-.001	6	.005	8	NC	4
186			min	-.008	7	-.169	7	807.728	7
187		4	max	-.002	6	.007	8	NC	4
188			min	-.01	7	-.183	7	1130.171	7
189		5	max	-.002	6	.008	2	NC	3
190			min	-.012	7	-.187	7	3296.093	2
191	P21	1	max	0	8	0	1	NC	1
192			min	0	1	0	1	NC	1
193		2	max	0	6	0	8	NC	1

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
194		min	-.001	7	-.027	7	4566.612	7
195	3	max	0	6	.001	8	NC	4
196		min	-.002	7	-.054	7	2854.155	7
197	4	max	0	6	.002	8	NC	4
198		min	-.004	7	-.079	7	3261.924	7
199	5	max	0	6	.003	8	NC	3
200		min	-.005	7	-.101	7	3699.341	2
201	P15	1	max	5	.021	8	NC	1
202		min	-.03	2	-.622	7	NC	1
203	2	max	-.002	5	.021	8	NC	1
204		min	-.031	2	-.666	7	172.586	7
205	3	max	-.002	5	.021	8	NC	1
206		min	-.031	2	-.71	7	85.704	7
207	4	max	-.002	5	.022	8	NC	1
208		min	-.031	2	-.754	7	56.834	7
209	5	max	-.002	3	.022	8	NC	1
210		min	-.031	2	-.799	7	42.466	7
211	P14B	1	max	5	.02	8	NC	1
212		min	-.029	2	-.36	7	NC	1
213	2	max	-.001	5	.02	8	NC	1
214		min	-.029	2	-.421	7	194.353	7
215	3	max	-.001	5	.021	8	NC	1
216		min	-.03	2	-.486	7	94.694	7
217	4	max	-.002	5	.021	8	NC	1
218		min	-.03	2	-.554	7	61.854	7
219	5	max	-.002	5	.021	8	NC	1
220		min	-.03	2	-.622	7	45.689	7
221	P14A	1	max	5	.023	2	NC	1
222		min	-.028	2	-.164	7	NC	1
223	2	max	0	5	.022	2	NC	1
224		min	-.028	2	-.203	7	303.795	7
225	3	max	0	5	.021	2	NC	1
226		min	-.028	2	-.25	7	139.627	7
227	4	max	0	5	.02	2	NC	1
228		min	-.029	2	-.302	7	86.701	7
229	5	max	-.001	5	.02	8	NC	1
230		min	-.029	2	-.36	7	61.234	7
231	P13B	1	max	5	.021	2	NC	1
232		min	-.023	2	-.065	7	NC	1
233	2	max	0	5	.022	2	NC	1
234		min	-.024	2	-.069	7	5443.792	7
235	3	max	0	5	.023	2	NC	1
236		min	-.025	2	-.085	7	1021.031	7
237	4	max	0	5	.023	2	NC	1
238		min	-.027	2	-.115	7	398.155	7
239	5	max	0	5	.023	2	NC	1
240		min	-.028	2	-.164	7	203.272	7
241	P13A	1	max	5	.015	2	NC	1
242		min	-.019	2	-.122	7	350.972	7
243	2	max	0	5	.017	2	NC	1
244		min	-.02	2	-.102	7	539.435	7
245	3	max	0	5	.019	2	NC	1
246		min	-.021	2	-.084	7	1039.755	7
247	4	max	0	5	.02	2	NC	1
248		min	-.022	2	-.071	7	3320.658	7
249	5	max	0	5	.021	2	NC	1
250		min	-.023	2	-.065	7	NC	1

Envelope Member Section Deflections Service (Continued)

	Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
251	P12B	1	max	0	5	.009	2	NC	1
252			min	-.012	2	-.171	7	NC	1
253		2	max	0	5	.01	2	NC	1
254			min	-.013	2	-.167	7	2450.028	7
255		3	max	0	5	.012	2	NC	1
256			min	-.015	2	-.157	7	2039.67	7
257		4	max	0	5	.014	2	NC	1
258			min	-.017	2	-.141	7	3055.932	7
259		5	max	0	5	.015	2	NC	1
260			min	-.019	2	-.122	7	NC	1
261	P12A	1	max	0	5	.002	8	NC	1
262			min	-.004	2	-.091	7	NC	1
263		2	max	0	5	.004	8	NC	1
264			min	-.006	2	-.129	7	1143.332	7
265		3	max	0	5	.005	8	NC	4
266			min	-.008	2	-.154	7	895.574	7
267		4	max	0	5	.007	2	NC	4
268			min	-.01	2	-.167	7	1250.407	7
269		5	max	0	5	.009	2	NC	3
270			min	-.012	2	-.171	7	3146.872	2
271	P11	1	max	0	8	0	1	NC	1
272			min	0	1	0	1	NC	1
273		2	max	0	5	0	8	NC	1
274			min	-.001	2	-.024	7	5490.813	7
275		3	max	0	5	.001	8	NC	1
276			min	-.002	2	-.048	7	3431.79	7
277		4	max	0	5	.002	8	NC	4
278			min	-.003	2	-.071	7	3922.095	7
279		5	max	0	5	.002	8	NC	3
280			min	-.004	2	-.091	7	3923.022	2
281	H4	1	max	.614	7	-.007	6	NC	1
282			min	-.021	8	-.061	7	NC	1
283		2	max	.614	7	-.007	6	NC	1
284			min	-.021	8	-.21	7	263.855	7
285		3	max	.614	7	-.007	6	NC	4
286			min	-.021	8	-.232	7	227.409	7
287		4	max	.614	7	-.007	6	NC	1
288			min	-.021	8	-.168	7	357.034	7
289		5	max	.614	7	-.007	6	NC	1
290			min	-.021	8	-.056	7	NC	1
291	H3	1	max	.166	7	.009	3	NC	1
292			min	-.023	2	-.028	2	NC	1
293		2	max	.167	7	.065	7	NC	1
294			min	-.023	2	-.028	2	667.394	7
295		3	max	.168	7	.089	7	NC	1
296			min	-.023	2	-.027	2	459.07	7
297		4	max	.169	7	.07	7	NC	1
298			min	-.023	2	-.027	2	563.59	7
299		5	max	.17	7	.006	5	NC	1
300			min	-.023	2	-.028	2	NC	1
301	H2	1	max	.124	7	.005	3	NC	1
302			min	-.015	2	-.018	2	NC	1
303		2	max	.126	7	.037	7	NC	1
304			min	-.015	2	-.016	2	1123.624	7
305		3	max	.128	7	.053	7	NC	1
306			min	-.015	2	-.016	2	745.91	7
307		4	max	.13	7	.043	7	NC	1

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
308		min	-.015	2	-.017	2	887.93	7
309	5	max	.132	7	0	5	NC	1
310		min	-.015	2	-.018	2	NC	1
311	H1	max	.094	7	.015	7	NC	1
312		min	-.003	8	-.005	2	NC	1
313	2	max	.095	7	.074	7	NC	1
314		min	-.003	8	-.007	2	675.717	7
315	3	max	.096	7	.1	7	NC	1
316		min	-.003	8	-.008	2	471.856	7
317	4	max	.097	7	.084	7	NC	1
318		min	-.003	8	-.007	2	586.767	7
319	5	max	.098	7	.017	7	NC	1
320		min	-.003	8	-.005	2	NC	1
321	D2	max	0	6	.026	2	NC	1
322		min	-.113	7	-.059	7	NC	1
323	2	max	0	6	.029	2	NC	1
324		min	-.116	7	-.056	7	NC	1
325	3	max	0	6	.032	2	NC	1
326		min	-.12	7	-.053	7	NC	1
327	4	max	0	6	.034	2	NC	1
328		min	-.123	7	-.052	7	NC	1
329	5	max	0	6	.036	2	NC	1
330		min	-.126	7	-.05	7	NC	1
331	D1	max	0	6	.006	2	NC	1
332		min	-.078	7	-.11	7	NC	1
333	2	max	0	6	.011	2	NC	1
334		min	-.082	7	-.106	7	NC	1
335	3	max	0	6	.015	2	NC	1
336		min	-.086	7	-.102	7	NC	1
337	4	max	0	6	.019	2	NC	1
338		min	-.09	7	-.1	7	NC	1
339	5	max	0	6	.023	2	NC	1
340		min	-.094	7	-.097	7	NC	1

Envelope Beam Deflection Checks


Be...	Design Rule	Span	Defl [in]	Ratio	LC	Defl [in]	Ratio	LC	Defl [in]	Ratio	LC
No Data to Print ...											

Envelope AISI S100-12: LRFD Cold Formed Steel Code Checks

Member	Shape	Code Check	Loc[in]	LC	Shear C...	Loc[in]	LC	Phi*Pn[lb]	Phi*Tn[lb]	Phi*Mn[lb-in]	Cb	Cm	Eqn
1	P21	UA300x22...	.891	8.5	7	.103	0	7	31228.065	33065.01	17761.94	1 .85	C5.2.2-2
2	P22A	UA300x22...	.819	0	7	.019	20	7	25233.668	33065.01	17761.94	1 .85	C5.2.2-1
3	P14A	UA300x22...	.780	0	7	.046	0	7	28258.062	33065.01	17761.94	1 .85	C5.2.2-3
4	P24A	UA300x22...	.743	0	7	.033	0	7	28258.062	33065.01	17761.94	1 .85	C5.2.2-3
5	P13B	UA300x22...	.723	20	7	.052	20	7	25233.668	33065.01	17761.94	1 .85	C3.3.2-1
6	H4	FBA275x1...	.715	0	7	.023	39.5	7	6814.335	16087.5	3481.013	1 1	C5.1.2-1
7	P23B	UA300x22...	.710	20	7	.048	20	7	25233.668	33065.01	17761.94	1 .85	C5.2.2-3
8	D1	FBA275x1...	.694	0	7	.001	50.214	1	4303.838	16087.5	2999.21	1 1	C5.2.2-1
9	D2	FBA275x1...	.614	0	7	.001	50.214	1	4303.838	16087.5	2999.21	1 1	C5.2.2-1
10	P12A	UA300x22...	.580	0	7	.016	20	7	25233.668	33065.01	17761.94	1 .85	C5.2.2-3
11	P11	UA300x22...	.559	8.5	7	.086	0	7	30096.378	33065.01	17761.94	1 .85	C5.2.2-3
12	P22B	UA300x22...	.547	0	7	.040	20	7	25233.668	33065.01	17761.94	1 .85	C5.2.2-1
13	P24B	UA300x22...	.501	0	7	.034	0	7	28258.062	33065.01	17761.94	1 .85	C5.2.2-3
14	P14B	UA300x22...	.442	0	7	.046	0	7	28258.062	33065.01	17761.94	1 .85	C5.2.2-3

Envelope AISI S100-12: LRFD Cold Formed Steel Code Checks (Continued)

	Member	Shape	Code Check	Loc[in]	LC	Shear C...	Loc[in]	LC	Phi*Pn[lb]	Phi*Tn[lb]	Phi*Mn[lb-in]	Cb	Cm	Eqn
15	P23A	UA300x22...	.439	20	7	.024	20	7	25233.668	33065.01	17761.94	1	.85	C5.2.2-3
16	P13A	UA300x22...	.389	20	7	.027	20	7	25233.668	33065.01	17761.94	1	.85	C5.2.2-3
17	P31	UA300x22...	.333	12	2	.026	0	8	29078.254	33065.01	30814.279	1	.85	C5.2.2-1
18	P12B	UA300x22...	.327	0	7	.034	20	7	25233.668	33065.01	17761.94	1	.85	C5.2.2-3
19	P32B	UA300x22...	.301	18	8	.021	0	8	26083.942	33065.01	28589.395	1	.85	C5.2.2-1
20	H3	FBA275x1...	.289	39.5	7	.007	39.5	7	6814.335	16087.5	3466.938	1	1	C3.3.2-1
21	P32A	UA300x22...	.288	0	8	.021	0	8	26083.942	33065.01	28584.895	1	.85	C5.2.2-1
22	H1	FBA275x1...	.266	39.5	7	.006	39.5	7	6814.335	16087.5	3466.938	1	1	C3.3.2-1
23	P25	UA300x22...	.245	0	7	.040	0	7	30331.367	33065.01	17761.94	1	.85	C5.2.2-3
24	P15	UA300x22...	.244	0	7	.040	0	7	30331.367	33065.01	17761.94	1	.85	C5.2.2-3
25	P33B	UA300x22...	.244	20	8	.016	0	8	25233.668	33065.01	28599.832	1	.85	C5.2.2-3
26	H2	FBA275x1...	.230	39.5	7	.006	39.5	7	6814.335	16087.5	7031.25	1	1	C5.1.2-1
27	P33A	UA300x22...	.192	0	8	.016	0	8	26881.33	33065.01	28582.479	1	.85	C5.2.2-3
28	P34B	UA300x22...	.149	18	8	.011	0	8	26083.942	33065.01	28614.606	1	.85	C5.2.2-3
29	P34A	UA300x22...	.096	18	8	.011	0	8	26083.942	33065.01	28580.977	1	.85	C5.2.2-3



24W x 120H - D Frame (1200lbs - ...

Joint Coordinates and Temperatures

	Label	X [in]	Y [in]	Temp [F]
1	D1	0	0	0
2	D2	0	120	0
3	D3	24	120	0
4	D4	24	0	0
5	D5	0	8	0
6	D5A	0	28.5	0
7	D6	24	8	0
8	D6A	24	28.5	0
9	D7	0	48.5	0
10	D7A	0	68.5	0
11	D8	24	48.5	0
12	D8A	24	68.5	0
13	D9	0	88.5	0
14	D9A	0	100.5	0
15	D10	24	88.5	0
16	D10A	24	100.5	0
17	D11	0	112.5	0
18	D12	24	112.5	0
19	D13	104	120	0
20	D14	104	0	0
21	D15	200	120	0
22	D16	200	0	0
23	D17	296	120	0
24	D18	296	0	0
25	D21	105.5	120	0
26	D22	198.5	120	0
27	D23	201.5	120	0
28	D24	294.5	120	0
29	D25	105.5	84	0
30	D26	198.5	84	0
31	D27	201.5	84	0
32	D28	294.5	84	0
33	D29	105.5	48	0
34	D30	198.5	48	0
35	D31	201.5	48	0
36	D32	294.5	48	0
37	D33	105.5	12	0
38	D34	198.5	12	0
39	D35	201.5	12	0
40	D36	294.5	12	0
41	D37	104	84	0
42	D38	104	48	0
43	D39	104	12	0
44	D40	200	84	0
45	D40A	200	102	0
46	D41	200	48	0
47	D41A	200	66	0
48	D42	200	12	0
49	D42A	200	30	0
50	D43	296	84	0
51	D44	296	48	0
52	D45	296	12	0

Joint Boundary Conditions

	Joint Label	X [k/in]	Y [k/in]	Rotation[k-ft/rad]
1	D1	Reaction	Reaction	
2	D4	Reaction	Reaction	
3	D14	Reaction	Reaction	
4	D16	Reaction	Reaction	
5	D18	Reaction	Reaction	
6	D21			S71.96
7	D23			S71.96
8	D22			S71.96
9	D24			S71.96
10	D25			S71.96
11	D27			S71.96
12	D26			S71.96
13	D28			S71.96
14	D29			S71.96
15	D31			S71.96
16	D30			S71.96
17	D32			S71.96
18	D33			S71.96
19	D35			S71.96
20	D34			S71.96
21	D36			S71.96

Member Primary Data

	Label	I Joint	J Joint	Rotate(deg)	Section/Shape	Type	Design List	Material	Design Rules
1	P5	D17	D18	180	UC	Column	None	A570_Gr55	Typical
2	P4	D13	D14	180	UC	Column	None	A570_Gr55	Typical
3	P34A	D40	D40A	180	UC	Column	None	A570_Gr55	Typical
4	P34B	D40A	D15	180	UC	Column	None	A570_Gr55	Typical
5	P33A	D41	D41A	180	UC	Column	None	A570_Gr55	Typical
6	P33B	D41A	D40	180	UC	Column	None	A570_Gr55	Typical
7	P32A	D42	D42A	180	UC	Column	None	A570_Gr55	Typical
8	P32B	D42A	D41	180	UC	Column	None	A570_Gr55	Typical
9	P31	D16	D42	180	UC	Column	None	A570_Gr55	Typical
10	P25	D12	D3	270	UC	Column	None	A570_Gr55	Typical
11	P24A	D10	D10A	270	UC	Column	None	A570_Gr55	Typical
12	P24B	D10A	D12	270	UC	Column	None	A570_Gr55	Typical
13	P23A	D8	D8A	270	UC	Column	None	A570_Gr55	Typical
14	P23B	D8A	D10	270	UC	Column	None	A570_Gr55	Typical
15	P22A	D6	D6A	270	UC	Column	None	A570_Gr55	Typical
16	P22B	D6A	D8	270	UC	Column	None	A570_Gr55	Typical
17	P21	D4	D6	270	UC	Column	None	A570_Gr55	Typical
18	P15	D11	D2	90	UC	Column	None	A570_Gr55	Typical
19	P14A	D9	D9A	90	UC	Column	None	A570_Gr55	Typical
20	P14B	D9A	D11	90	UC	Column	None	A570_Gr55	Typical
21	P13A	D7	D7A	90	UC	Column	None	A570_Gr55	Typical
22	P13B	D7A	D9	90	UC	Column	None	A570_Gr55	Typical
23	P12A	D5	D5A	90	UC	Column	None	A570_Gr55	Typical
24	P12B	D5A	D7	90	UC	Column	None	A570_Gr55	Typical
25	P11	D1	D5	90	UC	Column	None	A570_Gr55	Typical
26	H4	D11	D12	90	UWh	Beam	None	A570_Gr55	Typical
27	H3	D9	D10	90	UWh	Beam	None	A570_Gr55	Typical
28	H2	D7	D8	90	UWh	Beam	None	A570_Gr55	Typical
29	H1	D5	D6	90	UWh	Beam	None	A570_Gr55	Typical
30	SB42	D24	D23		FBts	Beam	Tube	A570 Gr. 55	Typical

Member Primary Data (Continued)

	Label	I Joint	J Joint	Rotate(deg)	Section/Shape	Type	Design List	Material	Design Rules
31	SB41	D22	D21		FBts	Beam	Tube	A570 Gr. 55	Typical
32	SB32	D28	D27		FBts	Beam	Tube	A570 Gr. 55	Typical
33	SB31	D26	D25		FBts	Beam	Tube	A570 Gr. 55	Typical
34	SB22	D32	D31		FBts	Beam	Tube	A570 Gr. 55	Typical
35	SB21	D30	D29		FBts	Beam	Tube	A570 Gr. 55	Typical
36	SB12	D36	D35		FBts	Beam	Tube	A570 Gr. 55	Typical
37	SB11	D34	D33		FBts	Beam	Tube	A570 Gr. 55	Typical
38	LB16	D17	D24		RIGID	None	None	RIGID	Typical
39	LB15	D23	D15		RIGID	None	None	RIGID	Typical
40	LB14	D15	D22		RIGID	None	None	RIGID	Typical
41	LB13	D21	D13		RIGID	None	None	RIGID	Typical
42	LB12	D43	D28		RIGID	None	None	RIGID	Typical
43	LB11	D27	D40		RIGID	None	None	RIGID	Typical
44	LB10	D40	D26		RIGID	None	None	RIGID	Typical
45	LB9	D25	D37		RIGID	None	None	RIGID	Typical
46	LB8	D44	D32		RIGID	None	None	RIGID	Typical
47	LB7	D31	D41		RIGID	None	None	RIGID	Typical
48	LB6	D41	D30		RIGID	None	None	RIGID	Typical
49	LB5	D29	D38		RIGID	None	None	RIGID	Typical
50	LB4	D45	D36		RIGID	None	None	RIGID	Typical
51	LB3	D35	D42		RIGID	None	None	RIGID	Typical
52	LB2	D42	D34		RIGID	None	None	RIGID	Typical
53	LB1	D33	D39		RIGID	None	None	RIGID	Typical
54	D2	D9	D8	90	UWd	VBrace	None	A570_Gr55	Typical
55	D1	D7	D6	90	UWd	VBrace	None	A570_Gr55	Typical

Member Advanced Data

	Label	I Release	J Release	I Offset[in]	J Offset[in]	T/C Only	Physical	Defl Rati...	TOM	Inactive
1	P5						Yes	** NA **	Yes	Exclude
2	P4						Yes	** NA **	Yes	Exclude
3	P34A						Yes	** NA **	Yes	
4	P34B						Yes	** NA **	Yes	
5	P33A						Yes	** NA **	Yes	
6	P33B						Yes	** NA **	Yes	
7	P32A						Yes	** NA **	Yes	
8	P32B						Yes	** NA **	Yes	
9	P31						Yes	** NA **	Yes	
10	P25						Yes	** NA **	Yes	
11	P24A						Yes	** NA **	Yes	
12	P24B						Yes	** NA **	Yes	
13	P23A						Yes	** NA **	Yes	
14	P23B						Yes	** NA **	Yes	
15	P22A						Yes	** NA **	Yes	
16	P22B						Yes	** NA **	Yes	
17	P21						Yes	** NA **	Yes	
18	P15						Yes	** NA **	Yes	
19	P14A						Yes	** NA **	Yes	
20	P14B						Yes	** NA **	Yes	
21	P13A						Yes	** NA **	Yes	
22	P13B						Yes	** NA **	Yes	
23	P12A						Yes	** NA **	Yes	
24	P12B						Yes	** NA **	Yes	
25	P11						Yes	** NA **	Yes	
26	H4		PIN				Yes		Yes	
27	H3	PIN					Yes		Yes	

Member Advanced Data (Continued)

	Label	I Release	J Release	I Offset[in]	J Offset[in]	T/C Only	Physical	Defl Rati...	TOM	Inactive
28	H2		PIN				Yes		Yes	
29	H1	PIN					Yes		Yes	
30	SB42	PIN	PIN				Yes		Yes	
31	SB41	PIN	PIN				Yes		Yes	Exclude
32	SB32	PIN	PIN				Yes		Yes	
33	SB31	PIN	PIN				Yes		Yes	Exclude
34	SB22	PIN	PIN				Yes		Yes	
35	SB21	PIN	PIN				Yes		Yes	Exclude
36	SB12	PIN	PIN				Yes		Yes	
37	SB11	PIN	PIN				Yes		Yes	Exclude
38	LB16						Yes	** NA **		Exclude
39	LB15						Yes	** NA **		Exclude
40	LB14						Yes	** NA **		Exclude
41	LB13						Yes	** NA **		Exclude
42	LB12						Yes	** NA **		Exclude
43	LB11						Yes	** NA **		Exclude
44	LB10						Yes	** NA **		Exclude
45	LB9						Yes	** NA **		Exclude
46	LB8						Yes	** NA **		Exclude
47	LB7						Yes	** NA **		Exclude
48	LB6						Yes	** NA **		Exclude
49	LB5						Yes	** NA **		Exclude
50	LB4						Yes	** NA **		Exclude
51	LB3						Yes	** NA **		Exclude
52	LB2						Yes	** NA **		Exclude
53	LB1						Yes	** NA **		Exclude
54	D2	PIN	PIN	3.875	3.875		Yes	** NA **	Yes	
55	D1	PIN	PIN	3.875	3.875		Yes	** NA **	Yes	

Cold Formed Steel Design Parameters

	Label	Shape	Length...	Lb-out[in]	Lb-in[in]	Lcomp to...	Lcom..L-tor...	K-out	K-in	Cm	Cb	R	a[in]	Out s...	In sw...
1	P5	UC	120	36	36	36	36								
2	P4	UC	120	36	36	36	36								
3	P34A	UC	18	22	31.5	31.5	31.5	1	1					Yes	Yes
4	P34B	UC	18	22	31.5	31.5	31.5	1	1					Yes	Yes
5	P33A	UC	18	35	31.5	31.5	31.5	1	1						Yes
6	P33B	UC	18	35	31.5	31.5	31.5	1	1						Yes
7	P32A	UC	18	35.5	31.5	31.5	31.5	1	1						Yes
8	P32B	UC	18	35.5	31.5	31.5	31.5	1	1						Yes
9	P31	UC	12	7	7.5	7.5	7.5	1	1					Yes	Yes
10	P25	UC	7.5	7.5	7.5	7.5	7.5	1	1					Yes	Yes
11	P24A	UC	12	31.5	22	22	22	1	1					Yes	Yes
12	P24B	UC	12	31.5	22	22	22	1	1					Yes	Yes
13	P23A	UC	20	31.5	35	35	35	1	1					Yes	
14	P23B	UC	20	31.5	35	35	35	1	1					Yes	
15	P22A	UC	20.5	31.5	35.5	35.5	35.5	1	1					Yes	
16	P22B	UC	20	31.5	35.5	35.5	35.5	1	1					Yes	
17	P21	UC	8	7.5	7	7	7	1	1					Yes	Yes
18	P15	UC	7.5	7.5	7.5	7.5	7.5	1	1					Yes	Yes
19	P14A	UC	12	31.5	22	22	22	1	1					Yes	Yes
20	P14B	UC	12	31.5	22	22	22	1	1					Yes	Yes
21	P13A	UC	20	31.5	35	35	35	1	1					Yes	
22	P13B	UC	20	31.5	35	35	35	1	1					Yes	
23	P12A	UC	20.5	31.5	35.5	35.5	35.5	1	1					Yes	
24	P12B	UC	20	31.5	35.5	35.5	35.5	1	1					Yes	

Cold Formed Steel Design Parameters (Continued)

	Label	Shape	Length...	Lb-out[in]	Lb-in[in]	Lcomp to...	Lcom...L-tor...	K-out	K-in	Cm	Cb	R	a[in]	Out s...	In sw...
25	P11	UC	8	7.5	7	7	7	1	1					Yes	Yes
26	H4	UWh	24			Lb out									
27	H3	UWh	24			Lb out									
28	H2	UWh	24			Lb out									
29	H1	UWh	24			Lb out									
30	D2	UWd	46.648			Lb out									
31	D1	UWd	47.077			Lb out									

Hot Rolled Steel Design Parameters

	Label	Shape	Length[in]	Lb-out[in]	Lb-in[in]	Lcomp top[in]	Lcomp bot[in]	L-torqu...	K-out	K-in	Cb	Function
1	SB42	FBts	93			Lb out						Lateral
2	SB41	FBts	93			Lb out						Lateral
3	SB32	FBts	93			Lb out						Lateral
4	SB31	FBts	93			Lb out						Lateral
5	SB22	FBts	93			Lb out						Lateral
6	SB21	FBts	93			Lb out						Lateral
7	SB12	FBts	93			Lb out						Lateral
8	SB11	FBts	93			Lb out						Lateral

Member Point Loads (BLC 1 : DL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-15	%100
2	P25	Y	-15	%100
3	P13B	Y	-15	15.5
4	P23B	Y	-15	15.5
5	P12B	Y	-15	19.5
6	P22B	Y	-15	19.5
7	P12A	Y	-15	4
8	P22A	Y	-15	4

Member Point Loads (BLC 2 : #1/ #2 / #5 - PL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-517.5	%100
2	P25	Y	-517.5	%100
3	P13B	Y	-517.5	15.5
4	P23B	Y	-517.5	15.5
5	P12B	Y	-517.5	19.5
6	P22B	Y	-517.5	19.5
7	P12A	Y	-517.5	4
8	P22A	Y	-517.5	4

Member Point Loads (BLC 3 : #6a - (0.67)PL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-346.725	%100
2	P25	Y	-346.725	%100
3	P13B	Y	-346.725	15.5
4	P23B	Y	-346.725	15.5
5	P12B	Y	-346.725	19.5
6	P22B	Y	-346.725	19.5
7	P12A	Y	-346.725	4
8	P22A	Y	-346.725	4

Member Point Loads (BLC 4 : #6a - (0.67)PL - horiz - Trans)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	X	87.8	%100
2	P25	X	87.8	%100
3	P13B	X	62.2	15.5
4	P23B	X	62.2	15.5
5	P12B	X	40.2	19.5
6	P22B	X	40.2	19.5
7	P12A	X	18.3	4
8	P22A	X	18.3	4

Member Point Loads (BLC 5 : #6b - (1)PL - horiz - Trans)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	X	89.9	%100
2	P25	X	89.9	%100

Member Point Loads (BLC 6 : #5 - (1)PL - horiz - Trans)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	X	131	%100
2	P25	X	131	%100
3	P13B	X	92.8	15.5
4	P23B	X	92.8	15.5
5	P12B	X	60	19.5
6	P22B	X	60	19.5
7	P12A	X	27.3	4
8	P22A	X	27.3	4

Member Point Loads (BLC 7 : #6b - (1)PL)

	Member Label	Direction	Magnitude[lb,lb-in]	Location[in,%]
1	P15	Y	-517.5	%100
2	P25	Y	-517.5	%100

Member Distributed Loads (BLC 1 : DL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...]	Start Location[in,%]	End Location[in,%]
1	SB41	Y	-1.95	-1.95	0	0
2	SB42	Y	-1.95	-1.95	0	0
3	SB31	Y	-1.95	-1.95	0	0
4	SB32	Y	-1.95	-1.95	0	0
5	SB21	Y	-1.95	-1.95	0	0
6	SB22	Y	-1.95	-1.95	0	0
7	SB11	Y	-1.95	-1.95	0	0
8	SB12	Y	-1.95	-1.95	0	0

Member Distributed Loads (BLC 2 : #1/ #2 / #5 - PL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...]	Start Location[in,%]	End Location[in,%]
1	SB41	Y	-66.774	-66.774	0	0
2	SB42	Y	-66.774	-66.774	0	0
3	SB31	Y	-66.774	-66.774	0	0
4	SB32	Y	-66.774	-66.774	0	0
5	SB21	Y	-66.774	-66.774	0	0
6	SB22	Y	-66.774	-66.774	0	0
7	SB11	Y	-66.774	-66.774	0	0
8	SB12	Y	-66.774	-66.774	0	0

Member Distributed Loads (BLC 3 : #6a - (0.67)PL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...	Start Location[in, %]	End Location[in, %]
1	SB41	Y	-44.739	-44.739	0	0
2	SB42	Y	-44.739	-44.739	0	0
3	SB31	Y	-44.739	-44.739	0	0
4	SB32	Y	-44.739	-44.739	0	0
5	SB21	Y	-44.739	-44.739	0	0
6	SB22	Y	-44.739	-44.739	0	0
7	SB11	Y	-44.739	-44.739	0	0
8	SB12	Y	-44.739	-44.739	0	0

Member Distributed Loads (BLC 7 : #6b - (1)PL)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...	Start Location[in, %]	End Location[in, %]
1	SB41	Y	-66.774	-66.774	0	0
2	SB42	Y	-66.774	-66.774	0	0

Member Distributed Loads (BLC 8 : #6a - (0.67)PL - horiz - Long)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...	Start Location[in, %]	End Location[in, %]
1	SB41	X	31.8	31.8	0	0
2	SB42	X	31.8	31.8	0	0
3	SB31	X	22.6	22.6	0	0
4	SB32	X	22.6	22.6	0	0
5	SB21	X	14.6	14.6	0	0
6	SB22	X	14.6	14.6	0	0
7	SB11	X	6.6	6.6	0	0
8	SB12	X	6.6	6.6	0	0

Member Distributed Loads (BLC 9 : #6b - (1)PL - horiz - Long)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...	Start Location[in, %]	End Location[in, %]
1	SB41	X	32.6	32.6	0	0
2	SB42	X	32.6	32.6	0	0

Member Distributed Loads (BLC 10 : #5 - (1)PL - horiz - Long)

	Member Label	Direction	Start Magnitude[lb/ft,F,ksf]	End Magnitude[lb...	Start Location[in, %]	End Location[in, %]
1	SB41	X	47.5	47.5	0	0
2	SB42	X	47.5	47.5	0	0
3	SB31	X	33.7	33.7	0	0
4	SB32	X	33.7	33.7	0	0
5	SB21	X	21.8	21.8	0	0
6	SB22	X	21.8	21.8	0	0
7	SB11	X	9.9	9.9	0	0
8	SB12	X	9.9	9.9	0	0

Joint Loads and Enforced Displacements (BLC 11 : Notional (+Xq) Lat All Shlvs)

	Joint Label	L,D,M	Direction	Magnitude[(lb,lb-in), (in,rad), (lb*s^...
1	D2	L	X	2.5
2	D3	L	X	2.5
3	D15	L	X	2.5
4	D40	L	X	2.5
5	D41	L	X	2.5
6	D42	L	X	2.5

Basic Load Cases

	BLC Description	Category	X Gravity	Y Gravity	Joint	Point	Distributed
1	DL	DL		-1		8	8
2	#1/ #2 / #5 - PL	LL				8	8
3	#6a - (0.67)PL	LL				8	8
4	#6a - (0.67)PL - horiz - Trans	EL	.394			8	
5	#6b - (1)PL - horiz - Trans	EL	.394			2	
6	#5 - (1)PL - horiz - Trans	EL	.394			8	
7	#6b - (1)PL	LL				2	2
8	#6a - (0.67)PL - horiz - Long	EL	.098				8
9	#6b - (1)PL - horiz - Long	EL	.098				2
10	#5 - (1)PL - horiz - Long	EL	.098				8
11	Notional (+Xg) Lat All Shlvs	NLX	.004		6		

Load Combinations

	Description	So...	P...	S...	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..	BLCFac..
1	RMI - LC #1	Yes	Y		1	1.4	2	1.2	11	1										
2	RMI - LC #2	Yes	Y		1	1.2	2	1.4	11	1										
3	RMI - LC #6a - Trans	Yes	Y		1	.58	3	.58	4	1										
4	RMI - LC #6a - Long	Yes	Y		1	.58	3	.58	8	1										
5	RMI - LC #6b - Trans	Yes	Y		1	.58	7	.58	5	1										
6	RMI - LC #6b - Long	Yes	Y		1	.58	7	.58	9	1										
7	RMI - LC #5 - Trans	Yes	Y		1	1.52	2	1.17	6	1										
8	RMI - LC #5 - Long	Yes	Y		1	1.52	2	1.17	10	1										

Envelope Joint Reactions

	Joint		X [lb]	LC	Y [lb]	LC	Moment [lb-in]	LC
1	D33	max	0	8	0	8	13817.408	8
2		min	0	1	0	1	605.954	5
3	D36	max	0	8	0	8	12606.373	8
4		min	0	1	0	1	-632.528	2
5	D32	max	0	8	0	8	12573.961	8
6		min	0	1	0	1	92.743	1
7	D29	max	0	8	0	8	12510.599	8
8		min	0	1	0	1	24.539	2
9	D35	max	0	8	0	8	12180.535	8
10		min	0	1	0	1	64.516	1
11	D34	max	0	8	0	8	12180.535	8
12		min	0	1	0	1	64.516	1
13	D31	max	0	8	0	8	11379.859	8
14		min	0	1	0	1	55.098	1
15	D30	max	0	8	0	8	11379.859	8
16		min	0	1	0	1	55.098	1
17	D25	max	0	8	0	8	9457.627	8
18		min	0	1	0	1	88.278	1
19	D28	max	0	8	0	8	9365.569	8
20		min	0	1	0	1	-12.219	2
21	D27	max	0	8	0	8	8662.778	8
22		min	0	1	0	1	38.018	1
23	D26	max	0	8	0	8	8662.778	8
24		min	0	1	0	1	38.018	1
25	D21	max	0	8	0	8	6233.328	8
26		min	0	1	0	1	137.177	1
27	D24	max	0	8	0	8	6014.091	8
28		min	0	1	0	1	-102.44	2

Envelope Joint Reactions (Continued)

	Joint		X [lb]	LC	Y [lb]	LC	Moment [lb-in]	LC
29	D23	max	0	8	0	8	5152.309	8
30		min	0	1	0	1	21.273	1
31	D22	max	0	8	0	8	5152.309	8
32		min	0	1	0	1	21.273	1
33	D1	max	-2.584	6	2977.968	2	0	8
34		min	-288.985	7	-693.834	3	0	1
35	D4	max	.666	2	4853.816	7	0	8
36		min	-353.23	7	361.866	6	0	1
37	D14	max	-28.936	5	1563.024	2	0	8
38		min	-573.638	8	206.119	5	0	1
39	D16	max	-5.46	2	3105.156	2	0	8
40		min	-913.007	8	400.279	6	0	1
41	D18	max	162.74	2	1563.005	2	0	8
42		min	-288.759	8	198.639	6	0	1
43	Totals:	max	-16.222	2	12232.185	2		
44		min	-1780.388	8	1510.037	6		

Envelope Joint Displacements

	Joint		X [in]	LC	Y [in]	LC	Rotation [rad]	LC
1	D1	max	0	8	0	8	2.286e-04	2
2		min	0	1	0	1	-4.242e-03	7
3	D2	max	.319	7	.003	3	5.097e-05	8
4		min	-.018	8	-.013	2	-8.512e-03	7
5	D3	max	.32	7	-.003	6	6.107e-05	8
6		min	-.018	8	-.016	7	-9.197e-03	7
7	D4	max	0	8	0	8	2.462e-04	2
8		min	0	1	0	1	-4.635e-03	7
9	D5	max	.033	7	0	3	2.431e-04	2
10		min	-.002	2	-.002	2	-3.429e-03	7
11	D5A	max	.065	7	.002	3	2.693e-04	2
12		min	-.007	2	-.005	2	-1.713e-04	3
13	D6	max	.035	7	0	6	2.422e-04	2
14		min	-.002	2	-.003	7	-3.585e-03	7
15	D6A	max	.069	7	0	6	2.549e-04	2
16		min	-.007	2	-.007	7	-1.408e-04	5
17	D7	max	.052	7	.003	3	1.07e-03	7
18		min	-.012	2	-.008	2	3.548e-05	6
19	D7A	max	.039	7	.003	3	1.555e-04	2
20		min	-.016	2	-.01	2	-3.133e-04	7
21	D8	max	.055	7	-.001	6	9.609e-04	7
22		min	-.012	2	-.011	7	4.339e-05	6
23	D8A	max	.046	7	-.002	6	1.54e-04	2
24		min	-.016	2	-.013	7	-4.229e-04	7
25	D9	max	.083	7	.004	3	8.753e-05	8
26		min	-.018	2	-.011	2	-4.679e-03	7
27	D9A	max	.159	7	.003	3	7.024e-05	8
28		min	-.018	2	-.012	2	-7.492e-03	7
29	D10	max	.085	7	-.002	6	8.109e-05	8
30		min	-.018	2	-.014	7	-4.044e-03	7
31	D10A	max	.154	7	-.002	6	6.578e-05	8
32		min	-.018	2	-.015	7	-7.115e-03	7
33	D11	max	.256	7	.003	3	5.098e-05	8
34		min	-.017	8	-.013	2	-8.175e-03	7
35	D12	max	.252	7	-.002	6	6.107e-05	8
36		min	-.017	2	-.015	7	-8.859e-03	7

Envelope Joint Displacements (Continued)

	Joint		X [in]	LC	Y [in]	LC	Rotation [rad]	LC
37	D13	max	1.688	8	-.001	5	-1.589e-04	1
38		min	.023	1	-.007	2	-7.219e-03	8
39	D14	max	0	8	0	8	-7.769e-04	5
40		min	0	1	0	1	-1.756e-02	8
41	D15	max	1.674	8	-.003	5	-2.464e-05	1
42		min	.008	1	-.014	2	-5.967e-03	8
43	D16	max	0	8	0	8	-8.956e-05	1
44		min	0	1	0	1	-1.66e-02	8
45	D17	max	1.659	8	-.001	6	1.186e-04	2
46		min	-.009	2	-.007	2	-6.965e-03	8
47	D18	max	0	8	0	8	1.161e-03	2
48		min	0	1	0	1	-1.54e-02	8
49	D21	max	1.688	8	-.002	5	-1.589e-04	1
50		min	.023	1	-.017	8	-7.219e-03	8
51	D22	max	1.674	8	.002	6	-2.464e-05	1
52		min	.008	1	-.014	2	-5.967e-03	8
53	D23	max	1.674	8	-.003	5	-2.464e-05	1
54		min	.008	1	-.021	8	-5.967e-03	8
55	D24	max	1.659	8	.005	4	1.186e-04	2
56		min	-.009	2	-.007	2	-6.965e-03	8
57	D25	max	1.336	8	-.002	5	-1.022e-04	1
58		min	.021	1	-.022	8	-1.095e-02	8
59	D26	max	1.322	8	.007	4	-4.403e-05	1
60		min	.007	1	-.012	2	-1.003e-02	8
61	D27	max	1.322	8	-.003	5	-4.403e-05	1
62		min	.007	1	-.025	8	-1.003e-02	8
63	D28	max	1.307	8	.011	8	1.415e-05	2
64		min	-.01	2	-.006	2	-1.085e-02	8
65	D29	max	.822	8	-.001	5	-2.842e-05	2
66		min	.019	1	-.025	8	-1.449e-02	8
67	D30	max	.807	8	.013	8	-6.381e-05	1
68		min	.004	1	-.008	2	-1.318e-02	8
69	D31	max	.807	8	-.002	5	-6.381e-05	1
70		min	.004	1	-.027	8	-1.318e-02	8
71	D32	max	.792	8	.018	8	-1.074e-04	1
72		min	-.013	2	-.004	2	-1.456e-02	8
73	D33	max	.208	8	-.001	5	-7.017e-04	5
74		min	.009	5	-.025	8	-1.6e-02	8
75	D34	max	.195	8	.019	8	-7.471e-05	1
76		min	.001	1	-.002	2	-1.411e-02	8
77	D35	max	.195	8	-.001	5	-7.471e-05	1
78		min	.001	1	-.023	8	-1.411e-02	8
79	D36	max	.184	8	.021	8	7.325e-04	2
80		min	-.013	2	-.002	2	-1.46e-02	8
81	D37	max	1.336	8	-.001	5	-1.022e-04	1
82		min	.021	1	-.006	2	-1.095e-02	8
83	D38	max	.822	8	0	5	-2.842e-05	2
84		min	.019	1	-.004	2	-1.449e-02	8
85	D39	max	.208	8	0	5	-7.017e-04	5
86		min	.009	5	-.001	2	-1.6e-02	8
87	D40	max	1.322	8	-.002	5	-4.403e-05	1
88		min	.007	1	-.012	2	-1.003e-02	8
89	D40A	max	1.516	8	-.002	5	-4.336e-05	1
90		min	.007	1	-.013	2	-1.033e-02	8
91	D41	max	.807	8	-.001	6	-6.381e-05	1
92		min	.004	1	-.008	2	-1.318e-02	8
93	D41A	max	1.079	8	-.002	6	-6.955e-05	1

Envelope Joint Displacements (Continued)

	Joint		X [in]	LC	Y [in]	LC	Rotation [rad]	LC
94		min	.005	1	-.01	2	-1.514e-02	8
95	D42	max	.195	8	0	6	-7.471e-05	1
96		min	.001	1	-.002	2	-1.411e-02	8
97	D42A	max	.506	8	0	6	-9.171e-05	1
98		min	.003	1	-.005	2	-1.807e-02	8
99	D43	max	1.307	8	-.001	6	1.415e-05	2
100		min	-.01	2	-.006	2	-1.085e-02	8
101	D44	max	.792	8	0	6	-1.074e-04	1
102		min	-.013	2	-.004	2	-1.456e-02	8
103	D45	max	.184	8	0	6	7.325e-04	2
104		min	-.013	2	-.001	2	-1.46e-02	8

Envelope Maximum Member Section Forces

	Member		Axial[lb]	Loc[in]	LC	Shear[lb]	Loc[in]	LC	Moment[lb-in]	Loc[in]	LC
1	P34A	max	777.334	0	2	398.895	0	8	4049.329	0	8
2		min	225.124	18	4	1.545	18	1	-3128.472	18	8
3	P34B	max	774.204	0	2	397.242	0	8	-14.952	0	1
4		min	223.611	18	4	1.527	18	1	-10276.52	18	8
5	P33A	max	1554.659	0	2	604.241	0	8	8447.562	0	8
6		min	349.711	18	5	2.675	18	1	-2426.471	18	8
7	P33B	max	1551.529	0	2	601.819	0	8	-15.282	0	1
8		min	348.198	18	5	2.65	18	1	-13256.917	18	8
9	P32A	max	2331.994	0	2	755.832	0	8	12885.464	0	8
10		min	375.248	18	5	3.837	18	1	-717.205	18	8
11	P32B	max	2328.864	0	2	754.576	0	8	166.16	0	6
12		min	373.735	18	5	3.815	18	1	-14297.28	18	8
13	P31	max	3105.156	0	2	956.634	0	8	0	0	1
14		min	399.271	12	6	5.693	12	1	-11478.58	12	8
15	P25	max	743.804	0	2	137.176	0	7	1027.212	0	7
16		min	209.801	7.5	3	-.038	7.5	8	-.052	4.766	8
17	P24A	max	749.442	0	2	104.971	0	7	3549.856	0	7
18		min	211.869	12	4	.514	12	6	5.556	12	6
19	P24B	max	747.355	0	2	105.935	0	7	2294.317	0	7
20		min	210.861	12	4	.345	12	6	.112	12	8
21	P23A	max	1500.173	0	2	.588	0	8	1414.626	20	7
22		min	322.945	20	6	-62.853	20	7	-221.204	0	5
23	P23B	max	1496.695	0	2	.407	0	8	3046.667	20	7
24		min	213.492	20	4	-154.093	20	7	6.657	0	6
25	P22A	max	3628.843	0	7	-.123	0	6	5.96	20.5	8
26		min	340.716	20.5	6	-64.295	20.5	7	-2507.232	0	7
27	P22B	max	2996.053	0	7	-.419	0	6	160.743	20	7
28		min	330.335	20	6	-132.627	20	7	-1310.374	0	7
29	P21	max	4853.816	0	7	374.715	0	7	11.27	8	2
30		min	361.193	8	6	-1.411	8	2	-2995.896	8	7
31	P15	max	743.804	0	2	136.745	0	7	1023.981	0	7
32		min	209.801	7.5	3	-.032	7.5	8	-.036	5.234	8
33	P14A	max	749.167	0	2	169.117	0	7	3690.226	0	7
34		min	173.895	12	3	-.161	12	8	7.073	12	6
35	P14B	max	747.08	0	2	169.421	0	7	1664.935	0	7
36		min	172.887	12	3	-.32	12	8	-364.002	12	7
37	P13A	max	1488.915	0	2	.129	0	4	1612.711	20	7
38		min	-297.368	20	3	-82.694	20	7	-355.189	0	5
39	P13B	max	1485.438	0	2	-.145	0	4	3698.473	20	7
40		min	-508.849	20	3	-176.779	20	7	4.186	0	6
41	P12A	max	2973.557	0	2	-.497	0	6	14.752	20.5	8

Envelope Maximum Member Section Forces (Continued)

Member		Axial[lb]	Loc[in]	LC	Shear[lb]	Loc[in]	LC	Moment[lb-in]	Loc[in]	LC
42		min	-892.962	20.5	3	-57.492	20.5	-2318.175	0	7
43	P12B	max	2227.493	0	2	-.792	0	67.223	20	8
44		min	-1104.443	20	3	-118.104	20	-1260.781	0	7
45	P11	max	2977.968	0	2	290	0	0	0	1
46		min	-694.506	8	3	2.468	8	-2318.175	8	7
47	H4	max	.605	24	8	2.507	0	19.605	0	8
48		min	-32.67	0	7	-59.501	24	-1376.484	0	7
49	H3	max	-.83	24	8	1.914	0	593.706	24	7
50		min	-258.021	0	7	-22.634	24	-12.704	13.75	8
51	H2	max	-3.569	24	8	3.262	0	236.24	24	7
52		min	-672.007	0	7	-4.11	24	.567	18.75	6
53	H1	max	-2.741	24	6	3.036	0	591.868	24	7
54		min	-317.47	0	7	-21.686	24	-37.868	24	2
55	SB42	max	192.076	0	8	385.541	93	9014.708	46.5	2
56		min	-178.372	93	8	-385.536	0	-414.714	93	8
57	SB32	max	156.204	0	8	385.541	93	8932.12	46.5	2
58		min	-107.294	93	8	-385.536	0	-249.459	93	8
59	SB22	max	155.813	0	8	385.541	93	9108.062	46.5	2
60		min	-29.03	93	4	-385.536	0	-67.494	93	4
61	SB12	max	-3.131	0	5	385.541	93	8421.215	46.5	2
62		min	-297.52	93	8	-385.536	0	-691.734	93	8
63	D2	max	1171.481	38.898	7	1.285	0	8.328	0	1
64		min	.956	0	8	-1.285	38.898	-4.164	19.449	1
65	D1	max	1395.935	39.327	7	1.287	0	8.435	39.327	1
66		min	8.737	0	6	-1.287	39.327	-4.217	19.664	1

Envelope Member Section Deflections Service

	Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
1	P34A	1	max	-0.002	5	-0.007	1	NC	1
2			min	-0.012	2	-1.322	8	NC	1
3		2	max	-0.002	5	-0.007	1	NC	1
4			min	-0.012	2	-1.369	8	379.898	8
5		3	max	-0.002	5	-0.007	1	NC	1
6			min	-0.012	2	-1.418	8	186.695	8
7		4	max	-0.002	5	-0.007	1	NC	1
8			min	-0.012	2	-1.468	8	123.471	8
9		5	max	-0.002	5	-0.007	1	NC	1
10			min	-0.013	2	-1.516	8	92.7	8
11	P34B	1	max	-0.002	5	-0.007	1	NC	1
12			min	-0.013	2	-1.516	8	NC	1
13		2	max	-0.003	5	-0.008	1	NC	1
14			min	-0.013	2	-1.562	8	2682.069	8
15		3	max	-0.003	5	-0.008	1	NC	1
16			min	-0.013	2	-1.605	8	1832.785	8
17		4	max	-0.003	5	-0.008	1	NC	1
18			min	-0.013	2	-1.642	8	2244.28	8
19		5	max	-0.003	5	-0.008	1	NC	1
20			min	-0.014	2	-1.674	8	NC	1
21	P33A	1	max	-0.001	6	-0.004	1	NC	1
22			min	-0.008	2	-.807	8	NC	1
23		2	max	-0.001	6	-0.004	1	NC	1
24			min	-0.008	2	-.871	8	283.287	8
25		3	max	-0.001	6	-0.005	1	NC	1
26			min	-0.009	2	-.939	8	137.115	8
27		4	max	-0.002	6	-0.005	1	NC	1

Envelope Member Section Deflections Service (Continued)

	Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
28			min	-0.009	2	-1.009	8	89.455	8
29		5	max	-0.002	6	-0.005	1	NC	1
30			min	-.01	2	-1.079	8	66.329	8
31	P33B	1	max	-0.002	6	-0.005	1	NC	1
32			min	-.01	2	-1.079	8	NC	1
33		2	max	-0.002	6	-0.006	1	NC	1
34			min	-.01	2	-1.147	8	2360.384	8
35		3	max	-0.002	6	-0.006	1	NC	1
36			min	-.011	2	-1.212	8	1566.544	8
37		4	max	-0.002	6	-0.006	1	NC	1
38			min	-.011	2	-1.271	8	1873.154	8
39		5	max	-0.002	5	-0.007	1	NC	1
40			min	-.012	2	-1.322	8	NC	1
41	P32A	1	max	0	6	-0.001	1	NC	1
42			min	-0.002	2	-.195	8	NC	1
43		2	max	0	6	-0.001	1	NC	1
44			min	-0.003	2	-.265	8	258.529	8
45		3	max	0	6	-0.002	1	NC	1
46			min	-0.004	2	-.342	8	123.121	8
47		4	max	0	6	-0.002	1	NC	1
48			min	-0.005	2	-.423	8	79.216	8
49		5	max	0	6	-0.003	1	NC	1
50			min	-0.005	2	-.506	8	58.023	8
51	P32B	1	max	0	6	-0.003	1	NC	1
52			min	-0.005	2	-.506	8	NC	1
53		2	max	0	6	-0.003	1	NC	1
54			min	-0.006	2	-.588	8	2569.022	8
55		3	max	0	6	-0.003	1	NC	1
56			min	-0.007	2	-.668	8	1636.33	8
57		4	max	-0.001	6	-0.004	1	NC	1
58			min	-0.007	2	-.742	8	1895.989	8
59		5	max	-0.001	6	-0.004	1	NC	1
60			min	-0.008	2	-.807	8	NC	1
61	P31	1	max	0	8	0	1	NC	1
62			min	0	1	0	1	NC	1
63		2	max	0	6	0	1	NC	1
64			min	0	2	-.051	8	5137.05	8
65		3	max	0	6	0	1	NC	1
66			min	-0.001	2	-.101	8	3210.673	8
67		4	max	0	6	0	1	NC	1
68			min	-0.002	2	-.15	8	3669.366	8
69		5	max	0	6	-0.001	1	NC	1
70			min	-0.002	2	-.195	8	NC	1
71	P25	1	max	-0.002	6	.017	2	NC	1
72			min	-0.015	7	-.252	7	NC	1
73		2	max	-0.002	6	.017	8	NC	1
74			min	-0.015	7	-.269	7	444.99	7
75		3	max	-0.003	6	.018	8	NC	1
76			min	-0.015	7	-.286	7	220.941	7
77		4	max	-0.003	6	.018	8	NC	1
78			min	-0.016	7	-.303	7	146.498	7
79		5	max	-0.003	6	.018	8	NC	1
80			min	-0.016	7	-.32	7	109.451	7
81	P24A	1	max	-0.002	6	.018	2	NC	1
82			min	-0.014	7	-.085	7	NC	1
83		2	max	-0.002	6	.018	2	NC	1
84			min	-0.014	7	-.099	7	881.775	7

Envelope Member Section Deflections Service (Continued)

	Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
85		3	max	-.002	6	.018	2	NC	1
86			min	-.014	7	-.115	7	403.114	7
87		4	max	-.002	6	.018	2	NC	1
88			min	-.015	7	-.134	7	248.806	7
89		5	max	-.002	6	.018	2	NC	1
90			min	-.015	7	-.154	7	174.55	7
91	P24B	1	max	-.002	6	.018	2	NC	1
92			min	-.015	7	-.154	7	NC	1
93		2	max	-.002	6	.018	2	NC	1
94			min	-.015	7	-.176	7	537.469	7
95		3	max	-.002	6	.018	2	NC	1
96			min	-.015	7	-.2	7	259.672	7
97		4	max	-.002	6	.017	2	NC	1
98			min	-.015	7	-.226	7	168.053	7
99		5	max	-.002	6	.017	2	NC	1
100			min	-.015	7	-.252	7	122.877	7
101	P23A	1	max	-.001	6	.012	2	NC	1
102			min	-.011	7	-.055	7	2106.942	7
103		2	max	-.001	6	.013	2	NC	1
104			min	-.011	7	-.05	7	4016.14	5
105		3	max	-.001	6	.014	2	NC	1
106			min	-.012	7	-.047	7	8414.039	5
107		4	max	-.001	6	.015	2	NC	1
108			min	-.012	7	-.045	7	NC	1
109		5	max	-.002	6	.016	2	NC	1
110			min	-.013	7	-.046	7	NC	1
111	P23B	1	max	-.002	6	.016	2	NC	1
112			min	-.013	7	-.046	7	NC	1
113		2	max	-.002	6	.017	2	NC	1
114			min	-.013	7	-.049	7	5502.759	7
115		3	max	-.002	6	.017	2	NC	1
116			min	-.013	7	-.057	7	1813.686	7
117		4	max	-.002	6	.018	2	NC	1
118			min	-.014	7	-.068	7	875.6	7
119		5	max	-.002	6	.018	2	NC	1
120			min	-.014	7	-.085	7	501.668	7
121	P22A	1	max	0	6	.002	2	NC	1
122			min	-.003	7	-.035	7	NC	1
123		2	max	0	6	.003	2	NC	1
124			min	-.004	7	-.051	7	2870.993	7
125		3	max	0	6	.005	2	NC	4
126			min	-.005	7	-.061	7	2269.446	7
127		4	max	0	6	.006	2	NC	4
128			min	-.006	7	-.067	7	3202.156	7
129		5	max	0	6	.007	2	NC	3
130			min	-.007	7	-.069	7	3965.28	2
131	P22B	1	max	0	6	.007	2	NC	1
132			min	-.007	7	-.069	7	NC	1
133		2	max	0	6	.008	2	NC	1
134			min	-.008	7	-.068	7	8549.759	7
135		3	max	0	6	.01	2	NC	1
136			min	-.009	7	-.064	7	7711.48	7
137		4	max	0	6	.011	2	NC	1
138			min	-.01	7	-.06	7	NC	1
139		5	max	-.001	6	.012	2	NC	1
140			min	-.011	7	-.055	7	NC	1
141	P21	1	max	0	8	0	1	NC	1

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
142		min	0	1	0	1	NC	1
143	2	max	0	6	0	2	NC	1
144		min	0	7	-.01	7	NC	1
145	3	max	0	6	0	2	NC	1
146		min	-.001	7	-.019	7	7619.489	7
147	4	max	0	6	.001	2	NC	1
148		min	-.002	7	-.027	7	8708.398	7
149	5	max	0	6	.002	2	NC	1
150		min	-.003	7	-.035	7	NC	1
151	P15	max	.003	3	.017	8	NC	1
152		min	-.013	2	-.256	7	NC	1
153	2	max	.003	3	.017	8	NC	1
154		min	-.013	2	-.271	7	481.664	7
155	3	max	.003	3	.017	8	NC	1
156		min	-.013	2	-.287	7	239.018	7
157	4	max	.003	3	.018	8	NC	1
158		min	-.013	2	-.303	7	158.417	7
159	5	max	.003	3	.018	8	NC	1
160		min	-.013	2	-.319	7	118.321	7
161	P14A	max	.004	3	.018	2	NC	1
162		min	-.011	2	-.083	7	NC	1
163	2	max	.004	3	.018	2	NC	1
164		min	-.012	2	-.098	7	768.389	7
165	3	max	.004	3	.018	2	NC	1
166		min	-.012	2	-.117	7	355.623	7
167	4	max	.003	3	.018	2	NC	1
168		min	-.012	2	-.137	7	222.304	7
169	5	max	.003	3	.018	2	NC	1
170		min	-.012	2	-.159	7	158.045	7
171	P14B	max	.003	3	.018	2	NC	1
172		min	-.012	2	-.159	7	NC	1
173	2	max	.003	3	.018	2	NC	1
174		min	-.012	2	-.182	7	515.904	7
175	3	max	.003	3	.018	2	NC	1
176		min	-.012	2	-.206	7	252.992	7
177	4	max	.003	3	.017	2	NC	1
178		min	-.012	2	-.231	7	166.397	7
179	5	max	.003	3	.017	8	NC	1
180		min	-.013	2	-.256	7	123.822	7
181	P13A	max	.003	3	.012	2	NC	1
182		min	-.008	2	-.052	7	1540.028	7
183	2	max	.003	3	.013	2	NC	1
184		min	-.008	2	-.047	7	2632.511	7
185	3	max	.003	3	.014	2	NC	1
186		min	-.009	2	-.042	7	5306.457	5
187	4	max	.003	3	.015	2	NC	1
188		min	-.009	2	-.039	7	NC	1
189	5	max	.003	3	.016	2	NC	1
190		min	-.01	2	-.039	7	NC	1
191	P13B	max	.003	3	.016	2	NC	1
192		min	-.01	2	-.039	7	NC	1
193	2	max	.003	3	.017	2	NC	1
194		min	-.01	2	-.042	7	6056.877	7
195	3	max	.003	3	.017	2	NC	1
196		min	-.011	2	-.05	7	1810.87	7
197	4	max	.003	3	.018	2	NC	1
198		min	-.011	2	-.063	7	828.541	7

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
199	5	max	.004	3	.018	2	NC	1
200		min	-.011	2	-.083	7	458.468	7
201	P12A	1	max	0	.002	2	NC	1
202		min	-.002	2	-.033	7	NC	1
203	2	max	0	3	.003	2	NC	1
204		min	-.002	2	-.048	7	3064.969	7
205	3	max	0	3	.005	2	NC	4
206		min	-.003	2	-.057	7	2416.318	7
207	4	max	.001	3	.006	2	NC	4
208		min	-.004	2	-.063	7	3399.527	7
209	5	max	.002	3	.007	2	NC	3
210		min	-.005	2	-.065	7	3769.599	2
211	P12B	1	max	.002	.007	2	NC	1
212		min	-.005	2	-.065	7	NC	1
213	2	max	.002	3	.009	2	NC	1
214		min	-.006	2	-.065	7	7770.423	7
215	3	max	.002	3	.01	2	NC	1
216		min	-.006	2	-.062	7	6639.311	7
217	4	max	.002	3	.011	2	NC	1
218		min	-.007	2	-.057	7	NC	1
219	5	max	.003	3	.012	2	NC	1
220		min	-.008	2	-.052	7	NC	1
221	P11	1	max	0	0	1	NC	1
222		min	0	1	0	1	NC	1
223	2	max	0	3	0	2	NC	1
224		min	0	2	-.009	7	NC	1
225	3	max	0	3	0	2	NC	1
226		min	0	2	-.017	7	8778.984	2
227	4	max	0	3	.001	2	NC	3
228		min	-.001	2	-.025	7	5813.972	2
229	5	max	0	3	.002	2	NC	3
230		min	-.002	2	-.033	7	4320.503	2
231	H4	1	max	.253	.003	3	NC	1
232		min	-.017	2	-.013	2	NC	1
233	2	max	.253	7	-.002	6	NC	1
234		min	-.017	2	-.034	7	813.073	7
235	3	max	.253	7	-.002	6	NC	1
236		min	-.017	2	-.042	7	711.478	7
237	4	max	.253	7	-.002	6	NC	1
238		min	-.017	2	-.033	7	1140.117	7
239	5	max	.253	7	-.002	6	NC	1
240		min	-.017	2	-.015	7	NC	1
241	H3	1	max	.083	.004	3	NC	1
242		min	-.018	2	-.011	2	NC	1
243	2	max	.083	7	.008	3	NC	1
244		min	-.018	2	-.012	2	2242.19	7
245	3	max	.084	7	.01	5	NC	1
246		min	-.018	2	-.012	2	1472.675	7
247	4	max	.084	7	.007	5	NC	1
248		min	-.018	2	-.012	2	1742.634	7
249	5	max	.084	7	-.002	6	NC	1
250		min	-.018	2	-.014	7	NC	1
251	H2	1	max	.053	.003	3	NC	1
252		min	-.012	2	-.008	2	NC	1
253	2	max	.053	7	.005	3	NC	1
254		min	-.012	2	-.007	2	3374.73	7
255	3	max	.053	7	.005	3	NC	1

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
256		min	-.012	2	-.007	2	2474.526	7
257	4	max	.054	7	.002	3	NC	1
258		min	-.012	2	-.007	2	3213.999	7
259	5	max	.054	7	-.001	6	NC	1
260		min	-.012	2	-.011	7	NC	1
261	H1	max	.033	7	0	3	NC	1
262		min	-.002	2	-.002	2	NC	1
263	2	max	.034	7	.01	7	NC	1
264		min	-.002	2	-.002	2	2157.753	7
265	3	max	.034	7	.015	7	NC	1
266		min	-.002	2	-.003	2	1431.745	7
267	4	max	.034	7	.012	7	NC	1
268		min	-.002	2	-.003	2	1707.915	7
269	5	max	.034	7	0	6	NC	1
270		min	-.002	2	-.003	7	NC	1
271	SB42	max	0	2	.007	2	NC	1
272		min	-1.667	8	-.005	4	NC	1
273	2	max	0	2	.084	2	4284.536	3
274		min	-1.667	8	.021	4	1242.062	2
275	3	max	0	2	.115	2	3077.579	4
276		min	-1.667	8	.033	4	885.287	2
277	4	max	0	2	.087	2	4423.458	4
278		min	-1.667	8	.025	3	1242.068	2
279	5	max	0	2	.021	8	NC	1
280		min	-1.667	8	.003	5	NC	1
281	SB32	max	.002	2	.006	2	NC	1
282		min	-1.316	8	-.011	8	NC	1
283	2	max	.002	2	.081	2	NC	5
284		min	-1.316	8	0	6	1256.582	2
285	3	max	.002	2	.113	2	NC	5
286		min	-1.316	8	.005	6	895.116	2
287	4	max	.002	2	.084	2	NC	5
288		min	-1.316	8	.005	5	1256.589	2
289	5	max	.002	2	.025	8	NC	1
290		min	-1.316	8	.003	5	NC	1
291	SB22	max	.004	2	.004	2	NC	1
292		min	-.801	8	-.018	8	NC	1
293	2	max	.004	2	.081	2	NC	5
294		min	-.801	8	-.001	6	1226.048	2
295	3	max	.004	2	.112	2	NC	5
296		min	-.801	8	.003	6	874.433	2
297	4	max	.004	2	.083	2	NC	5
298		min	-.801	8	.003	5	1226.054	2
299	5	max	.004	2	.027	8	NC	1
300		min	-.801	8	.002	5	NC	1
301	SB12	max	.006	2	.002	2	NC	1
302		min	-.191	8	-.021	8	NC	1
303	2	max	.006	2	.071	2	NC	5
304		min	-.191	8	-.002	6	1354.539	2
305	3	max	.006	2	.099	2	NC	5
306		min	-.191	8	.002	6	961.134	2
307	4	max	.006	2	.071	2	NC	5
308		min	-.19	8	.003	5	1354.547	2
309	5	max	.007	2	.023	8	NC	1
310		min	-.19	8	.001	5	NC	1
311	D2	max	.042	7	.053	7	NC	1
312		min	0	6	-.021	2	NC	1

Envelope Member Section Deflections Service (Continued)

Member	Sec		x [in]	LC	y [in]	LC	L/y' Ratio	LC
313	2	max	.041	7	.049	7	NC	1
314		min	0	6	-.02	2	NC	1
315	3	max	.04	7	.045	7	NC	1
316		min	0	6	-.018	2	NC	1
317	4	max	.039	7	.042	7	NC	1
318		min	0	6	-.017	2	NC	1
319	5	max	.038	7	.038	7	NC	1
320		min	0	6	-.015	2	NC	1
321	D1	max	.026	7	.049	7	NC	1
322		min	0	6	-.014	2	NC	1
323	2	max	.025	7	.048	7	NC	1
324		min	0	6	-.011	2	NC	1
325	3	max	.023	7	.046	7	NC	1
326		min	0	6	-.009	2	NC	1
327	4	max	.022	7	.045	7	NC	1
328		min	0	6	-.006	2	NC	1
329	5	max	.02	7	.043	7	NC	1
330		min	0	6	-.003	2	NC	1

Envelope Beam Deflection Checks

Be...	Design Rule	Span	Defl [in]	Ratio	LC	Defl [in]	Ratio	LC	Defl [in]	Ratio	LC
No Data to Print ...											

Envelope AISI S100-12: LRFD Cold Formed Steel Code Checks

	Member	Shape	Code Check	Loc[in]	LC	Shear C...	Loc[in]	LC	Phi*Pn[lb]	Phi*Tn[lb]	Phi*Mn[lb-in]	Cb	Cm	Eqn
1	P32B	UA300x22...	.825	18	8	.123	0	8	19606.003	25294.5	19789.464	1	.85	C5.2.2-3
2	P32A	UA300x22...	.754	0	8	.124	0	8	19606.003	25294.5	19788.314	1	.85	C5.2.2-3
3	P33B	UA300x22...	.738	18	8	.098	0	8	19606.003	25294.5	19792.453	1	.85	C5.2.2-3
4	P31	UA300x22...	.621	12	8	.156	0	8	21679.519	25294.5	23091.602	1	.85	C5.2.2-3
5	P34B	UA300x22...	.553	18	8	.065	0	8	19606.003	25294.5	19795.365	1	.85	C5.2.2-3
6	P33A	UA300x22...	.495	0	8	.099	0	8	19606.003	25294.5	19788.127	1	.85	C5.2.2-3
7	P21	UA300x22...	.422	8	7	.043	0	7	23116.815	25294.5	14125.047	1	.85	C5.2.2-2
8	H4	FBA275x1...	.398	0	7	.022	24	7	10973.171	16087.5	3466.938	1	1	C3.3.2-1
9	P22A	UA300x22...	.350	0	7	.007	20.5	7	18806.333	25294.5	14125.047	1	.85	C5.2.2-1
10	P14A	UA300x22...	.289	0	7	.019	0	7	21158.482	25294.5	14125.047	1	.85	C5.2.2-3
11	P24A	UA300x22...	.284	0	7	.012	0	7	21158.482	25294.5	14125.047	1	.85	C5.2.2-3
12	P13B	UA300x22...	.263	20	7	.020	20	7	18972.248	25294.5	14125.047	1	.85	C3.3.2-1
13	P23B	UA300x22...	.253	20	7	.018	20	7	18972.248	25294.5	14125.047	1	.85	C5.2.2-3
14	P22B	UA300x22...	.240	0	7	.015	20	7	18972.248	25294.5	14125.047	1	.85	C5.2.2-1
15	P34A	UA300x22...	.239	0	8	.065	0	8	19606.003	25294.5	19787.646	1	.85	C5.2.2-3
16	D1	FBA275x1...	.205	39.327	7	.000	39.327	1	6862.243	16087.5	3261.322	1	1	C5.2.2-1
17	P24B	UA300x22...	.195	0	7	.012	0	7	21158.482	25294.5	14125.047	1	.85	C5.2.2-3
18	P12A	UA300x22...	.178	0	7	.007	20.5	7	18806.333	25294.5	14125.047	1	.85	C5.2.2-3
19	P11	UA300x22...	.175	8	7	.033	0	7	22451.452	25294.5	14125.047	1	.85	C5.2.2-3
20	H3	FBA275x1...	.171	24	7	.008	24	7	10973.171	16087.5	3466.938	1	1	C3.3.2-1
21	P23A	UA300x22...	.171	20	7	.007	20	7	18972.248	25294.5	14125.047	1	.85	C5.2.2-3
22	H1	FBA275x1...	.171	24	7	.008	24	7	10973.171	16087.5	3466.938	1	1	C3.3.2-1
23	D2	FBA275x1...	.170	38.898	7	.000	0	1	6981.746	16087.5	3271.555	1	1	C5.2.2-1
24	P14B	UA300x22...	.145	0	7	.019	0	7	21158.482	25294.5	14125.047	1	.85	C5.2.2-3
25	P13A	UA300x22...	.124	20	7	.010	20	7	18972.248	25294.5	14125.047	1	.85	C5.2.2-3
26	P12B	UA300x22...	.121	19.375	2	.014	20	7	18972.248	25294.5	14125.047	1	.85	C5.2.2-3
27	P25	UA300x22...	.101	0	7	.016	0	7	22527.606	25294.5	14125.047	1	.85	C5.2.2-3
28	P15	UA300x22...	.100	0	7	.016	0	7	22527.606	25294.5	14125.047	1	.85	C5.2.2-3
29	H2	FBA275x1...	.075	24	7	.002	24	7	10973.171	16087.5	7031.25	1	1	C5.1.2-1