

Air System Sizing Summary for Kitchen

Project Name: 2024-023 International Village
 Prepared by: Middlebrook Engineering, LLC



05/03/2024
 05:18PM

PRCNC20241090

Air System Information

Air System Name Kitchen	Number of zones 1
Equipment Class UNDEF	Floor Area 2392.0 ft ²
Air System Type SZCAV	Location Tacoma, Washington

Sizing Calculation Information

Calculation Months Jan to Dec	Zone CFM Sizing Sum of space airflow rates
Sizing Data Calculated	Space CFM Sizing Individual peak space loads

Central Cooling Coil Sizing Data

Total coil load 4.0 Tons	Load occurs at Jul 1400
Total coil load 48.4 MBH	OA DB / WB 85.3 / 64.8 °F
Sensible coil load 48.4 MBH	Entering DB / WB 76.1 / 63.1 °F
Coil CFM at Jul 1400 2692 CFM	Leaving DB / WB 59.3 / 57.0 °F
Max block CFM 2692 CFM	Coil ADP 57.4 °F
Sum of peak zone CFM 2692 CFM	Bypass Factor 0.100
Sensible heat ratio 1.000	Resulting RH 49 %
CFM/Ton 667.0	Design supply temp. 58.0 °F
ft ² /Ton 592.8	Zone T-stat Check 1 of 1 OK
BTU/(hr-ft ²) 20.2	Max zone temperature deviation 0.0 °F
Water flow @ 10.0 °F rise 9.69 gpm	

Central Heating Coil Sizing Data

Max coil load 19.8 MBH	Load occurs at Des Htg
Coil CFM at Des Htg 2692 CFM	BTU/(hr-ft ²) 8.3
Max coil CFM 2692 CFM	Ent. DB / Lvg DB 69.6 / 76.5 °F
Water flow @ 20.0 °F drop 1.99 gpm	

Supply Fan Sizing Data

Actual max CFM 2692 CFM	Fan motor BHP 0.00 BHP
Standard CFM 2661 CFM	Fan motor kW 0.00 kW
Actual max CFM/ft ² 1.13 CFM/ft ²	Fan static 0.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM 0 CFM	CFM/person 0.00 CFM/person
CFM/ft ² 0.00 CFM/ft ²	

Zone Sizing Summary for Kitchen

Project Name: 2024-023 International Village
 Prepared by: Middlebrook Engineering, LLC



05/03/2024
 05:18PM

Air System Information

Air System Name **Kitchen**
 Equipment Class **UNDEF**
 Air System Type **SZCAV**

Number of zones **1**
 Floor Area **2392.0** ft²
 Location **Tacoma, Washington**

Sizing Calculation Information

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
 Space CFM Sizing **Individual peak space loads**

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/ft ²	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Unit Coil Load (MBH)	Zone Htg Unit Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	2692	2692	1.13	0.0	0.00	0.0	0.00	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (ft ²)
Zone 1	48.8	Jul 1400	20.5	2392.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
Kitchen Area	1	48.8	Jul 1400	2692	20.5	2392.0	1.13

Air System Design Load Summary for Kitchen

Project Name: 2024-023 International Village
 Prepared by: Middlebrook Engineering, LLC



05/03/2024
 05:18PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jul 1400			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 85.3 °F / 64.8 °F			HEATING OA DB / WB 18.0 °F / 14.8 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	700 ft²	1200	-	700 ft²	3783	-
Roof Transmission	2392 ft²	4507	-	2392 ft²	3330	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	0 ft²	0	-	0 ft²	0	-
Floor Transmission	2392 ft²	0	-	2392 ft²	2898	-
Partitions	545 ft²	0	-	545 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	2392 W	8161	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	2392 W	8161	-	0	0	-
People	4	980	820	0	0	0
Infiltration	-	2087	-840	-	10512	0
Miscellaneous	-	23750	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	48847	-20	-	20523	0
Zone Conditioning	-	48424	-20	-	19848	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	2692 CFM	0	-	2692 CFM	0	-
Ventilation Load	0 CFM	0	0	0 CFM	0	0
Supply Fan Load	2692 CFM	0	-	2692 CFM	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	48424	-20	-	19848	0
Central Cooling Coil	-	48424	0	-	0	0
Central Heating Coil	-	0	-	-	19848	-
>> Total Conditioning	-	48424	0	-	19848	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

Air System Sizing Summary for Office

Project Name: 2024-023 International Village
 Prepared by: Middlebrook Engineering, LLC



05/03/2024
 05:18PM

Air System Information

Air System Name	Office	Number of zones	1
Equipment Class	UNDEF	Floor Area	150.0 ft ²
Air System Type	SZCAV	Location	Tacoma, Washington

Sizing Calculation Information

Calculation Months	Jan to Dec	Zone CFM Sizing	Sum of space airflow rates
Sizing Data	Calculated	Space CFM Sizing	Individual peak space loads

Central Cooling Coil Sizing Data

Total coil load	0.1 Tons	Load occurs at	Jun 1400
Total coil load	1.8 MBH	OA DB / WB	84.3 / 64.8 °F
Sensible coil load	1.6 MBH	Entering DB / WB	76.3 / 63.5 °F
Coil CFM at Jun 1400	79 CFM	Leaving DB / WB	57.0 / 55.8 °F
Max block CFM	79 CFM	Coil ADP	54.9 °F
Sum of peak zone CFM	79 CFM	Bypass Factor	0.100
Sensible heat ratio	0.914	Resulting RH	50 %
CFM/Ton	534.9	Design supply temp.	55.0 °F
ft ² /Ton	1018.3	Zone T-stat Check	1 of 1 OK
BTU/(hr-ft ²)	11.8	Max zone temperature deviation	0.0 °F
Water flow @ 10.0 °F rise	0.35 gpm		

Central Heating Coil Sizing Data

Max coil load	0.8 MBH	Load occurs at	Des Htg
Coil CFM at Des Htg	79 CFM	BTU/(hr-ft ²)	5.4
Max coil CFM	79 CFM	Ent. DB / Lvg DB	69.3 / 78.8 °F
Water flow @ 20.0 °F drop	0.08 gpm		

Supply Fan Sizing Data

Actual max CFM	79 CFM	Fan motor BHP	0.00 BHP
Standard CFM	78 CFM	Fan motor kW	0.00 kW
Actual max CFM/ft ²	0.53 CFM/ft ²	Fan static	0.00 in wg

Outdoor Ventilation Air Data

Design airflow CFM	0 CFM	CFM/person	0.00 CFM/person
CFM/ft ²	0.00 CFM/ft ²		

Zone Sizing Summary for Office

Project Name: 2024-023 International Village
 Prepared by: Middlebrook Engineering, LLC

City of Puyallup Development & Permitting Services ISSUED PERMIT		05/03/2024
Building	Planning	
Engineering	Public Works	
Fire	Traffic	05:18PM

Air System Information

Air System Name	Office	Number of zones	1
Equipment Class	UNDEF	Floor Area	150.0 ft ²
Air System Type	SZCAV	Location	Tacoma, Washington

Sizing Calculation Information

Calculation Months	Jan to Dec	Zone CFM Sizing	Sum of space airflow rates
Sizing Data	Calculated	Space CFM Sizing	Individual peak space loads

Zone Terminal Sizing Data

Zone Name	Design Supply Airflow (CFM)	Minimum Supply Airflow (CFM)	Zone CFM/ft ²	Reheat Coil Load (MBH)	Reheat Coil Water gpm @ 20.0 °F	Zone Htg Unit Coil Load (MBH)	Zone Htg Unit Water gpm @ 20.0 °F	Mixing Box Fan Airflow (CFM)
Zone 1	79	79	0.53	0.0	0.00	0.0	0.00	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (MBH)	Time of Peak Sensible Cooling Load	Zone Heating Load (MBH)	Zone Floor Area (ft ²)
Zone 1	1.7	Jul 1400	0.9	150.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (MBH)	Time of Peak Sensible Load	Air Flow (CFM)	Heating Load (MBH)	Floor Area (ft ²)	Space CFM/ft ²
Zone 1							
OFFICE	1	1.7	Jul 1400	79	0.9	150.0	0.53

Air System Design Load Summary for Office

Project Name: 2024-023 International Village
 Prepared by: Middlebrook Engineering, LLC



05/03/2024
 05:18PM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jun 1400			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 84.3 °F / 64.8 °F			HEATING OA DB / WB 18.0 °F / 14.8 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	0 ft²	0	-	0 ft²	-	-
Wall Transmission	0 ft²	0	-	0 ft²	0	-
Roof Transmission	150 ft²	288	-	150 ft²	209	-
Window Transmission	0 ft²	0	-	0 ft²	0	-
Skylight Transmission	0 ft²	0	-	0 ft²	0	-
Door Loads	0 ft²	0	-	0 ft²	0	-
Floor Transmission	150 ft²	0	-	150 ft²	0	-
Partitions	0 ft²	0	-	0 ft²	0	-
Ceiling	0 ft²	0	-	0 ft²	0	-
Overhead Lighting	150 W	512	-	0	0	-
Task Lighting	0 W	0	-	0	0	-
Electric Equipment	150 W	512	-	0	0	-
People	1	245	205	0	0	0
Infiltration	-	118	-54	-	659	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	1675	151	-	868	0
Zone Conditioning	-	1616	151	-	807	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	79 CFM	0	-	79 CFM	0	-
Ventilation Load	0 CFM	0	0	0 CFM	0	0
Supply Fan Load	79 CFM	0	-	79 CFM	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	1616	151	-	807	0
Central Cooling Coil	-	1616	151	-	0	0
Central Heating Coil	-	0	-	-	807	-
>> Total Conditioning	-	1616	151	-	807	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		