



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 21, 2024                      **Inspection Result:**     **FAILED**

**Permit Number:** PRMU20240404

**Property Address:** 2902 E PIONEER, BUILDING B, PUYALLUP, WA

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902  
E PIONEER - ETC - APT BLDG G

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** E&S inspection will always be open during construction.  
See corrections below.

**Corrections:**

- 1 - Clean track out off paved areas on site.
  - Keep on site paved areas cleaned.
  - No pumping into storm, sewer, or infiltration area.
  - Keep infiltration area south of the building clean and protect with snow fence.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 435-3636