



7855 S. 206th Street • Kent, WA 98032
253.872.7222 • Fax 253.872.7277
ARCHEI-219*DR

FIRE PROTECTION DIVISION

10/21/24

Archer Construction, Inc.
7855 South 206th Street
Kent, Wa 98032

Attention: Puyallup Fire Prevention

Reference: Boot Barn Demising Wall – 4102 S. Meridian, Ste. D

The above referenced fire sprinkler tenant improvement involves adding sprinklers along the Boot Barn side of a new demising wall. The new design criteria (OH2 or less / mostly leather goods Class I commodity) is less than the existing High Piled Storage criteria. For these reasons the proposed sprinkler modifications will not affect the hydraulic calculations.

Sincerely,
Theodore Queen

