



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 22, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCTI20240784

Property Address: 1023 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: Interior tenant improvement to construct UPS & Battery Rooms totaling 1,753 sf - CENTERIS SCALE MATRIX UPS & BATTERY ROOM TENANT IMPROVEMENT

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 2 Date of inspection 10/22/2024
- 1 ; complete framing of opening for fire damper as per install instructions as discussed with contractor.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org