



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 22, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240404

Property Address: 2902 E PIONEER, BUILDING B, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER - ETC - APT BLDG G

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Maintain on site asphalt cleanliness.

Protect the infiltration trench along the south side of building "G & H".

See corrections below.

Corrections:

- 1 - Keep on site paved areas cleaned.
- No pumping into storm, sewer, or infiltration area.
- Keep infiltration area south of the building clean and protect with snow fence.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 435-3636