



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 22, 2024 **Inspection Result:** **PASSED**

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW * REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT * REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS * REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Energy (Insulation) Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 2nd layer of insulation complete at parking garage ceiling.

Corrections:

- 1 1 ;pay \$180 reinspection fee for correction of item #2 of inspection dated 9/16/2024 not corrected prior to reinspection.
- 2 ; complete steel plates and rated collars as per install instructions at ceiling of parking garage.

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684