



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 23, 2024

Inspection Result: **FAILED**

Permit Number: PRRRSF20231337

Property Address: 1724 13TH AVE CT NW, PUYALLUP, WA 98371;

Contractor:

To construct: CONVERT GARAGE INTO (3) BEDROOMS, (1) UTILITY ROOM AND LAUNDRY ROOM.PARTITION BEDROOM C TO CREATE A STORAGE ROOM.REMODEL BATHROOM A & B TO ADD A WALK IN SHOWER.CONSTRUCT RAMP. INTERIOR REMODEL IS 700SF * REVISION (1) 2.26.2024 - INSTALL WINDOW IN STORAGE, INSTALL SINKAND DOOR IN BATHROOM B, REMOVE CLOSET IN BEDROOM F, ENTRY INTO CONVERTED GARAGE RELOCATED & OFFICE WALL EXTENDED OUT BY 36".

On this day we have inspected your construction for **Residential Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. complete caulking around make up air vent outside
2.provide screens at make up air inlets outside
3.complete drywall at washer and dryer area
- 2 1 ; nobody on-site at time of inspection. (11:03 am,no access)

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684