



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Oct 25, 2024                      **Inspection Result:**     **PASSED**

**Permit Number:** B-20-0078

**Property Address:** 1515 S MERIDIAN, PUYALLUP, WA 98371;

**Contractor:** BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

**To construct:** HAMPTON INN ADDITION & PARKING BELOW \* REV (1) - 10/26/2023 - LOCATION CHANGE FOR OIL/WATER SEPARATOR IN PARKING LOT \* REV (2) - 12/27/2023 - UPDATES TO WALL TYPE, PLANS, SECTIONS, ELEVATIONS & SHEAR WALL DETAILS \* REV (3) - 3/25/2024 - UPDATES TO CHASE AND SHAFT WALLS

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** joist repair complete at 2nd floor of stack 39

**Corrections:**

- 1 date of inspection 8/28/2024
  - 1.stack 39 floor 3 and 4 complete header install at new opening to existing corridor per detail
  - 2.complete fire stopping
  3. ok to insulateGARAGE AREA
  1. rockwool at pipe penetration's approved
  - 2.provide documentation to support repair of holes with no pipe in them
- 2 date of inspection 8/30/2024
  - 1.stack 39 header at corridor 2nd 3rd 4th floors approved
  2. stack 39 2nd level corridor ok to cover ceiling only
- 3 date of inspection 9/10/2024
  1. cancelled on site by contractor



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684