



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 28, 2024 **Inspection Result:** **FAILED**

Permit Number: E-21-0313

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790
DP EXCAVATION 11410 316th st e GRAHAM, WA 98338 (253) 720-7790

To construct: PARKING LOT EXPANSION W. 675 STALLS,CFG~SHB-TC PARKING EXPANSION/BENAROYA

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: What is the status for completed the punchlist items.

Once section "A" is completed an AoF can be established for section "B".

Please contact Racheal B. once the wetland has been staked and figured out what is being done with the portion filled in.

Corrections:

- 1 - PL11 Establish wetland boundary, (F-3 & F-2) install wetland boundary signage, schedule a planning inspection through Rachael Brown @ RNBrown@PuyallupWA.gov when completed.
 - PL21 Install "sewer" c/o lids on all existing sewer c/o's. The addition of storm c/o's will confuse maintenance.
- PL = Punchlist

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387