



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Oct 29, 2024

Inspection Result: PARTIAL PASS

Permit Number: PRGR20230972

Property Address:

Contractor: MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

To construct: Early Clear, Grade, and Fill for the associated East Town Crossing Civil Permit submittal (2902 E PIONEER, PUYALLUP, WA 98372)

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: McKee, thank you for you quick response.

McKee has a plan for the stormwater runoff.

McKee is working diligently on stormwater controls. They are working with the design engineer to come up with a temporary sediment pond.

Please maintain corrections, Thank you!

Corrections:

- 1 Maintain sediment controls.
No track out! Maintain spalls and keep tires clean!
Keep trucks out of mud unless there is a wheel wash.
Keep spalls on site.
Maintain SWPPP on site.

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by several vertical, wavy lines that resemble a series of connected loops or a stylized 'L'. A horizontal line extends to the right from the end of the signature.

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387