



City of Puyallup

**Fire Prevention**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 07, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRFS20241391

**Property Address:** 304 2ND ST NE, PUYALLUP, WA 98372;

**Contractor:** RELIANCE FIRE PROTECTION 500 S LANDER ST SEATTLE, WA 98134

**To construct:** RETROFIT EXISTING MCDONALD'S WITH NEW WET FIRE SPRINKLER SYSTEM.

On this day we have inspected your construction for **Fire Sprinkler Cover Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1) Complete riser from underground and bracing at same area.
- 2) Repair and secure insulation provide clearance to ALL sprinkler heads.
- 3) At South above drive through area add protection or fill cavity with secured insulation.
- 4) Over dining area - remove GWB obstruction left above new ACT ceiling or provide code reference related to the obstruction.

Sincerely,

Ray Cockerham  
Building Code Official  
RayC@PuyallupWA.gov  
(253) 841-5585