

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Nov 07, 2024	Inspection Result:	FAILED
Permit Number: Property Address:	PRCA20231634 304 2ND ST NE, PUYALL 98372; 304 2ND ST NE, I		AVE NE, PUYALLUP, WA
Contractor:	ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111		
To construct	Auburn, WA 98092		
To construct:	5 5 15		
	w/kitchen area addition, demo and construction of non-structural		
	partitions, remodel of dropped ceiling in Dining and Customer Service		
	areas, new order counters, new menu boards, new kitchen equipment,		
	new seating/decor in dining and revision of existing sidewalk to		
	accommodate door relo	cation. `McDONALD'S R	EMODEL/ADDITION

On this day we have inspected your construction for **Plumbing Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

3 1; test failed on gas pipe test. (fix leak and retest system)

Sincerely,

Shannon King Building Inspector 2

2 King



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

ShannonK@PuyallupWA.gov (253) 840-6684