



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 07, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCA20231634

Property Address: 304 2ND ST NE, PUYALLUP, WA 98372; 304 2ND AVE NE, PUYALLUP, WA 98372; 304 2ND ST NE, PUYALLUP, WA 98372;

Contractor: ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111
Auburn, WA 98092

To construct: Remodel of existing McDonald's including: exterior facade upgrade w/kitchen area addition, demo and construction of non-structural partitions, remodel of dropped ceiling in Dining and Customer Service areas, new order counters, new menu boards, new kitchen equipment, new seating/decor in dining and revision of existing sidewalk to accommodate door relocation. `McDONALD'S REMODEL/ADDITION

On this day we have inspected your construction for **Exhaust/Vent Fans Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 provide positive attachment of diffuser to main and cross tee of suspended ceiling at S.W. corner of building as discussed with contractor.

Sincerely,

Shannon King



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684