



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 07, 2024                      **Inspection Result:**      **FAILED**

**Permit Number:** PRCA20231634

**Property Address:** 304 2ND ST NE, PUYALLUP, WA 98372; 304 2ND AVE NE, PUYALLUP, WA 98372; 304 2ND ST NE, PUYALLUP, WA 98372;

**Contractor:** ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111  
Auburn, WA 98092

**To construct:** Remodel of existing McDonald's including: exterior facade upgrade w/kitchen area addition, demo and construction of non-structural partitions, remodel of dropped ceiling in Dining and Customer Service areas, new order counters, new menu boards, new kitchen equipment, new seating/decor in dining and revision of existing sidewalk to accommodate door relocation. `McDONALD'S REMODEL/ADDITION

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete all ceiling grid requirements as discussed with contractor at time of inspection.
  - 2 , complete all insulation and vapor barrier at walls and ceiling .
  - 3 ; provide gas pipe test approval prior to ceiling grid inspection.
  - 4 ; provide fire cover approval of ceiling grid prior to next inspection.
  - 5 ; remove abandoned mechanical equipment and plumbing vents above ceiling as discussed with contractor.
  - 6 ; provide 1" clearance to combustibles at b-vent of hot water heater.
  - 7 ; provide min. 3 turns on tie wires of lights.
- not ready



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Shannon King

Building Inspector 2

[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)

(253) 840-6684