

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Nov 12, 2024	Inspection Result:	FAILED
Permit Number: Property Address:	PRMU20240404 2902 E PIONEER, BUILI	DING B, PUYALLUP, WA	
	MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371 BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902 E PIONEER - ETC - APT BLDG G		


On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Please see and correct #1 correction prior to next rain event!

Corrections:

- 1 1. Please empty excess high PH water to the next washout and remove full washout.
 - ZERO concrete washout on the ground!
 - No pumping excess washout water to the ground.
 - ZERO track out onto Pioneer or Shaw Rd.
 - Keep on site paved areas cleaned.
 - No pumping into storm, sewer, or infiltration area.
 - Keep infiltration area south of the building clean and protect with snow fence.

Sincerely,





Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Jason Little Development Engineering Inspector JLittle@PuyallupWA.gov (253) 244-0387