



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 15, 2024

**Inspection Result:** **FAILED**

**Permit Number:** PRCCP20230970

**Property Address:**

**Contractor:** MCKEE ENTERPRISES, LLC PO BOX 5 ENUMCLAW, WA 98022

**To construct:** Civil Construction Permit for the East Town Crossing project associated with Preliminary Site Plan/SEPA, P-21-0034.

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Please sweep the on site asphalt.

Do not wash the heavy debris in the CB's.

Correct item #1 below.

**Corrections:**

- 1 1. - Sweep the on site asphalt! DO NOT wash the heavy debris in the CB's!
  - Maintain construction entrance. No track out onto Pioneer.
  - Install snow fencing along north side of infiltration trench on south side of building "G".
  - Maintain on site asphalt cleanliness.
  - No pumping silty water into storm, sewer, new stream, existing storm pond, and/or infiltration area.

Sincerely,



City of Puyallup

---

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387