

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

## **INSPECTION REPORT**

Date of Inspection:	Nov 15, 2024	Inspection Result:	FAILED
Permit Number: Property Address:		DING B, PUYALLUP, WA	
		5 CANYON RD SUITE PU partment building - EAST	
	E PIONEER - ETC - AP	f BLDG G	

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** No pumping the concrete washout on the ground! Install covers to keep rain water out so that it does not over flow.

No inspections until corrected item #1 below is complete!

## Corrections:

- 1 1. Please empty excess high PH water to the next washout and remove full washout.
  - ZERO concrete washout on the ground!
  - No pumping excess washout water to the ground.
  - ZERO track out onto Pioneer or Shaw Rd.
  - Keep on site paved areas cleaned.
  - No pumping into storm, sewer, or infiltration area.
  - Keep infiltration area south of the building clean and protect with snow fence.

Sincerely,





Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Jason Little Development Engineering Inspector JLittle@PuyallupWA.gov (253) 244-0387