



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 18, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRCCP20240864

Property Address: 304 2ND ST NE, PUYALLUP, WA 98372;

Contractor: ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111
Auburn, WA 98092

To construct: Adding sprinklers to an existing McDonald's which requires a new hydrant, PIV & FDC. Will be cutting the roadway and public sidewalk to bring new water service from hydrant across the street. ~ McDONALD'S FIRE HYDRANT/FIRE SPRINKLERS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: OSG is hydrotesting the fire line. Hydrostatic pressure (PASSED)
The fire line in was flushed and 1st purity taken to the labs @245pm.

Corrections:

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387