



CITY OF PUYALLUP
Development & Permitting Services
 333 S. Meridian, Puyallup, WA 98371
 (253) 864-4165
www.cityofpuyallup.org

Permit No:
 PRFA20241433

FIRE ALARMS

Puyallup, WA

Job Address	Address: 304 2ND ST NE, PUYALLUP, WA 98372 Parcel # 3330000011	ISSUED October 03, 2024
Owner	MC DONALD CORP 41/46 110 N CARPENTER STREET CHICAGO, IL 43218-2571	
Applicant	Camryn Olivarez 206 Frontage Rd N, Suite C Pacific, WA 98047 (253) 431-5860 camryno@firesystemswest.com	
Contractor	FIRE SYSTEMS WEST 206 FRONTAGE ROAD ST PACIFIC, WA 98047 WA L&I #:	
Description of Work	Install new FACP. Install new input modules to monitor the sprinkler riser system. Install new input modules to monitor the kitchen hood suppression system.	
Permit Types	Fire Alarms	
Expiration Date:	April 01, 2025	
Total ESU's		

Building Components:

Quantity	Units	Description
8	DEVICES	Fire Alarm and Detection System and Related Equipment, New

Total Value of Work:	\$0.00
-----------------------------	--------

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.
 - Provide plans and permit on site for inspection.
 - Complete labor and industries inspections prior to requesting city inspection.
 - Exterior fire bell required outside fire sprinkler room.
 - Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.
 - Pre-test shall be conducted with a printout for inspector at time of inspection.
 - Labeling of all devices above and below ceiling required.
 - Fire sprinkler tamper valves and PIV will be required to be tested at inspection. Fire sprinkler contractor to be onsite.
 - Due to unforeseeable construction design, all device locations to be field verified for compliance.
- Schedule your inspection online through the city of puyallup online permit system. This is a request for inspection only. A date and

time will be selected by Inspector depending on availability. Email morning of inspection between 7am – 8am for scheduled date and time. Fire Inspections are Monday – Thursday there will be no inspections on Fridays. For larger system please make an appointment prior to scheduling first.

David Drake ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Camryn Olivarez