

HANGER ATTACHMENT

SIDE BEAM BRACKE

**NUT & PLATE WASHER** 

SAMMY SIDEWINDE

SAMMY SUPERSCREW

COACH SCREW ROD

CEILING FLANGE

**EYE SOCKET** 

KWIK-BOLT

**ABBREVIATIONS** 

CENTERLINE OF PIPE

rs Cut to suit

FO FIELD ORDER

COJ CUT ON JOB

IFOW INSIDE FACE OF WALL

OFOW OUTSIDE FACE OF WALL

NAS NO AUTO. SPRINKLERS

UNO UNLESS NOTED OTHERWISE

SYMBOLS

★ TS (CL) TOP OF STEEL / BOTTOM OF DECK

★ FF (CL) ABOVE FINISHED FLOOR

★ BB (CL) BOTTOM OF BEAM

★ TB (CL) TOP OF BEAM

FLEXIBLE COUPLING

RIGID COUPLING

**SPRINKLER SYMBOLS** 

TOTAL PROJECT SPRINKLERS =

SYM MAKE MODEL SIN#

TO REMAIN

RELIABLE GXLO

EXISTING

**REVISIONS** 

DESCRIPTION

**WATER SUPPLY** 

GPM FLOWING 950 GPM

DATE & TIME 10/5/2010

HYDRAULICS HAVE NOT

HARDIMAN, FRUITLAND

LOCATION: PARKING LOT

NOTES: FIRE PUMP

TEST IS OLDER BUT

CHANGED PER TED

WATER 4/3/24

RESIDUAL

40 PSI

38 PSI

**HYDRAULIC DESIGN INFORMATION** 

AREA HAZARD CLASSIFICATION TYPE DENSITY AREA SIZE COVERAGE PER SPRINKLER HOSE SYST. DEMAND @ BOR

**SCOPE OF WORK** 

• ADD HEADS ALONG NEW DEMISING WALL

### **CLARIFICATIONS:**

• ALL AREAS PROTECTED BY A WET SYSTEM MUST BE MAINTAINED AT A MINIMUM OF 40°F (BY OTHERS)

IN ORDER TO PREVENT THE PIPE FROM FREEZING.

# **EXCLUSIONS:**

• RELOCATION OF EXISTING MAIN AND BRANCHLINE PIPING.

 HYDRAULIC CALCULATIONS • INSTALLATION OF SPECIALTY SYSTEMS: DRY SYSTEM, KITCHEN HOOD, EXHAUST DUCT.

· CHANGE OUT OF EXISTING HEADS TO QUICK RESPONSE.

• PAINTING, PREPARATION OR CLEANING OF PIPE.

 SHUTDOWN FEES, WSST, BONDS • ANY AND ALL ELECTRICAL OR ALARM WORK.

### **GENERAL NOTES:**

• ALL MATERIAL AND EQUIPMENT TO BE NEW AND UL AND/OR FM APPROVED.

 JOINING OF PIPE AND FITTINGS, THREADED AND WELDED, SHALL BE IN ACCORDANCE WITH NFPA #13. • PIPE HANGER AND METHOD OF HANGING TO BE IN ACCORDANCE WITH NFPA #13.

## • PIPING SHALL BE IN ACCORDANCE WITH NFPA #13.

# **DESIGN CRITERIA:**

• DESIGN AND TESTING BASED ON NFPA 13 (2019) AND PUYALLUP CODES

• EXISTING CRITERIA - HIGH PILED STORAGE, WI HEAD SPACING OF 8' X 11'.

8:55:12 AM

**BUILDING INFO:** 

PARCEL # = 0419095021

• OWNER: WRI-URS SOUTH HILL LLC, C/O KIMCO REALTY CORPORATION PROPERTY TAX DEPT, 500 N BROADWAY STE 201, JERICHO, NY 11753




THE APPROVED CONSTRUCTION PLANS AND ALL ENGINEERING MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.



Approval of submitted plans is not an approval of omissions or oversight by this office or noncompliance with any applicable regulations of local government.

The contractor is responsible for making sure that the building complies with all applicable building codes and regulations of the local government





FIRE SPRINKLER

PIPING PLAN

PERMIT NO: -

DATE:

REVISED //

JOB NO: R24-053

DESIGNER: Queen

SCALE: As Noted

10/21/24

FP 1 OF 1

AUTHORITY: PUYALLUP

**VICINITY / KEY PLAN** SCALE: 1" = 100'-0"

LS					
FINISH	K-FAC.	THREAD	TEMP	CANOPY	QTY
BRASS	11.2	3/4"	286°	N/A	14
					-

PROJECT:	Boot Barn Demising Wall
	4102 S. Meridian, Ste D
	Puyallup, WA 98373
CONTRACT W/:	Powell Ryka

Ryan Brehm

(425) 828-4774

-	ARCHERA	4
	WSCL#: ARCHEI*219DR	CONTRACT W/:
	7855 S 206TH STREET, KENT, WA 98032	CONTACT:
14	PHONE 253-872-7222 FAX 253-872-7277	PHONE: