



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Nov 22, 2024                      **Inspection Result:**     **PASSED**

**Permit Number:** PRMU20240139

**Property Address:** 2902 E PIONEER - BUILDING B, PUYALLUP, WA

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING B 3-story apartment building with (24) 2-bedroom/2-bathroom units ETC - 2902 E PIONEER - ETC – APT BLDG B

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** provide min. embedment depth of hold downs as required per city approved plans at foundation inspection.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684