

City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 25, 2024 Inspection Result: PARTIAL PASS

Permit Number: PRMU20240404

Property Address: 2902 E PIONEER, BUILDING G, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902

E PIONEER - ETC - APT BLDG G

On this day we have inspected your construction for **Slab/Insulation Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: r-10 complete at exterior foundation walls only.

Corrections:

Sincerely,

Shannon King Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684