



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Nov 25, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCTI20240772

Property Address: 4505 S MERIDIAN, Unit: A, PUYALLUP, WA 98373;

Contractor: RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW
GIG HARBOR, WA 98335-8325

To construct: Tenant Improvement of an existing 4,833 (NET) SF building for a new
urgent care and occ med clinic. - INDIGO - PUYALLUP

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide service plug at heat pump on roof.
- 2 ; provide balance report with o.s.a. at time of mechanical final.
- 3 ; provide ladder to inspect water heater.
- 4 ; complete install of coffee maker as discussed with contractor.
- 5 ; toilet to be min. 16" - 18" from wall to centerline of toilet as per City approved plans.
- 6 ; complete install of all doors.
- 7 ; complete install of restroom grab bars as per city approved plans.
- 8 ; provide D.O.H. prewalk inspection prior to final.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684