


# Structural Analysis Report AT&T

October 30, 2024

PRCTI20241032

**City of Puyallup  
Building  
REVIEWED  
FOR  
COMPLIANCE**

BSnowden  
11/13/2024  
1:56:27 PM




Site Name	GOOD SAMARITAN
Site ID	WA6659
FA #	10029581
PTN #	3801A1A1YK
Pace #	MRWOR073518
IWM #	WSWOR0029871
Client	Mastec
Proposed Carrier	AT&T
Site Location	407 14 <sup>th</sup> Ave SE Puyallup, WA 98371 47.1795000° N NAD83 122.290558° W NAD83
Structure Type	Penthouse Wall
Mount Usage Ratio	<b>79%</b>
Overall Result	<b>Pass</b>
Recommendation	--

Upon reviewing the results of this analysis, it is our opinion that the structure does meet the specified IBC/TIA/ASCE code and minimum design requirements. The existing structure is therefore deemed adequate to support the existing and proposed loading as listed in this report.

Michael Leeper

Digitally signed by Michael Leeper  
DN: cn=Michael Leeper, email=Michael.Leeper@coreoneconsulting.com,  
ou=Core One Consulting, c=United States of America  
Date: 2024.10.31 12:11:02 -0700



10/31/2024

Calculations required to be provided by  
the Permittee on site for all inspections

## **Summary of Contents**

---

- Introduction
  - Opening Statement
  - Project Description
  - Criteria46
  - Conclusion
- Calculations
- Appendix A
  - Design Tables & Resources Used

---

## **Assumptions and Limitations**

Our structural calculations are completed assuming all information provided to CORE ONE CONSULTING USA is accurate and applicable to this site. For the purposes of calculations, we assume an overall structure condition of “like new” and all members and connections to be free of corrosion and/or structural defects. The structure owner and/or contractor shall verify the structure’s condition prior to installation of any proposed equipment. If actual conditions differ from those described in this report CORE ONE CONSULTING USA should be notified immediately to complete a revised evaluation.

Our evaluation is completed using standard TIA, AISC, ACI, and ASCE methods and procedures. Our structural results are proprietary and should not be used by others as their own. CORE ONE CONSULTING USA is not responsible for decisions made by others that are or are not based on our supplied assumptions and conclusions.

This report is an evaluation of the antenna mount only and does not reflect the adequacy of the other mounts, or coax mounting attachments. These elements are assumed to be adequate for the purposes of this analysis and are assumed to have been installed per their manufacturer requirements.

## **INTRODUCTION**

At the request of **AT&T**, CORE ONE CONSULTING USA has performed a structural analysis on the existing antenna mount supporting structure. All supporting documents have been obtained from the client and are assumed to be accurate and applicable to this site. The structure was analyzed using RISA 3D version 22.0 engineering software.

## **Supporting Documentation**

<b>Antenna Loading</b>	DE130 Scoping Document, dated 01/29/2024
<b>Construction Documents</b>	Core One Consulting USA, Project # 2401U410, Rev A dated 09/16/2024
<b>Previous SA</b>	Ryka Land Services Site# WA6659, dated 05/30/2024 Morrison Hershfield Proj.# SML-052R5/2000479, dated 08/31/2021
<b>Photos</b>	Provided by Mastec

## **Analysis Code Requirements**

Wind Speed	108 mph (3-Second Gust)
Wind Speed w/ ice	30 mph wind w/ 1" Ice
TIA Revision	ANSI/TIA-222-H
Adopted IBC	2021 IBC/2021 WBC
Structure Class	IV
Exposure Category	C
Topographic Category	$K_{zt}:1.0$
Calculated Crest Height	0 ft
Site Class	D - Stiff Soil
Spectral Response	$S_s=1.267g$ , $S_1=0.436g$ , $S_{DS}= 1.014g$

## **CONCLUSION**

Upon reviewing the results of this analysis, it is our opinion that the structure meets the specified IBC/TIA/ASCE code and minimum design requirements. The existing structure are therefore deemed adequate to support the proposed loading as listed in this report. The additional equipment proposed for the referenced project will not increase the design gravity loading by more than 5 percent or the lateral loading by more than 10 percent, therefore the proposed installation is acceptable per the requirements listed in sections 502.4 and 502.5 of the 2021 IEBC. See appendix for details.

Alexander Bazeley  
Structural Lead | [Core One Consulting USA](#)  
2875 W Ray Road, Suite 6, Chandler, AZ 85224  
(O) 1+(855) 708-2195 |  
[alex.bazeley@coreoneconsulting.com](mailto:alex.bazeley@coreoneconsulting.com)

## Final Configuration

RAD Height (ft)	Qty.	Appurtenance	Sector	Cable	Mount type	Carrier
88'-9"	<b>3</b>	<b>Air6419 B77D</b>	Alpha Beta Gamma	<b>(6) 6AWG DC Trunks</b> <b>(3) Fiber Trunk</b>	Pipe Mount	AT&T
	<b>3</b>	<b>Air6419 B77G</b>				
80'-0"	<b>6</b>	<b>KMW EPBQ-654L8H8-L2</b>				
	<b>3</b>	<b>Ericsson 4490 B5/B12A</b>				
	<b>3</b>	<b>Ericsson 4415 B30</b>				
	<b>3</b>	<b>Ericsson 4478 B14</b>				
	<b>3</b>	<b>Ericsson 4890 B25/B66</b>				
<b>3</b>	<b>Raycap DC9-48-60-24-PC16-EV</b>					

\*Bold items denote appurtenances to be installed

## Structure Usages

	Summary	
Wall*	79%	Pass
<b>RATING =</b>	<b>79%</b>	<b>Pass</b>

\*Each mount is supported by (3) 12'-0" long 2x6 at 16" OC

**APPENDIX A**  
Design Tables & Resources


## ANSI/TIA-222H - WIND, ICE & SEISMIC LOAD CALCULATIONS

Site Code/Name	WA6659 - GOOD SAMARITAN	
State	Washington	<i>Reference</i> Table 2-1 Section 2.6.5.1.2 Section 2.6.6.2.2 ASCE7 Hazard Tool or Site Specific Section 2.6.7
County	Pierce	
Structure Class	IV	
Exposure Category	C	
Topographic Factor	1.00	
Mean Elevation of base of structure	89.6	ft
Height Above Ground	80	ft
Rooftop Wind Speed-Up Factor	1.00	K <sub>s</sub>
<b>Wind Parameters</b>		
Basic wind speed	108	V mph
Wind direction probability factor	0.95	K <sub>d</sub>
Gust effect factor	1.00	G <sub>h</sub>
Velocity Pressure (K <sub>a</sub> = 0.9)	30.73	psf
<b>Wind &amp; Ice Parameters</b>		
Base windspeed in conjunction with ice, V	30	t <sub>i</sub> mph
Base Ice thickness	1.00	in
Ice Velocity Pressure (K <sub>a</sub> = 0.9)	2.37	q <sub>ice</sub> psf
Design Ice Thickness	1.37	t <sub>iz</sub> in
<b>Seismic Parameters</b>		
Site Soil Class	D - Default	Table 2-10 ASCE7 Hazards Tool ASCE7 Hazards Tool ASCE7 Hazards Tool ASCE7 Hazards Tool Table 2-3 Section 16.7 Table 2-11 Section 2.7.5 Section 2.7.7.1
Seismic Design Category	D	
Spectral Response at Short Periods	1.267	
Spectral Response at 1sec	0.436	
Long Period Transition Period	6	
Seismic Importance Factor	1.5	
Response modification coefficient	2	
Short-Period Site Coefficient	1.2	
Design Spectral Response at Short Periods	1.014	
Seismic Response Coefficient	0.760	


# TYPICAL SECTOR

Position	Appurtenance properties										Wind		Ice		Seismic		EPA	
	Manufacturer	Model	L [in]	W [in]	D [in]	Weight [lbs]	0° [lbs]	90° [lbs]	Weight [lbs]	A <sub>N</sub> [sqft]	A <sub>T</sub> [sqft]	E <sub>H</sub> [lbs]	A <sub>N</sub> [sqft]	A <sub>T</sub> [sqft]				
1	Ericsson	AIR 6419 B77D	28.2	16.1	7.3	64.0	116.3	55.4	78.3	3.8	1.8	48.7	3.8	1.8				
2	Ericsson	AIR 6419 B77G	28.3	16.1	7.9	64.0	116.7	59.5	79.6	3.8	1.9	48.7	3.8	1.9				
1	KMW	EPBQ-654L8H8-L2	96.0	21.0	6.3	80.0	555.9	216.1	315.3	18.1	7.0	60.8	18.1	7.0				
2	KMW	EPBQ-654L8H8-L2	96.0	21.0	6.3	80.0	555.9	216.1	315.3	18.1	7.0	60.8	18.1	7.0				
R1	Ericsson	RRU 4490 B5/B12A	20.6	15.6	7.0	68.4	37.5	82.3	56.4	2.7	1.2	52.0	2.7	1.2				
R1	Ericsson	RRU 4415 B30	15.0	13.2	5.1	46.3	19.9	50.7	35.3	1.7	0.6	35.2	1.7	0.6				
R2	Ericsson	RRU 4478 B14	15.0	13.2	7.3	59.4	28.0	50.7	37.4	1.7	0.9	45.2	1.7	0.9				
R2	Ericsson	RRU 4890 B25/B66	20.6	15.7	7.0	69.5	37.5	82.8	56.7	2.7	1.2	52.8	2.7	1.2				
R1	Raycap	DC9-48-60-24-8C-EV	22.3	11.0	11.0	32.8	62.8	62.8	55.7	2.0	2.0	24.9	2.0	2.0				

Plan View  
(N.T.S.)





Elevation  
(N.T.S.)



LEGEND:

- Existing Antennas
- Proposed Antennas
- Existing Equipment
- Proposed Equipment



Envelope Only Solution

Core One Consulting USA	GOOD SAMARITAN	SK - 1
SR		Oct 22, 2024 at 5:06 PM
WA6659		Pipe Mount.r3d




Level, Wall: Stud

**1 piece(s) 2 x 6 DF No.2 @ 16" OC**

Wall Height: 16'

Member Height: 15' 7 1/2"

O. C. Spacing: 16.00"



Drawing is Conceptual

Design Results	Actual	Allowed	Result	LDF	Load: Combination
Slenderness	34	50	Passed (68%)	--	--
Compression (lbs)	600	3135	Passed (19%)	0.90	1.0 D
Plate Bearing (lbs)	600	6445	Passed (9%)	--	1.0 D
Lateral Reaction (lbs)	178	--	--	1.60	1.0 D + 0.6 W
Lateral Shear (lbs)	167	1584	Passed (11%)	1.60	1.0 D + 0.6 W
Lateral Moment (ft-lbs)	695 @ mid-span	1342	Passed (52%)	1.60	1.0 D + 0.6 W
Total Deflection (in)	0.75 @ mid-span	1.56	Passed (L/249)	--	1.0 D + 0.6 W
Bending/Compression	0.79	1	Passed (79%)	1.60	1.0 D + 0.6 W

- Lateral deflection criteria: Wind (L/120)
- Input axial load eccentricity for this design is 50% of applicable member side dimension.
- Applicable calculations are based on NDS.
- A bearing area factor of 1.25 has been applied to base plate bearing capacity.
- A 15% increase in the moment capacity has been added to account for repetitive member usage.

Supports	Type	Material
Top	Dbl 2X	Douglas Fir-Larch
Base	2X	Douglas Fir-Larch

System : Wall  
 Member Type : Stud  
 Building Code : IBC 2018  
 Design Methodology : ASD

Max Unbraced Length	Comments
1'	

Lateral Connections				
Supports	Connector	Type/Model	Quantity	Connector Nailing
Top	Nails	8d (0.113" x 2 1/2") (Toe)	2	N/A
Base	Nails	8d (0.113" x 2 1/2") (Toe)	2	N/A

- Nailed connection at the top of the member is assumed to be nailed through the bottom 2x plate prior to placement of the top 2x of the double top plate assembly.

Vertical Load	Spacing	Dead (0.90)	Comments
1 - Point (lb)	N/A	600	Default Load

Lateral Load	Location	Spacing	Wind (1.60)	Comments
1 - Uniform (PSF)	Full Length	16.00"	28.5	

- ASCE/SEI 7 Sec. 30.4: Exposure Category (C), Mean Roof Height (33'), Topographic Factor (1.0), Wind Directionality Factor (0.85), Basic Wind Speed (108), Risk Category(IV), Wind Zone (4), GCpi (+/- 0.18), Effective Wind Area determined using full member span and trib. width.
- IBC Table 1604.3, footnote f: Deflection checks are performed using 42% of this lateral wind load.

**Weyerhaeuser Notes**

Weyerhaeuser warrants that the sizing of its products will be in accordance with Weyerhaeuser product design criteria and published design values. Weyerhaeuser expressly disclaims any other warranties related to the software. Use of this software is not intended to circumvent the need for a design professional as determined by the authority having jurisdiction. The designer of record, builder or framer is responsible to assure that this calculation is compatible with the overall project. Accessories (Rim Board, Blocking Panels and Squash Blocks) are not designed by this software. Products manufactured at Weyerhaeuser facilities are third-party certified to sustainable forestry standards. Weyerhaeuser Engineered Lumber Products have been evaluated by ICC-ES under evaluation reports ESR-1153 and ESR-1387 and/or tested in accordance with applicable ASTM standards. For current code evaluation reports, Weyerhaeuser product literature and installation details refer to [www.weyerhaeuser.com/woodproducts/document-library](http://www.weyerhaeuser.com/woodproducts/document-library).

The product application, input design loads, dimensions and support information have been provided by APB

Forteweb Software Operator	Job Notes
Alex Bazeley Core One Consulting USA (727) 798-4974 alexander.bazeley@coreoneconsultants.com	





# ASCE Hazards Report

**Address:**  
No Address at This Location

**Standard:** ASCE/SEI 7-16  
**Risk Category:** IV  
**Soil Class:** D - Default (see Section 11.4.3)

**Latitude:** 47.1795  
**Longitude:** -122.290558  
**Elevation:** 89.60877477364868 ft (NAVD 88)



## Wind

### Results:

Wind Speed	108 Vmph
10-year MRI	67 Vmph
25-year MRI	73 Vmph
50-year MRI	78 Vmph
100-year MRI	83 Vmph

Data Source: ASCE/SEI 7-16, Fig. 26.5-1D and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Tue Oct 22 2024

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 1.6% probability of exceedance in 50 years (annual exceedance probability = 0.00033, MRI = 3,000 years).

Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.

## Seismic

---

**Site Soil Class:** D - Default (see Section 11.4.3)

**Results:**

$S_s$ :	1.267	$S_{D1}$ :	N/A
$S_1$ :	0.436	$T_L$ :	6
$F_a$ :	1.2	PGA :	0.5
$F_v$ :	N/A	PGA <sub>M</sub> :	0.6
$S_{MS}$ :	1.52	F <sub>PGA</sub> :	1.2
$S_{M1}$ :	N/A	$I_e$ :	1.5
$S_{DS}$ :	1.014	$C_v$ :	1.353

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

**Data Accessed:** Tue Oct 22 2024

**Date Source:** [USGS Seismic Design Maps](#)

## Ice

---

**Results:**

Ice Thickness: 1.00 in.  
Concurrent Temperature: 25 F  
Gust Speed 30 mph

**Data Source:** Standard ASCE/SEI 7-16, Figs. 10-2 through 10-8

**Date Accessed:** Tue Oct 22 2024

Ice thicknesses on structures in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

Values provided are equivalent radial ice thicknesses due to freezing rain with concurrent 3-second gust speeds, for a 500-year mean recurrence interval, and temperatures concurrent with ice thicknesses due to freezing rain. Thicknesses for ice accretions caused by other sources shall be obtained from local meteorological studies. Ice thicknesses in exposed locations at elevations higher than the surrounding terrain and in valleys and gorges may exceed the mapped values.

---

The ASCE Hazard Tool is provided for your convenience, for informational purposes only, and is provided "as is" and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE Hazard Tool.