



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 03, 2024                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRMU20240404

**Property Address:** 2902 E PIONEER, BUILDING G, PUYALLUP, WA

**Contractor:** MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

**To construct:** BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902  
E PIONEER - ETC - APT BLDG G

On this day we have inspected your construction for **Sidewer Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Plumbing contractor began SS install today. we discussed types of connections allowed. I gave them SS as-built sheets due to the added bends and separate depths for building "G". The plumber is leaving all pipes open until building plumbing inspection is complete. Please schedule sidesewer inspection for the same day of plumbing inspection.

**Corrections:**

1. - After plumbing has been tested and released, please plug sewer at closest sewer MH.  
Note: The underground contractor has tested and cleaned all of the sewer on site. Before building final, the sewer will need to be TV'ed by the building GC and any building material found in the sewer will need to be jetted and vaced.

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

A handwritten signature in black ink, consisting of a large, loopy initial 'J' followed by a series of vertical, wavy lines that resemble the letters 'LITTLE'. A horizontal line extends to the right from the end of the signature.

Jason Little

Development Engineering Inspector

[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)

(253) 244-0387