



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 03, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: B-20-0741

Property Address: 2345 W STEWART, PUYALLUP, WA 98371;

Contractor: RICHARD A FARRIS 2401 W STEWART PUYALLUP, WA 98371-4813
(253) 255-3413

To construct: NEW SFR

On this day we have inspected your construction for **Storm Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The correct size trenches are installed.

The spreader board should be raised and/or balanced out with the down hill positive slope away. Will verify grades and vegetation prior to final.

Corrections:

Sincerely,

Jason Little
Development Engineering Inspector



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

JLittle@PuyallupWA.gov

(253) 244-0387