

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Dec 04, 2024	Inspection Result:	PASSED
Permit Number:	PRCA20231634		
Property Address:	304 2ND ST NE, PUYALLUP, WA 98372; 304 2ND AVE NE, PUYALLUP, WA 98372; 304 2ND ST NE, PUYALLUP, WA 98372;		
Contractor	ZNAA ENTERRRIGES ING 1400 Laka Tarana Darkuway SE Sta 104 111		
Contractor:	ZIVA ENTERPRISES INC. 1402 Lake Tapps Parkway SE, Ste 104-111		
	Auburn, WA 98092		
To construct:	Remodel of existing McDonald's including: exterior facade upgrade		
	w/kitchen area addition, demo and construction of non-structural		
	partitions, remodel of dropped ceiling in Dining and Customer Service		
	areas, new order counters, new menu boards, new kitchen equipment,		
	new seating/decor in dining and revision of existing sidewalk to		
	accommodate door relo	cation. `McDONALD'S R	EMODEL/ADDITION

On this day we have inspected your construction for **Plumbing Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1; complete install of all equipment as discussed with contractor.
 - 2 ; provide hammer arrestors at ice machine and dishwasher supply lines.
 - 3 ; provide 1" clearance at b-vent of hot water heater.
 - 4 ; provide health dept. pre-walk inspection prior to plumbing final inspection.
 - 5 ; provide 17" max. to Urinal rim above finish floor as per city approved plans.
 - 6 ; provide back flow cert. at time of plumbing final.
 - 7 ; provide manual for ice maker to check air gap of water supply.
 - 8 ; not ready (complete all items as discussed with contractor)

Sincerely,





Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

King

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684