



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 09, 2024 **Inspection Result:** **PARTIAL PASS**

Permit Number: PRMU20240404

Property Address: 2902 E PIONEER, BUILDING G, PUYALLUP, WA

Contractor: MKM LEGACY LLC 8705 CANYON RD SUITE PUYALLUP, WA 98371

To construct: BUILDING G 3-story apartment building - EAST TOWN CROSSING - 2902
E PIONEER - ETC - APT BLDG G

On this day we have inspected your construction for **Sidewer Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Received sewer as-builts.

Corrections:

1. - After plumbing has been tested and released, please plug sewer at closest sewer MH.
Note: The underground contractor has tested and cleaned all of the sewer on site. Before building final, the sewer will need to be TV'ed by the building GC and any building material found in the sewer will need to be jetted and vaced.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387