



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 12, 2024

Inspection Result: **PARTIAL PASS**

Permit Number: PRCCP20221569

Property Address: 4002 10TH ST SE, PUYALLUP, WA 98374;

Contractor: BRC FAMILY LLC PO BOX 731310 PUYALLUP, WA 98373-0060 GREAT
NORTHWEST EXCAVATION LLC 12203 40TH AVE TACOMA, WA 98466

To construct: Extend utilities from 10th street SE on a site for purposes of construction
2- 6 plexus as well as provide infiltration on site. COPPERBERRY
CONDOMINIUMS

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Sight distance triangle was surveyed. I accepted the mail box location layout.

Corrections:

Sincerely,

Jason Little
Development Engineering Inspector



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

JLittle@PuyallupWA.gov

(253) 244-0387