



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Dec 13, 2024      **Inspection Result:** **PASSED**

**Permit Number:** PRCTI20240772

**Property Address:** 4505 S MERIDIAN, Unit: A, PUYALLUP, WA 98373;

**Contractor:** RUSH COMMERCIAL CONSTRUCTION INC 6622 WOLLOCHET DR NW  
GIG HARBOR, WA 98335-8325

**To construct:** Tenant Improvement of an existing 4,833 (NET) SF building for a new  
urgent care and occ med clinic. - INDIGO - PUYALLUP

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; provide service plug at heat pump on roof.
- 2 ; provide balance report with o.s.a. at time of mechanical final.
- 3 ; provide ladder to inspect water heater.
- 4 ; complete install of coffee maker as discussed with contractor.
- 5 ; toilet to be min. 16" - 18" from wall to centerline of toilet as per City approved plans.
- 6 ; complete install of all doors.
- 7 ; complete install of restroom grab bars as per city approved plans.
- 8 ; provide D.O.H. prewalk inspection prior to final.

Sincerely,

Monty Johnson  
Sr Building Inspector  
Monty@PuyallupWA.gov



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 770-3326