



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 13, 2024 **Inspection Result:** **FAILED**

Permit Number: PRCCP20241123

Property Address: 105 7TH ST SW, PUYALLUP, WA 98371; 711 W MAIN, PUYALLUP, WA 98371;

Contractor: STREAMLINE GENERAL CONSTRUCTION LLC 1006 208TH AVE E LAKE TAPPS, WA 98391

To construct: On site civil grading, walkway modifications and additions, and stormwater system being installed for the addition of 3 double classroom portable buildings. Per zoning code requirement Frontage planting buffer improvements are included. Offsite related improvements to be submitted separately. This permit application is related to individual portable building permits PRPF 20241042, PRPF 20241043, PRPF 20241044 and CUP PLCUP 20230109.

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: The asphalt contractor ran through the amended soil area. The silt fence has been removed without stabilization. See corrections.

Corrections:

- 1 - Re-amend landscape area along south side of portables.
- Stabilize ALL exposed areas ASAP1

Sincerely,



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little

Development Engineering Inspector

JLittle@PuyallupWA.gov

(253) 244-0387