



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Dec 16, 2024 **Inspection Result:** PASSED

Permit Number: PRCTI20241072

Property Address: 4102 S MERIDIAN, Unit: D, PUYALLUP, WA 98373;

Contractor: POWELL CONSTRUCTION COMPANY 2625 NORTHUP WAY BELLEVUE, WA 98004

To construct: NEW ENTRY FACADE/FEATURE FOR EXISTING RETAIL SPACE (#10), ALONG WITH NEW FULL-HEIGHT DEMISING WALL, NEW SEWER AND WATER LINES ALONG WITH ELECTRICAL RUNS (ALL TO BE CAPPED AT LOCATION OF FUTURE NEEDS). PREPPING SPACE FOR NEW TENANT (BY OTHERS) WHO WILL HAVE THEIR OWN TI PERMIT FOR ALL INTERIOR WORK.

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: All storm has been cleaned. There is still garbage left in the fire room. I highly recommend yearly maintenance on the storm system.

Corrections:

- 1 - Dilute, clean, and dry fire room floor.
- Vac and jet entire storm system along the west and north side of the building and the outlet to the swale.

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Jason Little
Development Engineering Inspector
JLittle@PuyallupWA.gov
(253) 244-0387